



Patterson ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003093	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 132	WF-06052018-003093	11/6/2018	FT-FY19-102018-003093-A	< 1	FT-FY19-102018-003093-B	< 1	
WS- 003095	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 131	WF-06052018-003095	11/6/2018	FT-FY19-102018-003095-A	< 1	FT-FY19-102018-003095-B	< 1	
WS- 003097	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 127	WF-06052018-003097	11/6/2018	FT-FY19-102018-003097-A	< 1	FT-FY19-102018-003097-B	< 1	
WS- 003099	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 125	WF-06052018-003099	11/6/2018	FT-FY19-102018-003099-A	< 1	FT-FY19-102018-003099-B	< 1	
WS- 003102	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 115	WF-06052018-003102	11/6/2018	FT-FY19-102018-003102-A	< 1	FT-FY19-102018-003102-B	< 1	
WS- 003103	10/17/2018	10/17/2019	1	Combo Faucet	In classroom 123	WF-10172018-003103	11/6/2018	FT-FY19-102018-003103-A	< 1	FT-FY19-102018-003103-B	< 1	
WS- 003104	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 123	WF-06052018-003104	11/6/2018	FT-FY19-102018-003104-A	< 1	FT-FY19-102018-003104-B	< 1	
WS- 003106	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 119	WF-06052018-003106	11/6/2018	FT-FY19-102018-003106-A	< 1	FT-FY19-102018-003106-B	< 1	
WS- 003108	6/5/2018	6/5/2019	1	Combo Fountain	In classroom 120	WF-06052018-003108	11/6/2018	FT-FY19-102018-003108-A	< 1	FT-FY19-102018-003108-B	< 1	
WS- 003109	6/5/2018	6/5/2019	1	Cooler	In hallway adjacent to restrooms	High Left	WF-06052018-003109	11/6/2018	FT-FY19-102018-003109-A	< 1	FT-FY19-102018-003109-B	< 1
WS- 003110	6/5/2018	6/5/2019	1	Cooler	In hallway adjacent to restrooms	Low Right	WF-06052018-003110	11/6/2018	FT-FY19-102018-003110-A	< 1	FT-FY19-102018-003110-B	< 1
WS- 003112	6/5/2018	6/5/2019	1	Cooler	In cafeteria 106	High Left	WF-06052018-003112	11/6/2018	FT-FY19-102018-003112-A	< 1	FT-FY19-102018-003112-B	< 1
WS- 003113	6/5/2018	6/5/2019	1	Cooler	In cafeteria 106	Low Right	WF-06052018-003113	11/6/2018	FT-FY19-102018-003113-A	< 1	FT-FY19-102018-003113-B	< 1
WS- 003117	10/25/2018	10/25/2019	2	Cooler	In hallway adjacent to restrooms	High Left	WF-10252018-003117	11/6/2018	FT-FY19-102018-003117-A	< 1	FT-FY19-102018-003117-B	< 1
WS- 003118	10/25/2018	10/25/2019	2	Cooler	In hallway adjacent to restrooms	Low Right	WF-10252018-003118	11/6/2018	FT-FY19-102018-003118-A	< 1	FT-FY19-102018-003118-B	< 1
WS- 003119	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 223	WF-10172018-003119	11/6/2018	FT-FY19-102018-003119-A	< 1	FT-FY19-102018-003119-B	< 1	
WS- 003120	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 223	WF-06052018-003120	11/6/2018	FT-FY19-102018-003120-A	< 1	FT-FY19-102018-003120-B	< 1	
WS- 003122	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 222	WF-06052018-003122	11/6/2018	FT-FY19-102018-003122-A	< 1	FT-FY19-102018-003122-B	< 1	
WS- 003124	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 224	WF-06052018-003124	11/6/2018	FT-FY19-102018-003124-A	< 1	FT-FY19-102018-003124-B	< 1	
WS- 003126	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 221	WF-06052018-003126	11/6/2018	FT-FY19-102018-003126-A	< 1	FT-FY19-102018-003126-B	< 1	
WS- 003127	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 220	WF-10172018-003127	11/6/2018	FT-FY19-102018-003127-A	< 1	FT-FY19-102018-003127-B	< 1	
WS- 003128	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 220	WF-06052018-003128	11/6/2018	FT-FY19-102018-003128-A	< 1	FT-FY19-102018-003128-B	< 1	
WS- 003129	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 225	WF-10172018-003129	11/6/2018	FT-FY19-102018-003129-A	< 1	FT-FY19-102018-003129-B	< 1	
WS- 003130	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 225	WF-06052018-003130	11/6/2018	FT-FY19-102018-003130-A	< 1	FT-FY19-102018-003130-B	< 1	
WS- 003131	6/5/2018	6/5/2019	2	Break Room	In staff work room 219	WF-06052018-003131	11/6/2018	FT-FY19-102018-003131-A	< 1	FT-FY19-102018-003131-B	< 1	
WS- 003132	6/5/2018	6/5/2019	2	Break Room	In staff work room 227	WF-06052018-003132	11/6/2018	FT-FY19-102018-003132-A	< 1	FT-FY19-102018-003132-B	< 1	
WS- 003133	6/5/2018	6/5/2019	2	Combo Fountain	In staff work room 227	WF-06052018-003133	11/6/2018	FT-FY19-102018-003133-A	< 1	FT-FY19-102018-003133-B	< 1	
WS- 003135	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 218	WF-06052018-003135	11/6/2018	FT-FY19-102018-003135-A	< 1	FT-FY19-102018-003135-B	< 1	
WS- 003137	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 226	WF-06052018-003137	11/6/2018	FT-FY19-102018-003137-A	< 1	FT-FY19-102018-003137-B	< 1	
WS- 003138	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 213	WF-10172018-003138	11/6/2018	FT-FY19-102018-003138-A	< 1	FT-FY19-102018-003138-B	< 1	
WS- 003139	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 213	WF-06052018-003139	11/6/2018	FT-FY19-102018-003139-A	< 1	FT-FY19-102018-003139-B	< 1	
WS- 003140	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 216	WF-10172018-003140	11/6/2018	FT-FY19-102018-003140-A	< 1	FT-FY19-102018-003140-B	< 1	
WS- 003141	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 216	WF-06052018-003141	11/6/2018	FT-FY19-102018-003141-A	< 1	FT-FY19-102018-003141-B	< 1	

WS- 003142	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 215	WF-10172018-003142	11/6/2018	FT-FY19-102018-003142-A	< 1	FT-FY19-102018-003142-B	< 1	
WS- 003143	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 215	WF-06052018-003143	11/6/2018	FT-FY19-102018-003143-A	< 1	FT-FY19-102018-003143-B	< 1	
WS- 003144	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 214	WF-10172018-003144	11/6/2018	FT-FY19-102018-003144-A	< 1	FT-FY19-102018-003144-B	< 1	
WS- 003145	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 214	WF-06052018-003145	11/6/2018	FT-FY19-102018-003145-A	< 1	FT-FY19-102018-003145-B	< 1	
WS- 003147	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 232	WF-10172018-003147	11/6/2018	FT-FY19-102018-003147-A	< 1	FT-FY19-102018-003147-B	< 1	
WS- 003148	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 232	WF-06052018-003148	11/6/2018	FT-FY19-102018-003148-A	< 1	FT-FY19-102018-003148-B	< 1	
WS- 003149	10/17/2018	10/17/2019	2	Combo Faucet	In classroom 230	WF-10172018-003149	11/6/2018	FT-FY19-102018-003149-A	< 1	FT-FY19-102018-003149-B	< 1	
WS- 003150	6/5/2018	6/5/2019	2	Combo Fountain	In classroom 230	WF-06052018-003150	11/6/2018	FT-FY19-102018-003150-A	< 1	FT-FY19-102018-003150-B	< 1	
WS- 003152	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 323	WF-06052018-003152	11/6/2018	FT-FY19-102018-003152-A	< 1	FT-FY19-102018-003152-B	< 1	
WS- 003154	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 324	WF-06052018-003154	11/6/2018	FT-FY19-102018-003154-A	< 1	FT-FY19-102018-003154-B	< 1	
WS- 003156	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 321	WF-06052018-003156	11/6/2018	FT-FY19-102018-003156-A	< 1	FT-FY19-102018-003156-B	< 1	
WS- 003159	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 317	WF-06052018-003159	11/6/2018	FT-FY19-102018-003159-A	< 1	FT-FY19-102018-003159-B	< 1	
WS- 003161	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 307	WF-06052018-003161	11/6/2018	FT-FY19-102018-003161-A	< 1	FT-FY19-102018-003161-B	< 1	
WS- 003165	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 312	WF-06052018-003165	11/6/2018	FT-FY19-102018-003165-A	< 1	FT-FY19-102018-003165-B	< 1	
WS- 003167	6/5/2018	6/5/2019	3	Combo Fountain	In classroom 311	WF-06052018-003167	11/6/2018	FT-FY19-102018-003167-A	< 1	FT-FY19-102018-003167-B	< 1	
WS- 003168	6/5/2018	6/5/2019	3	Cooler	In hallway adjacent to room 302	High Left	WF-06052018-003168	11/6/2018	FT-FY19-102018-003168-A	< 1	FT-FY19-102018-003168-B	< 1
WS- 003169	6/5/2018	6/5/2019	3	Cooler	In hallway adjacent to room 302	Low Right	WF-06052018-003169	11/6/2018	FT-FY19-102018-003169-A	< 1	FT-FY19-102018-003169-B	< 1
WS- 003170	6/5/2018	6/5/2019	1	Break Room	In custodians' break room 103		WF-06052018-003170	11/6/2018	FT-FY19-102018-003170-A	< 1	FT-FY19-102018-003170-B	< 1
WS- 003171	6/5/2018	6/5/2019	2	Health Suite	In health suite 202I		WF-06052018-003171	11/6/2018	FT-FY19-102018-003171-A	< 1	FT-FY19-102018-003171-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003116	1	Food Prep Sink	In kitchen		Right	11/6/2018	FT-FY19-102018-003116-A	< 1	FT-FY19-102018-003116-B	< 1