



Payne ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000116	2/3/2025	2/3/2026	1	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)	WF-02032025-000116	12/31/2025	FT-FY26-12112025-000116-A	<2	FT-FY26-12112025-000116-B	<2	
WS-000122	2/3/2025	2/3/2026	1	Cooler	In hallway adjacent to room 102	Low Right	WF-02032025-000122	12/31/2025	FT-FY26-12112025-000122-A	<2	FT-FY26-12112025-000122-B	<2
WS-000123	7/28/2025	7/28/2026	1	Combo Faucet	In parent resource room 104	Left	WF-07282025-000123	12/31/2025	FT-FY26-12112025-000123-A	<2	FT-FY26-12112025-000123-B	<2
WS-000124	2/3/2025	2/3/2026	1	Cooler	In hallway adjacent to room 102	Low Left	WF-02032025-000124	12/31/2025	FT-FY26-12112025-000124-A	<2	FT-FY26-12112025-000124-B	<2
WS-000126	2/3/2025	2/3/2026	1	Bottle Filler	In hallway adjacent to room 102 (bottle filler)		WF-02032025-000126	12/31/2025	FT-FY26-12112025-000126-A	<2	FT-FY26-12112025-000126-B	<2
WS-000131	2/3/2025	2/3/2026	1	Health Suite	In health suite 103	Left	WF-02032025-000131	12/31/2025	FT-FY26-12112025-000131-A	<2	FT-FY26-12112025-000131-B	<2
WS-000134	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 130	Low Left	WF-07282025-000134	12/31/2025	FT-FY26-12112025-000134-A	<2	FT-FY26-12112025-000134-B	<2
WS-000137	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 130	Low Left	WF-02032025-000137	12/31/2025	FT-FY26-12112025-000137-A	<2	FT-FY26-12112025-000137-B	<2
WS-000138	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 130	High Right	WF-07282025-000138	12/31/2025	FT-FY26-12112025-000138-A	<2	FT-FY26-12112025-000138-B	<2
WS-000141	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 134	Right	WF-07282025-000141	12/31/2025	FT-FY26-12112025-000141-A	<2	FT-FY26-12112025-000141-B	<2
WS-000142	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 134	High Left	WF-07282025-000142	12/31/2025	FT-FY26-12112025-000142-A	<2	FT-FY26-12112025-000142-B	<2
WS-000143	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 134	Low Right	WF-02032025-000143	12/31/2025	FT-FY26-12112025-000143-A	<2	FT-FY26-12112025-000143-B	<2
WS-000144	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 136	Low Left	WF-07282025-000144	12/31/2025	FT-FY26-12112025-000144-A	<2	FT-FY26-12112025-000144-B	<2
WS-000146	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 136	Low Left	WF-02032025-000146	12/31/2025	FT-FY26-12112025-000146-A	<2	FT-FY26-12112025-000146-B	<2
WS-000147	2/3/2025	2/3/2026	1	Bottle Filler	In hallway across from room 138 (bottle filler)		WF-02032025-000147	12/31/2025	FT-FY26-12112025-000147-A	<2	FT-FY26-12112025-000147-B	<2
WS-000148	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 136	High Right	WF-07282025-000148	12/31/2025	FT-FY26-12112025-000148-A	<2	FT-FY26-12112025-000148-B	<2
WS-000149	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 137	High Left	WF-07282025-000149	12/31/2025	FT-FY26-12112025-000149-A	<2	FT-FY26-12112025-000149-B	<2
WS-000150	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 137	Low Right	WF-07282025-000150	12/31/2025	FT-FY26-12112025-000150-A	<2	FT-FY26-12112025-000150-B	<2
WS-000151	2/3/2025	2/3/2026	1	Cooler	In hallway across from room 138	Low Right	WF-02032025-000151	12/31/2025	FT-FY26-12112025-000151-A	<2	FT-FY26-12112025-000151-B	<2
WS-000153	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 137	Low Right	WF-02032025-000153	12/31/2025	FT-FY26-12112025-000153-A	<2	FT-FY26-12112025-000153-B	<2
WS-000154	2/3/2025	2/3/2026	1	Cooler	In hallway across from room 138	Low Left	WF-02032025-000154	12/31/2025	FT-FY26-12112025-000154-A	<2	FT-FY26-12112025-000154-B	<2
WS-000155	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 138	High Left	WF-07282025-000155	12/31/2025	FT-FY26-12112025-000155-A	<2	FT-FY26-12112025-000155-B	<2
WS-000156	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 138	Low Right	WF-07282025-000156	12/31/2025	FT-FY26-12112025-000156-A	<2	FT-FY26-12112025-000156-B	<2
WS-000158	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 138	Low Right	WF-02032025-000158	12/31/2025	FT-FY26-12112025-000158-A	<2	FT-FY26-12112025-000158-B	<2
WS-000161	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 139	High Left	WF-07282025-000161	12/31/2025	FT-FY26-12112025-000161-A	<2	FT-FY26-12112025-000161-B	<2
WS-000162	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 142	Low Left	WF-07282025-000162	12/31/2025	FT-FY26-12112025-000162-A	<2	FT-FY26-12112025-000162-B	<2
WS-000163	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 139	Low Right	WF-07282025-000163	12/31/2025	FT-FY26-12112025-000163-A	<2	FT-FY26-12112025-000163-B	<2
WS-000164	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 142	Low Left	WF-02032025-000164	12/31/2025	FT-FY26-12112025-000164-A	<2	FT-FY26-12112025-000164-B	<2
WS-000165	7/28/2025	7/28/2026	1	Classroom Faucet	In classroom 142	High Right	WF-07282025-000165	12/31/2025	FT-FY26-12112025-000165-A	<2	FT-FY26-12112025-000165-B	<2
WS-000167	2/3/2025	2/3/2026	1	Combo Fountain	In classroom 139	Low Right	WF-02032025-000167	12/31/2025	FT-FY26-12112025-000167-A	<2	FT-FY26-12112025-000167-B	<2
WS-000169	2/3/2025	2/3/2026	1	Cooler	In hallway adjacent to room 142	Low Right	WF-02032025-000169	12/31/2025	FT-FY26-12112025-000169-A	<2	FT-FY26-12112025-000169-B	<2
WS-000170	11/14/2025	11/14/2026	1	Cooler	In hallway adjacent to room 142	Low Left	WF-11142025-000170	12/31/2025	FT-FY26-12112025-000170-A	<2	FT-FY26-12112025-000170-B	<2
WS-000171	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 204	High Left	WF-07282025-000171	12/31/2025	FT-FY26-12112025-000171-A	<2	FT-FY26-12112025-000171-B	<2
WS-000173	2/3/2025	2/3/2026	2	Combo Fountain	In classroom 204	High Left	WF-02032025-000173	12/31/2025	FT-FY26-12112025-000173-A	<2	FT-FY26-12112025-000173-B	<2

WS-000177	2/3/2025	2/3/2026	2	Bottle Filler	In classroom 204 (bottle filler)		WF-02032025-000177	12/31/2025	FT-FY26-12112025-000177-A	<2	FT-FY26-12112025-000177-B	<2
WS-000178	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 205	Left	WF-07282025-000178	12/31/2025	FT-FY26-12112025-000178-A	<2	FT-FY26-12112025-000178-B	<2
WS-000179	2/3/2025	2/3/2026	2	Cooler	In classroom 204	Low Left	WF-02032025-000179	12/31/2025	FT-FY26-12112025-000179-A	<2	FT-FY26-12112025-000179-B	<2
WS-000180	2/3/2025	2/3/2026	2	Combo Fountain	In classroom 205	Right	WF-02032025-000180	12/31/2025	FT-FY26-12112025-000180-A	<2	FT-FY26-12112025-000180-B	<2
WS-000181	2/3/2025	2/3/2026	2	Cooler	In classroom 204	Low Right	WF-02032025-000181	12/31/2025	FT-FY26-12112025-000181-A	<2	FT-FY26-12112025-000181-B	<2
WS-000182	2/3/2025	2/3/2026	2	Cooler	In hallway adjacent to boys' restroom	Low Left	WF-02032025-000182	12/31/2025	FT-FY26-12112025-000182-A	<2	FT-FY26-12112025-000182-B	<2
WS-000185	2/3/2025	2/3/2026	2	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-02032025-000185	12/31/2025	FT-FY26-12112025-000185-A	<2	FT-FY26-12112025-000185-B	<2
WS-000188	2/3/2025	2/3/2026	2	Bottle Filler	In hallway adjacent to boys' restroom (bottle filler)		WF-02032025-000188	12/31/2025	FT-FY26-12112025-000188-A	<2	FT-FY26-12112025-000188-B	<2
WS-000189	7/28/2025	7/28/2026	2	Combo Faucet	In classroom 209	Left	WF-07282025-000189	12/31/2025	FT-FY26-12112025-000189-A	<2	FT-FY26-12112025-000189-B	<2
WS-000191	2/3/2025	2/3/2026	2	Combo Fountain	In classroom 209	Right	WF-02032025-000191	12/31/2025	FT-FY26-12112025-000191-A	<2	FT-FY26-12112025-000191-B	<2
WS-000194	2/3/2025	2/3/2026	3	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-02032025-000194	12/31/2025	FT-FY26-12112025-000194-A	<2	FT-FY26-12112025-000194-B	<2
WS-000198	2/3/2025	2/3/2026	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-02032025-000198	12/31/2025	FT-FY26-12112025-000198-A	<2	FT-FY26-12112025-000198-B	<2
WS-000200	2/3/2025	2/3/2026	3	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler)		WF-02032025-000200	12/31/2025	FT-FY26-12112025-000200-A	<2	FT-FY26-12112025-000200-B	<2
WS-000203	2/3/2025	2/3/2026	3	Break Room	In break room 306		WF-02032025-000203	12/31/2025	FT-FY26-12112025-000203-A	<2	FT-FY26-12112025-000203-B	<2
WS-000205	2/3/2025	2/3/2026	1	Ice Maker	In kitchen (ice maker)		WF-02032025-000205	12/31/2025	FT-FY26-12112025-000205-A	<2	FT-FY26-12112025-000205-B	<2
WS-000209	2/3/2025	2/3/2026	2	Cooler	In hallway adjacent to room 236	Low Left	WF-02032025-000209	12/31/2025	FT-FY26-12112025-000209-A	<2	FT-FY26-12112025-000209-B	<2
WS-000211	2/3/2025	2/3/2026	2	Bottle Filler	In hallway adjacent to room 236 (bottle filler)		WF-02032025-000211	12/31/2025	FT-FY26-12112025-000211-A	<2	FT-FY26-12112025-000211-B	<2
WS-000214	2/3/2025	2/3/2026	2	Cooler	In hallway adjacent to room 236	Low Right	WF-02032025-000214	12/31/2025	FT-FY26-12112025-000214-A	<2	FT-FY26-12112025-000214-B	<2
WS-000217	2/3/2025	2/3/2026	2	Break Room	In breakroom 224		WF-02032025-000217	12/31/2025	FT-FY26-12112025-000217-A	<2	FT-FY26-12112025-000217-B	<2
WS-000222	2/3/2025	2/3/2026	2	Cooler	In hallway adjacent to room 224	Low Left	WF-02032025-000222	12/31/2025	FT-FY26-12112025-000222-A	<2	FT-FY26-12112025-000222-B	<2
WS-000223	2/3/2025	2/3/2026	2	Bottle Filler	In hallway adjacent to room 224 (bottle filler)		WF-02032025-000223	12/31/2025	FT-FY26-12112025-000223-A	<2	FT-FY26-12112025-000223-B	<2
WS-000224	2/3/2025	2/3/2026	2	Cooler	In hallway adjacent to room 224	Low Right	WF-02032025-000224	12/31/2025	FT-FY26-12112025-000224-A	<2	FT-FY26-12112025-000224-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000111	12/1/2025	12/1/2026	1	Food Prep Sink	In kitchen sixth clockwise from entry door	Right	WF-12012025-000111	12/31/2025	FT-FY26-12112025-000111-A	<2	FT-FY26-12112025-000111-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.