



Payne ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000115	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to cafeteria Low Right	WF-03182019-000115	12/2/2019	FT-FY20-112019-000115-A	<1	FT-FY20-112019-000115-B	<1
WS-000116	3/18/2019	3/18/2020	1	Bottle Filler	In hallway adjacent to cafeteria	WF-03182019-000116	12/2/2019	FT-FY20-112019-000116-A	<1	FT-FY20-112019-000116-B	<1
WS-000117	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to cafeteria Low Left	WF-03182019-000117	12/2/2019	FT-FY20-112019-000117-A	<1	FT-FY20-112019-000117-B	<1
WS-000118	3/18/2019	3/18/2020	1	Break Room	In break room 115B Left	WF-03182019-000118	12/2/2019	FT-FY20-112019-000118-A	<1	FT-FY20-112019-000118-B	<1
WS-000122	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to room 102 Low Right	WF-03182019-000122	12/2/2019	FT-FY20-112019-000122-A	<1	FT-FY20-112019-000122-B	<1
WS-000123	9/10/2019	9/10/2020	1	Combo Faucet	In parent resource room 104 Left	WF-09102019-000123	12/2/2019	FT-FY20-112019-000123-A	<1	FT-FY20-112019-000123-B	<1
WS-000124	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to room 102 Low Left	WF-03182019-000124	12/2/2019	FT-FY20-112019-000124-A	<1	FT-FY20-112019-000124-B	<1
WS-000125	3/18/2019	3/18/2020	1	Combo Fountain	In parent resource room 104 Right	WF-03182019-000125	12/2/2019	FT-FY20-112019-000125-A	<1	FT-FY20-112019-000125-B	<1
WS-000126	3/18/2019	3/18/2020	1	Bottle Filler	In hallway adjacent to room 102	WF-03182019-000126	12/2/2019	FT-FY20-112019-000126-A	<1	FT-FY20-112019-000126-B	<1
WS-000130	3/18/2019	3/18/2020	1	Health Suite	In health suite in unisex restroom 103	WF-03182019-000130	12/2/2019	FT-FY20-112019-000130-A	<1	FT-FY20-112019-000130-B	<1
WS-000131	3/18/2019	3/18/2020	1	Health Suite	In health suite 103 Left	WF-03182019-000131	12/2/2019	FT-FY20-112019-000131-A	<1	FT-FY20-112019-000131-B	<1
WS-000133	3/18/2019	3/18/2020	1	Combo Fountain	In health suite 103 Right	WF-03182019-000133	12/2/2019	FT-FY20-112019-000133-A	<1	FT-FY20-112019-000133-B	<1
WS-000134	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 130 Low Left	WF-09102019-000134	12/2/2019	FT-FY20-112019-000134-A	<1	FT-FY20-112019-000134-B	<1
WS-000137	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 130 Low Left	WF-03182019-000137	12/2/2019	FT-FY20-112019-000137-A	<1	FT-FY20-112019-000137-B	<1
WS-000138	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 130 High Right	WF-09102019-000138	12/2/2019	FT-FY20-112019-000138-A	2.7	FT-FY20-112019-000138-B	<1
WS-000141	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 134 Right	WF-09102019-000141	12/2/2019	FT-FY20-112019-000141-A	<1	FT-FY20-112019-000141-B	<1
WS-000142	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 134 High Left	WF-09102019-000142	12/2/2019	FT-FY20-112019-000142-A	<1	FT-FY20-112019-000142-B	<1
WS-000143	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 134 Low Right	WF-03182019-000143	12/2/2019	FT-FY20-112019-000143-A	<1	FT-FY20-112019-000143-B	<1
WS-000144	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 136 Low Left	WF-09102019-000144	12/2/2019	FT-FY20-112019-000144-A	<1	FT-FY20-112019-000144-B	<1
WS-000146	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 136 Low Left	WF-03182019-000146	12/2/2019	FT-FY20-112019-000146-A	<1	FT-FY20-112019-000146-B	<1
WS-000147	3/18/2019	3/18/2020	1	Bottle Filler	In hallway across from room 138	WF-03182019-000147	12/2/2019	FT-FY20-112019-000147-A	<1	FT-FY20-112019-000147-B	<1
WS-000148	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 136 High Right	WF-09102019-000148	12/2/2019	FT-FY20-112019-000148-A	<1	FT-FY20-112019-000148-B	<1
WS-000149	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 137 High Left	WF-09102019-000149	12/2/2019	FT-FY20-112019-000149-A	<1	FT-FY20-112019-000149-B	<1
WS-000150	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 137 Low Right	WF-09102019-000150	12/2/2019	FT-FY20-112019-000150-A	<1	FT-FY20-112019-000150-B	<1
WS-000151	3/18/2019	3/18/2020	1	Cooler	In hallway across from room 138 Low Right	WF-03182019-000151	12/2/2019	FT-FY20-112019-000151-A	<1	FT-FY20-112019-000151-B	<1
WS-000153	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 137 Low Right	WF-03182019-000153	12/2/2019	FT-FY20-112019-000153-A	<1	FT-FY20-112019-000153-B	<1
WS-000154	3/18/2019	3/18/2020	1	Cooler	In hallway across from room 138 Low Left	WF-03182019-000154	12/2/2019	FT-FY20-112019-000154-A	<1	FT-FY20-112019-000154-B	<1
WS-000155	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 138 High Left	WF-09102019-000155	12/2/2019	FT-FY20-112019-000155-A	<1	FT-FY20-112019-000155-B	<1
WS-000156	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 138 Low Right	WF-09102019-000156	12/2/2019	FT-FY20-112019-000156-A	<1	FT-FY20-112019-000156-B	<1
WS-000158	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 138 Low Right	WF-03182019-000158	12/2/2019	FT-FY20-112019-000158-A	<1	FT-FY20-112019-000158-B	<1
WS-000161	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 139 High Left	WF-09102019-000161	12/2/2019	FT-FY20-112019-000161-A	1.3	FT-FY20-112019-000161-B	<1
WS-000162	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 142 Low Left	WF-09102019-000162	12/2/2019	FT-FY20-112019-000162-A	<1	FT-FY20-112019-000162-B	<1
WS-000163	9/10/2019	9/10/2020	1	Combo Faucet	In classroom 139 Low Right	WF-09102019-000163	12/2/2019	FT-FY20-112019-000163-A	<1	FT-FY20-112019-000163-B	<1
WS-000164	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 142 Low Left	WF-03182019-000164	12/2/2019	FT-FY20-112019-000164-A	<1	FT-FY20-112019-000164-B	<1

WS- 000165	9/10/2019	9/10/2020	1	Classroom Faucet	In classroom 142	High	Right	WF-09102019-000165	12/2/2019	FT-FY20-112019-000165-A	<1	FT-FY20-112019-000165-B	<1
WS- 000167	3/18/2019	3/18/2020	1	Combo Fountain	In classroom 139	Low	Right	WF-03182019-000167	12/2/2019	FT-FY20-112019-000167-A	<1	FT-FY20-112019-000167-B	<1
WS- 000169	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to room 142	Low	Right	WF-03182019-000169	12/2/2019	FT-FY20-112019-000169-A	<1	FT-FY20-112019-000169-B	<1
WS- 000170	3/18/2019	3/18/2020	1	Cooler	In hallway adjacent to room 142	Low	Left	WF-03182019-000170	12/2/2019	FT-FY20-112019-000170-A	<1	FT-FY20-112019-000170-B	<1
WS- 000171	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 204	High	Left	WF-09102019-000171	12/2/2019	FT-FY20-112019-000171-A	<1	FT-FY20-112019-000171-B	<1
WS- 000173	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 204	High	Left	WF-03182019-000173	12/2/2019	FT-FY20-112019-000173-A	<1	FT-FY20-112019-000173-B	<1
WS- 000177	3/18/2019	3/18/2020	2	Bottle Filler	In classroom 204 (bottle filler)			WF-03182019-000177	12/2/2019	FT-FY20-112019-000177-A	<1	FT-FY20-112019-000177-B	<1
WS- 000178	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 205		Left	WF-09102019-000178	12/2/2019	FT-FY20-112019-000178-A	<1	FT-FY20-112019-000178-B	<1
WS- 000179	3/18/2019	3/18/2020	2	Cooler	In classroom 204	Low	Left	WF-03182019-000179	12/2/2019	FT-FY20-112019-000179-A	<1	FT-FY20-112019-000179-B	<1
WS- 000180	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 205		Right	WF-03182019-000180	12/2/2019	FT-FY20-112019-000180-A	<1	FT-FY20-112019-000180-B	<1
WS- 000181	3/18/2019	3/18/2020	2	Cooler	In classroom 204	Low	Right	WF-03182019-000181	12/2/2019	FT-FY20-112019-000181-A	<1	FT-FY20-112019-000181-B	<1
WS- 000182	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to boys' restroom	Low	Left	WF-03182019-000182	12/2/2019	FT-FY20-112019-000182-A	<1	FT-FY20-112019-000182-B	<1
WS- 000185	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to boys' restroom	Low	Right	WF-03182019-000185	12/2/2019	FT-FY20-112019-000185-A	<1	FT-FY20-112019-000185-B	<1
WS- 000188	3/18/2019	3/18/2020	2	Bottle Filler	In hallway adjacent to boys' restroom			WF-03182019-000188	12/2/2019	FT-FY20-112019-000188-A	<1	FT-FY20-112019-000188-B	<1
WS- 000189	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 209		Left	WF-09102019-000189	12/2/2019	FT-FY20-112019-000189-A	<1	FT-FY20-112019-000189-B	<1
WS- 000191	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 209		Right	WF-03182019-000191	12/2/2019	FT-FY20-112019-000191-A	<1	FT-FY20-112019-000191-B	<1
WS- 000194	3/18/2019	3/18/2020	3	Cooler	In hallway adjacent to girls' restroom	Low	Right	WF-03182019-000194	12/2/2019	FT-FY20-112019-000194-A	<1	FT-FY20-112019-000194-B	<1
WS- 000198	3/18/2019	3/18/2020	3	Cooler	In hallway adjacent to girls' restroom	High	Left	WF-03182019-000198	12/2/2019	FT-FY20-112019-000198-A	<1	FT-FY20-112019-000198-B	<1
WS- 000200	3/18/2019	3/18/2020	3	Bottle Filler	In hallway adjacent to girls' restroom			WF-03182019-000200	12/2/2019	FT-FY20-112019-000200-A	<1	FT-FY20-112019-000200-B	<1
WS- 000203	3/18/2019	3/18/2020	3	Break Room	In break room 306			WF-03182019-000203	12/2/2019	FT-FY20-112019-000203-A	<1	FT-FY20-112019-000203-B	<1
WS- 000204	3/18/2019	3/18/2020	3	Combo Fountain	In break room 306			WF-03182019-000204	12/2/2019	FT-FY20-112019-000204-A	<1	FT-FY20-112019-000204-B	<1
WS- 000205	3/18/2019	3/18/2020	1	Ice Maker	In kitchen (ice maker)			WF-03182019-000205	12/2/2019	FT-FY20-112019-000205-A	<1	FT-FY20-112019-000205-B	<1
WS- 000206	9/10/2019	9/10/2020	2	Combo Faucet	In classroom 240		Left	WF-09102019-000206	12/2/2019	FT-FY20-112019-000206-A	<1	FT-FY20-112019-000206-B	<1
WS- 000209	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to room 236	Low	Left	WF-03182019-000209	12/2/2019	FT-FY20-112019-000209-A	<1	FT-FY20-112019-000209-B	<1
WS- 000210	3/18/2019	3/18/2020	2	Combo Fountain	In classroom 240			WF-03182019-000210	12/2/2019	FT-FY20-112019-000210-A	<1	FT-FY20-112019-000210-B	<1
WS- 000211	3/18/2019	3/18/2020	2	Bottle Filler	In hallway adjacent to room 236			WF-03182019-000211	12/2/2019	FT-FY20-112019-000211-A	<1	FT-FY20-112019-000211-B	<1
WS- 000214	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to room 236	Low	Right	WF-03182019-000214	12/2/2019	FT-FY20-112019-000214-A	<1	FT-FY20-112019-000214-B	<1
WS- 000217	3/18/2019	3/18/2020	2	Break Room	In breakroom 224			WF-03182019-000217	12/2/2019	FT-FY20-112019-000217-A	<1	FT-FY20-112019-000217-B	<1
WS- 000222	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to room 224	Low	Left	WF-03182019-000222	12/2/2019	FT-FY20-112019-000222-A	<1	FT-FY20-112019-000222-B	<1
WS- 000223	3/18/2019	3/18/2020	2	Bottle Filler	In hallway adjacent to room 224			WF-03182019-000223	12/2/2019	FT-FY20-112019-000223-A	<1	FT-FY20-112019-000223-B	<1
WS- 000224	3/18/2019	3/18/2020	2	Cooler	In hallway adjacent to room 224	Low	Right	WF-03182019-000224	12/2/2019	FT-FY20-112019-000224-A	<1	FT-FY20-112019-000224-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000111	7/1/2019	7/1/2020	1	Food Prep Sink	In kitchen sixth clockwise from entry door	Right	WF-07012019-000111	12/2/2019	FT-FY20-112019-000111-A	<1	FT-FY20-112019-000111-B	<1