



Payne Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000115	2/15/2023	2/15/2024	1	Cooler	In hallway adjacent to cafeteria	Low Right	WF-02152023-000115	1/2/2024	FT-FY24-11012023-000115-A	<1	FT-FY24-11012023-000115-B	<1
WS- 000116	2/15/2023	2/15/2024	1	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)		WF-02152023-000116	1/2/2024	FT-FY24-11012023-000116-A	<1	FT-FY24-11012023-000116-B	<1
WS- 000117	2/15/2023	2/15/2024	1	Cooler	In hallway adjacent to cafeteria	Low Left	WF-02152023-000117	1/2/2024	FT-FY24-11012023-000117-A	<1	FT-FY24-11012023-000117-B	<1
WS- 000118	2/15/2023	2/15/2024	1	Break Room	In break room 115B	Left	WF-02152023-000118	1/2/2024	FT-FY24-11012023-000118-A	<1	FT-FY24-11012023-000118-B	<1
WS- 000122	2/15/2023	2/15/2024	1	Cooler	In hallway adjacent to room 102	Low Right	WF-02152023-000122	1/2/2024	FT-FY24-11012023-000122-A	<1	FT-FY24-11012023-000122-B	<1
WS- 000123	8/7/2023	8/7/2024	1	Combo Faucet	In parent resource room 104	Left	WF-08072023-000123	1/2/2024	FT-FY24-11012023-000123-A	2.9	FT-FY24-11012023-000123-B	<1
WS- 000124	2/15/2023	2/15/2024	1	Cooler	In hallway adjacent to room 102	Low Left	WF-02152023-000124	1/2/2024	FT-FY24-11012023-000124-A	<1	FT-FY24-11012023-000124-B	<1
WS- 000126	2/15/2023	2/15/2024	1	Bottle Filler	In hallway adjacent to room 102 (bottle filler)		WF-02152023-000126	1/2/2024	FT-FY24-11012023-000126-A	<1	FT-FY24-11012023-000126-B	<1
WS- 000130	2/15/2023	2/15/2024	1	Health Suite	In health suite in unisex restroom 103		WF-02152023-000130	1/2/2024	FT-FY24-11012023-000130-A	<1	FT-FY24-11012023-000130-B	<1
WS- 000131	2/15/2023	2/15/2024	1	Health Suite	In health suite 103	Left	WF-02152023-000131	1/2/2024	FT-FY24-11012023-000131-A	3.8	FT-FY24-11012023-000131-B	<1
WS- 000134	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 130	Low Left	WF-08072023-000134	1/2/2024	FT-FY24-11012023-000134-A	<1	FT-FY24-11012023-000134-B	<1
WS- 000137	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 130	Low Left	WF-02152023-000137	1/2/2024	FT-FY24-11012023-000137-A	1.2	FT-FY24-11012023-000137-B	<1
WS- 000138	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 130	High Right	WF-08072023-000138	1/2/2024	FT-FY24-11012023-000138-A	2.2	FT-FY24-11012023-000138-B	<1
WS- 000141	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 134	Right	WF-08072023-000141	1/2/2024	FT-FY24-11012023-000141-A	2.4	FT-FY24-11012023-000141-B	<1
WS- 000142	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 134	High Left	WF-08072023-000142	1/2/2024	FT-FY24-11012023-000142-A	2.3	FT-FY24-11012023-000142-B	<1
WS- 000143	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 134	Low Right	WF-02152023-000143	1/2/2024	FT-FY24-11012023-000143-A	<1	FT-FY24-11012023-000143-B	<1
WS- 000144	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 136	Low Left	WF-08072023-000144	1/2/2024	FT-FY24-11012023-000144-A	<1	FT-FY24-11012023-000144-B	<1
WS- 000146	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 136	Low Left	WF-02152023-000146	1/2/2024	FT-FY24-11012023-000146-A	1.0	FT-FY24-11012023-000146-B	<1
WS- 000147	2/15/2023	2/15/2024	1	Bottle Filler	In hallway across from room 138 (bottle filler)		WF-02152023-000147	1/2/2024	FT-FY24-11012023-000147-A	<1	FT-FY24-11012023-000147-B	<1
WS- 000148	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 136	High Right	WF-08072023-000148	1/2/2024	FT-FY24-11012023-000148-A	4.9	FT-FY24-11012023-000148-B	<1
WS- 000150	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 137	Low Right	WF-08072023-000150	1/2/2024	FT-FY24-11012023-000150-A	<1	FT-FY24-11012023-000150-B	<1
WS- 000151	2/15/2023	2/15/2024	1	Cooler	In hallway across from room 138	Low Right	WF-02152023-000151	1/2/2024	FT-FY24-11012023-000151-A	<1	FT-FY24-11012023-000151-B	<1
WS- 000153	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 137	Low Right	WF-02152023-000153	1/2/2024	FT-FY24-11012023-000153-A	<1	FT-FY24-11012023-000153-B	<1
WS- 000154	2/15/2023	2/15/2024	1	Cooler	In hallway across from room 138	Low Left	WF-02152023-000154	1/2/2024	FT-FY24-11012023-000154-A	<1	FT-FY24-11012023-000154-B	<1
WS- 000155	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 138	High Left	WF-08072023-000155	1/2/2024	FT-FY24-11012023-000155-A	1.0	FT-FY24-11012023-000155-B	<1
WS- 000156	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 138	Low Right	WF-08072023-000156	1/2/2024	FT-FY24-11012023-000156-A	2.0	FT-FY24-11012023-000156-B	<1
WS- 000158	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 138	Low Right	WF-02152023-000158	1/2/2024	FT-FY24-11012023-000158-A	1.6	FT-FY24-11012023-000158-B	<1
WS- 000161	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 139	High Left	WF-08072023-000161	1/2/2024	FT-FY24-11012023-000161-A	<1	FT-FY24-11012023-000161-B	<1
WS- 000162	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 142	Low Left	WF-08072023-000162	1/2/2024	FT-FY24-11012023-000162-A	<1	FT-FY24-11012023-000162-B	<1
WS- 000163	8/7/2023	8/7/2024	1	Combo Faucet	In classroom 139	Low Right	WF-08072023-000163	1/2/2024	FT-FY24-11012023-000163-A	<1	FT-FY24-11012023-000163-B	<1
WS- 000164	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 142	Low Left	WF-02152023-000164	1/2/2024	FT-FY24-11012023-000164-A	<1	FT-FY24-11012023-000164-B	<1
WS- 000165	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 142	High Right	WF-08072023-000165	1/2/2024	FT-FY24-11012023-000165-A	3.9	FT-FY24-11012023-000165-B	<1
WS- 000167	2/15/2023	2/15/2024	1	Combo Fountain	In classroom 139	Low Right	WF-02152023-000167	1/2/2024	FT-FY24-11012023-000167-A	1.2	FT-FY24-11012023-000167-B	1.2
WS- 000168	2/15/2023	2/15/2024	1	Bottle Filler	In hallway adjacent to room 142 (bottle filler)		WF-02152023-000168	1/2/2024	FT-FY24-11012023-000168-A	<1	FT-FY24-11012023-000168-B	<1

WS- 000169	2/15/2023	2/15/2024	1	Cooler	In hallway adjacent to room 142	Low	Right	WF-02152023-000169	1/2/2024	FT-FY24-11012023-000169-A	<1	FT-FY24-11012023-000169-B	<1
WS- 000170	2/15/2023	2/15/2024	1	Cooler	In hallway adjacent to room 142	Low	Left	WF-02152023-000170	1/2/2024	FT-FY24-11012023-000170-A	<1	FT-FY24-11012023-000170-B	<1
WS- 000171	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 204	High	Left	WF-08072023-000171	1/2/2024	FT-FY24-11012023-000171-A	2.4	FT-FY24-11012023-000171-B	<1
WS- 000173	2/15/2023	2/15/2024	2	Combo Fountain	In classroom 204	High	Left	WF-02152023-000173	1/2/2024	FT-FY24-11012023-000173-A	2.4	FT-FY24-11012023-000173-B	<1
WS- 000177	2/15/2023	2/15/2024	2	Bottle Filler	In classroom 204 (bottle filler)			WF-02152023-000177	1/2/2024	FT-FY24-11012023-000177-A	<1	FT-FY24-11012023-000177-B	<1
WS- 000178	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 205		Left	WF-08072023-000178	1/2/2024	FT-FY24-11012023-000178-A	1.7	FT-FY24-11012023-000178-B	<1
WS- 000179	2/15/2023	2/15/2024	2	Cooler	In classroom 204	Low	Left	WF-02152023-000179	1/2/2024	FT-FY24-11012023-000179-A	<1	FT-FY24-11012023-000179-B	<1
WS- 000180	2/15/2023	2/15/2024	2	Combo Fountain	In classroom 205		Right	WF-02152023-000180	1/2/2024	FT-FY24-11012023-000180-A	<1	FT-FY24-11012023-000180-B	<1
WS- 000181	2/15/2023	2/15/2024	2	Cooler	In classroom 204	Low	Right	WF-02152023-000181	1/2/2024	FT-FY24-11012023-000181-A	<1	FT-FY24-11012023-000181-B	<1
WS- 000182	2/15/2023	2/15/2024	2	Cooler	In hallway adjacent to boys' restroom	Low	Left	WF-02152023-000182	1/2/2024	FT-FY24-11012023-000182-A	<1	FT-FY24-11012023-000182-B	<1
WS- 000185	2/15/2023	2/15/2024	2	Cooler	In hallway adjacent to boys' restroom	Low	Right	WF-02152023-000185	1/2/2024	FT-FY24-11012023-000185-A	<1	FT-FY24-11012023-000185-B	<1
WS- 000188	2/15/2023	2/15/2024	2	Bottle Filler	In hallway adjacent to boys' restroom (bottle filler)			WF-02152023-000188	1/2/2024	FT-FY24-11012023-000188-A	<1	FT-FY24-11012023-000188-B	<1
WS- 000189	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 209		Left	WF-08072023-000189	1/2/2024	FT-FY24-11012023-000189-A	1.0	FT-FY24-11012023-000189-B	<1
WS- 000191	2/15/2023	2/15/2024	2	Combo Fountain	In classroom 209		Right	WF-02152023-000191	1/2/2024	FT-FY24-11012023-000191-A	2.9	FT-FY24-11012023-000191-B	<1
WS- 000194	2/15/2023	2/15/2024	3	Cooler	In hallway adjacent to girls' restroom	Low	Right	WF-02152023-000194	1/2/2024	FT-FY24-11012023-000194-A	<1	FT-FY24-11012023-000194-B	<1
WS- 000198	2/15/2023	2/15/2024	3	Cooler	In hallway adjacent to girls' restroom	High	Left	WF-02152023-000198	1/2/2024	FT-FY24-11012023-000198-A	<1	FT-FY24-11012023-000198-B	<1
WS- 000200	2/15/2023	2/15/2024	3	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler)			WF-02152023-000200	1/2/2024	FT-FY24-11012023-000200-A	<1	FT-FY24-11012023-000200-B	<1
WS- 000203	2/15/2023	2/15/2024	3	Break Room	In break room 306			WF-02152023-000203	1/2/2024	FT-FY24-11012023-000203-A	1.0	FT-FY24-11012023-000203-B	<1
WS- 000205	2/15/2023	2/15/2024	1	Ice Maker	In kitchen (ice maker)			WF-02152023-000205	1/2/2024	FT-FY24-11012023-000205-A	<1	FT-FY24-11012023-000205-B	<1
WS- 000206	8/7/2023	8/7/2024	2	Combo Faucet	In classroom 240		Left	WF-08072023-000206	1/2/2024	FT-FY24-11012023-000206-A	1.6	FT-FY24-11012023-000206-B	<1
WS- 000209	2/15/2023	2/15/2024	2	Cooler	In hallway adjacent to room 236	Low	Left	WF-02152023-000209	1/2/2024	FT-FY24-11012023-000209-A	<1	FT-FY24-11012023-000209-B	<1
WS- 000211	2/15/2023	2/15/2024	2	Bottle Filler	In hallway adjacent to room 236 (bottle filler)			WF-02152023-000211	1/2/2024	FT-FY24-11012023-000211-A	<1	FT-FY24-11012023-000211-B	<1
WS- 000214	2/15/2023	2/15/2024	2	Cooler	In hallway adjacent to room 236	Low	Right	WF-02152023-000214	1/2/2024	FT-FY24-11012023-000214-A	<1	FT-FY24-11012023-000214-B	<1
WS- 000217	2/15/2023	2/15/2024	2	Break Room	In breakroom 224			WF-02152023-000217	1/2/2024	FT-FY24-11012023-000217-A	1.1	FT-FY24-11012023-000217-B	<1
WS- 000222	2/15/2023	2/15/2024	2	Cooler	In hallway adjacent to room 224	Low	Left	WF-02152023-000222	1/2/2024	FT-FY24-11012023-000222-A	<1	FT-FY24-11012023-000222-B	<1
WS- 000223	2/15/2023	2/15/2024	2	Bottle Filler	In hallway adjacent to room 224 (bottle filler)			WF-02152023-000223	1/2/2024	FT-FY24-11012023-000223-A	<1	FT-FY24-11012023-000223-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 000111	1/19/2023	1/19/2024	1	Food Prep Sink	In kitchen sixth clockwise from entry door		Right	WF-01192023-000111	1/2/2024	FT-FY24-11012023-000111-A	<1	FT-FY24-11012023-000111-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation														
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 000149	8/7/2023	8/7/2024	1	Classroom Faucet	In classroom 137		High	Left	WF-08072023-000149	1/2/2024	FT-FY24-11012023-000149-A	5.6	FT-FY24-11012023-000149-B	<1
WS- 000210	2/15/2023	2/15/2024	2	Combo Fountain	In classroom 240				WF-02152023-000210	1/2/2024	FT-FY24-11012023-000210-A	5.0	FT-FY24-11012023-000210-B	<1

**First Re-test (After Plumbing Check)
FY24 Filter Test**

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000149	1/4/2024	1/4/2025	1	Classroom Faucet	In classroom 137 High Left	WF-01042024-000149	1/17/2024	FT-FY24-01122024-000149-A	2.7	FT-FY24-01122024-000149-B	1.8
WS- 000210	1/4/2024	1/4/2025	2	Combo Fountain	In classroom 240	WF-01042024-000210	1/17/2024	FT-FY24-01122024-000210-A	4.5	FT-FY24-01122024-000210-B	1.4