



PAYNE ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service												
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location			1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	PAYNE ELEMENTARY SCHOOL	WS-000165	1/16/2017	1	Classroom Faucet	In classroom 181	High	Right	FT-112016-000165-A	< 1	FT-112016-000165-B	< 1
2	PAYNE ELEMENTARY SCHOOL	WS-000162	1/16/2017	1	Combo Faucet	In classroom 181	Low	Left	FT-112016-000162-A	< 1	FT-112016-000162-B	< 1
3	PAYNE ELEMENTARY SCHOOL	WS-000148	1/16/2017	1	Classroom Faucet	In classroom 168	High	Right	FT-112016-000148-A	< 1	FT-112016-000148-B	< 1
4	PAYNE ELEMENTARY SCHOOL	WS-000150	1/16/2017	1	Combo Faucet	In classroom 187	Low	Right	FT-112016-000150-A	< 1	FT-112016-000150-B	< 1
5	PAYNE ELEMENTARY SCHOOL	WS-000156	1/16/2017	1	Combo Faucet	In classroom 184	Low	Right	FT-112016-000156-A	< 1	FT-112016-000156-B	< 1
6	PAYNE ELEMENTARY SCHOOL	WS-000142	1/16/2017	1	Classroom Faucet	In classroom 190	High	Left	FT-112016-000142-A	< 1	FT-112016-000142-B	< 1
7	PAYNE ELEMENTARY SCHOOL	WS-000163	1/16/2017	1	Combo Faucet	In classroom 172	Low	Right	FT-112016-000163-A	< 1	FT-112016-000163-B	< 1
8	PAYNE ELEMENTARY SCHOOL	WS-000118	1/16/2017	1	Break Room	In classroom 117		Left	FT-112016-000118-A	< 1	FT-112016-000118-B	< 1
9	PAYNE ELEMENTARY SCHOOL	WS-000134	1/16/2017	1	Combo Faucet	In classroom 161	Low	Left	FT-112016-000134-A	< 1	FT-112016-000134-B	< 1
10	PAYNE ELEMENTARY SCHOOL	WS-000138	1/16/2017	1	Classroom Faucet	In classroom 161	High	Right	FT-112016-000138-A	< 1	FT-112016-000138-B	< 1
11	PAYNE ELEMENTARY SCHOOL	WS-000178	1/16/2017	2	Combo Faucet	In classroom 205		Left	FT-112016-000178-A	< 1	FT-112016-000178-B	< 1
12	PAYNE ELEMENTARY SCHOOL	WS-000189	1/16/2017	2	Combo Faucet	In classroom 207		Left	FT-112016-000189-A	< 1	FT-112016-000189-B	< 1
13	PAYNE ELEMENTARY SCHOOL	WS-000123	1/16/2017	1	Combo Faucet	In classroom 131		Left	FT-112016-000123-A	< 1	FT-112016-000123-B	< 1
14	PAYNE ELEMENTARY SCHOOL	WS-000203	1/16/2017	3	Break Room	In break room 305			FT-112016-000203-A	< 1	FT-112016-000203-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken												
1	PAYNE ELEMENTARY SCHOOL	WS-000144	1/16/2017	1	Combo Faucet	In classroom 168	Low	Left	FT-112016-000144-A	1.4	FT-112016-000144-B	< 1
2	PAYNE ELEMENTARY SCHOOL	WS-000141	1/16/2017	1	Combo Faucet	In classroom 190		Right	FT-112016-000141-A	1.2	FT-112016-000141-B	< 1
3	PAYNE ELEMENTARY SCHOOL	WS-000149	1/16/2017	1	Classroom Faucet	In classroom 187	High	Left	FT-112016-000149-A	1.8	FT-112016-000149-B	< 1
4	PAYNE ELEMENTARY SCHOOL	WS-000155	1/16/2017	1	Classroom Faucet	In classroom 184	High	Left	FT-112016-000155-A	1.7	FT-112016-000155-B	< 1
5	PAYNE ELEMENTARY SCHOOL	WS-000161	1/16/2017	1	Classroom Faucet	In classroom 172	High	Left	FT-112016-000161-A	1.3	FT-112016-000161-B	< 1
6	PAYNE ELEMENTARY SCHOOL	WS-000171	1/16/2017	2	Combo Faucet	In classroom 204	High	Left	FT-112016-000171-A	1.2	FT-112016-000171-B	< 1
7	PAYNE ELEMENTARY SCHOOL	WS-000206	1/16/2017	2	Combo Faucet	In classroom 246		Left	FT-112016-000206-A	1.5	FT-112016-000206-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service												
1	PAYNE ELEMENTARY SCHOOL	WS-000141	1/25/2017	1	Combo Faucet	In classroom 190		Right	FT-112016-000141-A	< 1	FT-112016-000141-B	< 1
2	PAYNE ELEMENTARY SCHOOL	WS-000149	1/25/2017	1	Classroom Faucet	In classroom 187	High	Left	FT-112016-000149-A	< 1	FT-112016-000149-B	< 1
3	PAYNE ELEMENTARY SCHOOL	WS-000161	1/25/2017	1	Classroom Faucet	In classroom 172	High	Left	FT-112016-000161-A	< 1	FT-112016-000161-B	< 1
4	PAYNE ELEMENTARY SCHOOL	WS-000171	1/25/2017	2	Combo Faucet	In classroom 204	High	Left	FT-112016-000171-A	< 1	FT-112016-000171-B	< 1
5	PAYNE ELEMENTARY SCHOOL	WS-000206	1/25/2017	2	Combo Faucet	In classroom 246		Left	FT-112016-000206-A	< 1	FT-112016-000206-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation												
1	PAYNE ELEMENTARY SCHOOL	WS-000155	1/25/2017	1	Classroom Faucet	In classroom 184	High	Left	FT-112016-000155-A	1.6	FT-112016-000155-B	< 1
2	PAYNE ELEMENTARY SCHOOL	WS-000144	1/25/2017	1	Combo Faucet	In classroom 168	Low	Left	FT-112016-000144-A	1.7	FT-112016-000144-B	< 1

Note :
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation												
1	PAYNE ELEMENTARY SCHOOL	WS- 000155	3/30/2017	1	Classroom Faucet	In classroom 184	High	Left	FT-112016-000155-A	1.3	FT-112016-000155-B	< 1
2	PAYNE ELEMENTARY SCHOOL	WS- 000144	3/30/2017	1	Combo Faucet	In classroom 168	Low	Left	FT-112016-000144-A	3.7	FT-112016-000144-B	< 1

Note :
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb