



# Payne ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000115	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to cafeteria Low Right	WF-3262018-000115	11/26/2018	FT-FY19-112018-000115-A	<1	FT-FY19-112018-000115-B	<1
WS-000116	3/26/2018	3/26/2019	1	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)	WF-3262018-000116	11/26/2018	FT-FY19-112018-000116-A	<1	FT-FY19-112018-000116-B	<1
WS-000117	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to cafeteria Low Left	WF-3262018-000117	11/26/2018	FT-FY19-112018-000117-A	<1	FT-FY19-112018-000117-B	<1
WS-000118	3/26/2018	3/26/2019	1	Break Room	In break room 115B Left	WF-03262018-000118	11/26/2018	FT-FY19-112018-000118-A	<1	FT-FY19-112018-000118-B	<1
WS-000122	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to room 102 Low Right	WF-3262018-000122	11/26/2018	FT-FY19-112018-000122-A	<1	FT-FY19-112018-000122-B	<1
WS-000123	9/17/2018	9/17/2019	1	Combo Faucet	In parent resource room 104 Left	WF-09172018-000123	11/26/2018	FT-FY19-112018-000123-A	<1	FT-FY19-112018-000123-B	<1
WS-000124	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to room 102 Low Left	WF-3262018-000124	11/26/2018	FT-FY19-112018-000124-A	<1	FT-FY19-112018-000124-B	<1
WS-000125	3/26/2018	3/26/2019	1	Combo Fountain	In parent resource room 104 Right	WF-03262018-000125	11/26/2018	FT-FY19-112018-000125-A	<1	FT-FY19-112018-000125-B	<1
WS-000126	3/26/2018	3/26/2019	1	Bottle Filler	In hallway adjacent to room 102 (bottle filler)	WF-3262018-000126	11/26/2018	FT-FY19-112018-000126-A	<1	FT-FY19-112018-000126-B	<1
WS-000130	3/26/2018	3/26/2019	1	Health Suite	In health suite in unisex restroom 103	WF-03262018-000130	11/26/2018	FT-FY19-112018-000130-A	<1	FT-FY19-112018-000130-B	<1
WS-000131	3/26/2018	3/26/2019	1	Health Suite	In health suite 103 Left	WF-03262018-000131	11/26/2018	FT-FY19-112018-000131-A	<1	FT-FY19-112018-000131-B	<1
WS-000133	3/26/2018	3/26/2019	1	Combo Fountain	In health suite 103 Right	WF-03262018-000133	11/26/2018	FT-FY19-112018-000133-A	<1	FT-FY19-112018-000133-B	<1
WS-000134	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 130 Low Left	WF-09172018-000134	11/26/2018	FT-FY19-112018-000134-A	<1	FT-FY19-112018-000134-B	<1
WS-000137	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 130 Low Left	WF-03262018-000137	11/26/2018	FT-FY19-112018-000137-A	<1	FT-FY19-112018-000137-B	<1
WS-000138	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 130 High Right	WF-09172018-000138	11/26/2018	FT-FY19-112018-000138-A	<1	FT-FY19-112018-000138-B	<1
WS-000141	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 134 Right	WF-09172018-000141	11/26/2018	FT-FY19-112018-000141-A	1	FT-FY19-112018-000141-B	<1
WS-000142	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 134 High Left	WF-09172018-000142	11/26/2018	FT-FY19-112018-000142-A	<1	FT-FY19-112018-000142-B	<1
WS-000143	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 134 Low Right	WF-03262018-000143	11/26/2018	FT-FY19-112018-000143-A	<1	FT-FY19-112018-000143-B	<1
WS-000144	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 136 Low Left	WF-09172018-000144	11/26/2018	FT-FY19-112018-000144-A	<1	FT-FY19-112018-000144-B	<1
WS-000146	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 136 Low Left	WF-03262018-000146	11/26/2018	FT-FY19-112018-000146-A	<1	FT-FY19-112018-000146-B	<1
WS-000147	3/26/2018	3/26/2019	1	Bottle Filler	In hallway across from room 138 (bottle filler)	WF-3262018-000147	11/26/2018	FT-FY19-112018-000147-A	<1	FT-FY19-112018-000147-B	<1
WS-000148	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 136 High Right	WF-09172018-000148	11/26/2018	FT-FY19-112018-000148-A	<1	FT-FY19-112018-000148-B	<1
WS-000149	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 137 High Left	WF-09172018-000149	11/26/2018	FT-FY19-112018-000149-A	<1	FT-FY19-112018-000149-B	<1
WS-000150	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 137 Low Right	WF-09172018-000150	11/26/2018	FT-FY19-112018-000150-A	<1	FT-FY19-112018-000150-B	<1
WS-000151	3/26/2018	3/26/2019	1	Cooler	In hallway across from room 138 Low Right	WF-3262018-000151	11/26/2018	FT-FY19-112018-000151-A	<1	FT-FY19-112018-000151-B	<1
WS-000153	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 137 Low Right	WF-03262018-000153	11/26/2018	FT-FY19-112018-000153-A	<1	FT-FY19-112018-000153-B	<1
WS-000154	3/26/2018	3/26/2019	1	Cooler	In hallway across from room 138 Low Left	WF-3262018-000154	11/26/2018	FT-FY19-112018-000154-A	<1	FT-FY19-112018-000154-B	<1
WS-000155	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 138 High Left	WF-09172018-000155	11/26/2018	FT-FY19-112018-000155-A	<1	FT-FY19-112018-000155-B	<1
WS-000156	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 138 Low Right	WF-09172018-000156	11/26/2018	FT-FY19-112018-000156-A	<1	FT-FY19-112018-000156-B	<1
WS-000158	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 138 Low Right	WF-03262018-000158	11/26/2018	FT-FY19-112018-000158-A	<1	FT-FY19-112018-000158-B	<1
WS-000161	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 139 High Left	WF-09172018-000161	11/26/2018	FT-FY19-112018-000161-A	<1	FT-FY19-112018-000161-B	<1
WS-000162	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 142 Low Left	WF-09172018-000162	11/26/2018	FT-FY19-112018-000162-A	<1	FT-FY19-112018-000162-B	<1
WS-000163	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 139 Low Right	WF-09172018-000163	11/26/2018	FT-FY19-112018-000163-A	<1	FT-FY19-112018-000163-B	<1
WS-000164	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 142 Low Left	WF-03262018-000164	11/26/2018	FT-FY19-112018-000164-A	<1	FT-FY19-112018-000164-B	<1
WS-000165	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 142 High Right	WF-09172018-000165	11/26/2018	FT-FY19-112018-000165-A	<1	FT-FY19-112018-000165-B	<1

WS-000167	3/26/2018	3/26/2019	1	Combo Fountain	In classroom 139	Low	Right	WF-03262018-000167	11/26/2018	FT-FY19-112018-000167-A	<1	FT-FY19-112018-000167-B	<1
WS-000168	3/26/2018	3/26/2019	1	Bottle Filler	In hallway adjacent to room 142 (bottle filler)			WF-3262018-000168	11/26/2018	FT-FY19-112018-000168-A	<1	FT-FY19-112018-000168-B	<1
WS-000169	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to room 142	Low	Right	WF-3262018-000169	11/26/2018	FT-FY19-112018-000169-A	<1	FT-FY19-112018-000169-B	<1
WS-000170	3/26/2018	3/26/2019	1	Cooler	In hallway adjacent to room 142	Low	Left	WF-3262018-000170	11/26/2018	FT-FY19-112018-000170-A	<1	FT-FY19-112018-000170-B	<1
WS-000171	9/17/2018	9/17/2019	2	Combo Faucet	In classroom 204	High	Left	WF-09172018-000171	11/26/2018	FT-FY19-112018-000171-A	<1	FT-FY19-112018-000171-B	<1
WS-000173	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 204	High	Left	WF-03262018-000173	11/26/2018	FT-FY19-112018-000173-A	<1	FT-FY19-112018-000173-B	<1
WS-000177	3/26/2018	3/26/2019	2	Bottle Filler	In classroom 204 (bottle filler)			WF-3262018-000177	11/26/2018	FT-FY19-112018-000177-A	<1	FT-FY19-112018-000177-B	<1
WS-000178	9/17/2018	9/17/2019	2	Combo Faucet	In classroom 205		Left	WF-09172018-000178	11/26/2018	FT-FY19-112018-000178-A	<1	FT-FY19-112018-000178-B	<1
WS-000179	3/26/2018	3/26/2019	2	Cooler	In classroom 204	Low	Left	WF-3262018-000179	11/26/2018	FT-FY19-112018-000179-A	<1	FT-FY19-112018-000179-B	<1
WS-000180	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 205		Right	WF-03262018-000180	11/26/2018	FT-FY19-112018-000180-A	<1	FT-FY19-112018-000180-B	<1
WS-000181	3/26/2018	3/26/2019	2	Cooler	In classroom 204	Low	Right	WF-3262018-000181	11/26/2018	FT-FY19-112018-000181-A	<1	FT-FY19-112018-000181-B	<1
WS-000182	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to boys' restroom	Low	Left	WF-3262018-000182	11/26/2018	FT-FY19-112018-000182-A	<1	FT-FY19-112018-000182-B	<1
WS-000185	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to boys' restroom	Low	Right	WF-3262018-000185	11/26/2018	FT-FY19-112018-000185-A	<1	FT-FY19-112018-000185-B	<1
WS-000188	3/26/2018	3/26/2019	2	Bottle Filler	In hallway adjacent to boys' restroom (bottle filler)			WF-3262018-000188	11/26/2018	FT-FY19-112018-000188-A	<1	FT-FY19-112018-000188-B	<1
WS-000189	9/17/2018	9/17/2019	2	Combo Faucet	In classroom 209		Left	WF-09172018-000189	11/26/2018	FT-FY19-112018-000189-A	<1	FT-FY19-112018-000189-B	<1
WS-000191	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 209		Right	WF-03262018-000191	11/26/2018	FT-FY19-112018-000191-A	<1	FT-FY19-112018-000191-B	<1
WS-000194	3/26/2018	3/26/2019	3	Cooler	In hallway adjacent to girls' restroom	Low	Right	WF-3262018-000194	11/26/2018	FT-FY19-112018-000194-A	<1	FT-FY19-112018-000194-B	<1
WS-000198	3/26/2018	3/26/2019	3	Cooler	In hallway adjacent to girls' restroom	High	Left	WF-3262018-000198	11/26/2018	FT-FY19-112018-000198-A	<1	FT-FY19-112018-000198-B	<1
WS-000200	3/26/2018	3/26/2019	3	Bottle Filler	In hallway adjacent to girls' restroom (bottle filler)			WF-3262018-000200	11/26/2018	FT-FY19-112018-000200-A	<1	FT-FY19-112018-000200-B	<1
WS-000203	3/26/2018	3/26/2019	3	Break Room	In break room 306			WF-03262018-000203	11/26/2018	FT-FY19-112018-000203-A	<1	FT-FY19-112018-000203-B	<1
WS-000204	3/26/2018	3/26/2019	3	Combo Fountain	In break room 306			WF-03262018-000204	11/26/2018	FT-FY19-112018-000204-A	<1	FT-FY19-112018-000204-B	<1
WS-000205	3/26/2018	3/26/2019	1	Ice Maker	In kitchen (ice maker)			WF-03262018-000205	11/26/2018	FT-FY19-112018-000205-A	<1	FT-FY19-112018-000205-B	<1
WS-000206	9/17/2018	9/17/2019	2	Combo Faucet	In classroom 240		Left	WF-09172018-000206	11/26/2018	FT-FY19-112018-000206-A	<1	FT-FY19-112018-000206-B	<1
WS-000209	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to room 236	Low	Left	WF-3262018-000209	11/26/2018	FT-FY19-112018-000209-A	<1	FT-FY19-112018-000209-B	<1
WS-000210	3/26/2018	3/26/2019	2	Combo Fountain	In classroom 240			WF-03262018-000210	11/26/2018	FT-FY19-112018-000210-A	<1	FT-FY19-112018-000210-B	<1
WS-000211	3/26/2018	3/26/2019	2	Bottle Filler	In hallway adjacent to room 236 (bottle filler)			WF-3262018-000211	11/26/2018	FT-FY19-112018-000211-A	<1	FT-FY19-112018-000211-B	<1
WS-000214	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to room 236	Low	Right	WF-3262018-000214	11/26/2018	FT-FY19-112018-000214-A	<1	FT-FY19-112018-000214-B	<1
WS-000217	11/7/2018	11/7/2019	2	Break Room	In breakroom 224			WF-11072018-000217	11/26/2018	FT-FY19-112018-000217-A	<1	FT-FY19-112018-000217-B	<1
WS-000222	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to room 224	Low	Left	WF-3262018-000222	11/26/2018	FT-FY19-112018-000222-A	<1	FT-FY19-112018-000222-B	<1
WS-000223	3/26/2018	3/26/2019	2	Bottle Filler	In hallway adjacent to room 224 (bottle filler)			WF-3262018-000223	11/26/2018	FT-FY19-112018-000223-A	<1	FT-FY19-112018-000223-B	<1
WS-000224	3/26/2018	3/26/2019	2	Cooler	In hallway adjacent to room 224	Low	Right	WF-3262018-000224	11/26/2018	FT-FY19-112018-000224-A	<1	FT-FY19-112018-000224-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000111	1	Food Prep Sink	In kitchen sixth clockwise from entry door						