



PEABODY ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	PEABODY ELEMENTARY SCHOOL	WS- 009554	1/15/2017	3	Classroom Faucet	In classroom 307	FT-112016-009554-A	< 1	FT-112016-009554-B	< 1
2	PEABODY ELEMENTARY SCHOOL	WS- 009558	1/15/2017	3	Classroom Faucet	In classroom 304 Left	FT-112016-009558-A	< 1	FT-112016-009558-B	< 1
3	PEABODY ELEMENTARY SCHOOL	WS- 009544	1/15/2017	1	Classroom Faucet	In classroom 106	FT-112016-009544-A	< 1	FT-112016-009544-B	< 1
4	PEABODY ELEMENTARY SCHOOL	WS- 009553	1/15/2017	2	Classroom Faucet	In classroom 203	FT-112016-009553-A	< 1	FT-112016-009553-B	< 1
5	PEABODY ELEMENTARY SCHOOL	WS- 009537	1/15/2017	1	Classroom Faucet	In classroom 103	FT-112016-009537-A	< 1	FT-112016-009537-B	< 1
6	PEABODY ELEMENTARY SCHOOL	WS- 009550	1/15/2017	2	Classroom Faucet	In classroom 207	FT-112016-009550-A	< 1	FT-112016-009550-B	< 1
7	PEABODY ELEMENTARY SCHOOL	WS- 009539	1/15/2017	1	Classroom Faucet	In classroom 104	FT-112016-009539-A	< 1	FT-112016-009539-B	< 1
8	PEABODY ELEMENTARY SCHOOL	WS- 009557	1/15/2017	3	Classroom Faucet	In classroom 303	FT-112016-009557-A	< 1	FT-112016-009557-B	< 1
9	PEABODY ELEMENTARY SCHOOL	WS- 009547	1/15/2017	2	Break Room	In staff lounge	FT-112016-009547-A	< 1	FT-112016-009547-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	PEABODY ELEMENTARY SCHOOL	WS- 009560	1/15/2017	3	Classroom Faucet	In classroom 306	FT-112016-009560-A	1.9	FT-112016-009560-B	< 1
2	PEABODY ELEMENTARY SCHOOL	WS- 009548	1/15/2017	2	Classroom Faucet	In classroom 206	FT-112016-009548-A	1.6	FT-112016-009548-B	< 1
3	PEABODY ELEMENTARY SCHOOL	WS- 009542	1/15/2017	1	Classroom Faucet	In classroom 107	FT-112016-009542-A	1.3	FT-112016-009542-B	< 1
4	PEABODY ELEMENTARY SCHOOL	WS- 009563	1/15/2017	2	Classroom Faucet	In classroom 204 Left	FT-112016-009563-A	2.4	FT-112016-009563-B	< 1
5	PEABODY ELEMENTARY SCHOOL	WS- 009562	1/15/2017	4	Classroom Faucet	In library	FT-112016-009562-A	1.7	FT-112016-009562-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
1	PEABODY ELEMENTARY SCHOOL	WS- 009560	1/25/2017	3	Classroom Faucet	In classroom 306	FT-112016-009560-A	< 1	FT-112016-009560-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	PEABODY ELEMENTARY SCHOOL	WS- 009548	1/25/2017	2	Classroom Faucet	In classroom 206	FT-112016-009548-A	1.6	FT-112016-009548-B	< 1
2	PEABODY ELEMENTARY SCHOOL	WS- 009542	1/25/2017	1	Classroom Faucet	In classroom 107	FT-112016-009542-A	1.6	FT-112016-009542-B	< 1
3	PEABODY ELEMENTARY SCHOOL	WS- 009563	1/25/2017	2	Classroom Faucet	In classroom 204 Left	FT-112016-009563-A	1.5	FT-112016-009563-B	< 1
4	PEABODY ELEMENTARY SCHOOL	WS- 009562	1/25/2017	4	Classroom Faucet	In library	FT-112016-009562-A	1.2	FT-112016-009562-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	PEABODY ELEMENTARY SCHOOL	WS- 009548	3/30/2017	2	Classroom Faucet	In classroom 206	FT-112016-009548-A	2.2	FT-112016-009548-B	< 1
2	PEABODY ELEMENTARY SCHOOL	WS- 009542	3/30/2017	1	Classroom Faucet	In classroom 107	FT-112016-009542-A	1.9	FT-112016-009542-B	< 1
3	PEABODY ELEMENTARY SCHOOL	WS- 009563	3/30/2017	2	Classroom Faucet	In classroom 204 Left	FT-112016-009563-A	2	FT-112016-009563-B	< 1
4	PEABODY ELEMENTARY SCHOOL	WS- 009562	3/30/2017	4	Classroom Faucet	In library	FT-112016-009562-A	1.1	FT-112016-009562-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation											
1	PEABODY ELEMENTARY SCHOOL	WS- 009548	3/30/2017	2	Classroom Faucet	In classroom 206		FT-112016-009548-A	2.2	FT-112016-009548-B	< 1
2	PEABODY ELEMENTARY SCHOOL	WS- 009542	3/30/2017	1	Classroom Faucet	In classroom 107		FT-112016-009542-A	1.9	FT-112016-009542-B	< 1
3	PEABODY ELEMENTARY SCHOOL	WS- 009563	3/30/2017	2	Classroom Faucet	In classroom 204	Left	FT-112016-009563-A	2	FT-112016-009563-B	< 1
4	PEABODY ELEMENTARY SCHOOL	WS- 009562	3/30/2017	4	Classroom Faucet	In library		FT-112016-009562-A	1.1	FT-112016-009562-B	< 1

Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 5 ppb - Devices Returned to Service											
1	PEABODY ELEMENTARY SCHOOL	WS- 009548	8/11/2017	2	Classroom Faucet	In classroom 206		FT-112016-009548-A	< 1	FT-112016-009548-B	< 1
2	PEABODY ELEMENTARY SCHOOL	WS- 009542	8/11/2017	1	Classroom Faucet	In classroom 107		FT-112016-009542-A	< 1	FT-112016-009542-B	< 1
3	PEABODY ELEMENTARY SCHOOL	WS- 009563	8/11/2017	2	Classroom Faucet	In classroom 204	Left	FT-112016-009563-A	< 1	FT-112016-009563-B	< 1
4	PEABODY ELEMENTARY SCHOOL	WS- 009562	8/11/2017	4	Classroom Faucet	In library		FT-112016-009562-A	< 1	FT-112016-009562-B	< 1