



Peabody Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009535	8/26/2021	8/26/2022	Basement	Cooler	In hallway adjacent to girls' restroom High Left	WF-08262021-009535	8/30/2021	FT-FY21-08262021-009535-A	<1	FT-FY21-08262021-009535-B	<1
WS- 009536	8/26/2021	8/26/2022	Basement	Cooler	In hallway adjacent to girls' restroom Low Right	WF-08262021-009536	8/30/2021	FT-FY21-08262021-009536-A	<1	FT-FY21-08262021-009536-B	<1
WS- 009537	8/26/2021	8/26/2022	1	Combo Faucet	In classroom 103	WF-08262021-009537	8/30/2021	FT-FY21-08262021-009537-A	<1	FT-FY21-08262021-009537-B	<1
WS- 009538	8/26/2021	8/26/2022	1	Combo Fountain	In classroom 103	WF-08262021-009538	8/30/2021	FT-FY21-08262021-009538-A	<1	FT-FY21-08262021-009538-B	<1
WS- 009539	8/26/2021	8/26/2022	1	Combo Faucet	In classroom 104	WF-08262021-009539	8/30/2021	FT-FY21-08262021-009539-A	<1	FT-FY21-08262021-009539-B	<1
WS- 009540	8/26/2021	8/26/2022	1	Combo Fountain	In classroom 104	WF-08262021-009540	8/30/2021	FT-FY21-08262021-009540-A	<1	FT-FY21-08262021-009540-B	<1
WS- 009541	8/26/2021	8/26/2022	1	Combo Fountain	In classroom 107	WF-08262021-009541	8/30/2021	FT-FY21-08262021-009541-A	<1	FT-FY21-08262021-009541-B	<1
WS- 009542	8/26/2021	8/26/2022	1	Combo Faucet	In classroom 107	WF-08262021-009542	8/30/2021	FT-FY21-08262021-009542-A	<1	FT-FY21-08262021-009542-B	<1
WS- 009543	8/26/2021	8/26/2022	1	Combo Fountain	In classroom 106	WF-08262021-009543	8/30/2021	FT-FY21-08262021-009543-A	<1	FT-FY21-08262021-009543-B	<1
WS- 009544	8/26/2021	8/26/2022	1	Combo Faucet	In classroom 106	WF-08262021-009544	8/30/2021	FT-FY21-08262021-009544-A	<1	FT-FY21-08262021-009544-B	<1
WS- 009547	8/26/2021	8/26/2022	2	Break Room	In staff lounge	WF-08262021-009547	8/30/2021	FT-FY21-08262021-009547-A	<1	FT-FY21-08262021-009547-B	<1
WS- 009548	8/26/2021	8/26/2022	2	Combo Faucet	In classroom 206	WF-08262021-009548	8/30/2021	FT-FY21-08262021-009548-A	<1	FT-FY21-08262021-009548-B	<1
WS- 009549	8/26/2021	8/26/2022	2	Combo Fountain	In classroom 206	WF-08262021-009549	8/30/2021	FT-FY21-08262021-009549-A	<1	FT-FY21-08262021-009549-B	<1
WS- 009550	8/26/2021	8/26/2022	2	Combo Faucet	In classroom 207	WF-08262021-009550	8/30/2021	FT-FY21-08262021-009550-A	<1	FT-FY21-08262021-009550-B	<1
WS- 009551	8/26/2021	8/26/2022	2	Combo Fountain	In classroom 207	WF-08262021-009551	8/30/2021	FT-FY21-08262021-009551-A	<1	FT-FY21-08262021-009551-B	<1
WS- 009552	8/26/2021	8/26/2022	2	Combo Fountain	In classroom 203	WF-08262021-009552	8/30/2021	FT-FY21-08262021-009552-A	<1	FT-FY21-08262021-009552-B	<1
WS- 009553	8/26/2021	8/26/2022	2	Combo Faucet	In classroom 203	WF-08262021-009553	8/30/2021	FT-FY21-08262021-009553-A	<1	FT-FY21-08262021-009553-B	<1
WS- 009554	8/26/2021	8/26/2022	3	Combo Faucet	In classroom 307	WF-08262021-009554	8/30/2021	FT-FY21-08262021-009554-A	<1	FT-FY21-08262021-009554-B	<1
WS- 009555	8/26/2021	8/26/2022	3	Combo Fountain	In classroom 307	WF-08262021-009555	8/30/2021	FT-FY21-08262021-009555-A	<1	FT-FY21-08262021-009555-B	<1
WS- 009556	8/26/2021	8/26/2022	3	Combo Fountain	In classroom 303	WF-08262021-009556	8/30/2021	FT-FY21-08262021-009556-A	<1	FT-FY21-08262021-009556-B	<1
WS- 009557	8/26/2021	8/26/2022	3	Combo Faucet	In classroom 303	WF-08262021-009557	8/30/2021	FT-FY21-08262021-009557-A	<1	FT-FY21-08262021-009557-B	<1
WS- 009558	8/26/2021	8/26/2022	3	Combo Faucet	In classroom 304 Left	WF-08262021-009558	8/30/2021	FT-FY21-08262021-009558-A	<1	FT-FY21-08262021-009558-B	<1
WS- 009559	8/26/2021	8/26/2022	3	Combo Fountain	In classroom 304 Right	WF-08262021-009559	8/30/2021	FT-FY21-08262021-009559-A	<1	FT-FY21-08262021-009559-B	<1
WS- 009560	8/26/2021	8/26/2022	3	Combo Faucet	In classroom 306	WF-08262021-009560	8/30/2021	FT-FY21-08262021-009560-A	<1	FT-FY21-08262021-009560-B	<1
WS- 009561	8/26/2021	8/26/2022	3	Combo Fountain	In classroom 306	WF-08262021-009561	8/30/2021	FT-FY21-08262021-009561-A	<1	FT-FY21-08262021-009561-B	<1
WS- 009562	8/26/2021	8/26/2022	4	Classroom Faucet	In library	WF-08262021-009562	8/30/2021	FT-FY21-08262021-009562-A	<1	FT-FY21-08262021-009562-B	<1
WS- 009563	8/26/2021	8/26/2022	2	Combo Faucet	In classroom 204 Left	WF-08262021-009563	8/30/2021	FT-FY21-08262021-009563-A	<1	FT-FY21-08262021-009563-B	<1
WS- 009564	8/26/2021	8/26/2022	2	Combo Fountain	In classroom 204 Right	WF-08262021-009564	8/30/2021	FT-FY21-08262021-009564-A	<1	FT-FY21-08262021-009564-B	<1