



Peabody Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009535	5/13/2024	5/13/2025	Basement	Cooler	In hallway adjacent to girls' restroom High Left	WF-05132024-009535	1/8/2025	FT-FY25-12042024-009535-A	<2	FT-FY25-12042024-009535-B	<2
WS- 009536	5/13/2024	5/13/2025	Basement	Cooler	In hallway adjacent to girls' restroom Low Right	WF-05132024-009536	1/8/2025	FT-FY25-12042024-009536-A	<2	FT-FY25-12042024-009536-B	<2
WS- 009537	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 103	WF-09162024-009537	1/8/2025	FT-FY25-12042024-009537-A	<2	FT-FY25-12042024-009537-B	<2
WS- 009538	5/13/2024	5/13/2025	1	Combo Fountain	In classroom 103	WF-05132024-009538	1/8/2025	FT-FY25-12042024-009538-A	<2	FT-FY25-12042024-009538-B	<2
WS- 009539	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 104	WF-09162024-009539	1/8/2025	FT-FY25-12042024-009539-A	<2	FT-FY25-12042024-009539-B	<2
WS- 009540	5/13/2024	5/13/2025	1	Combo Fountain	In classroom 104	WF-05132024-009540	1/8/2025	FT-FY25-12042024-009540-A	<2	FT-FY25-12042024-009540-B	<2
WS- 009541	5/13/2024	5/13/2025	1	Combo Fountain	In classroom 107	WF-05132024-009541	1/8/2025	FT-FY25-12042024-009541-A	<2	FT-FY25-12042024-009541-B	<2
WS- 009542	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 107	WF-09162024-009542	1/8/2025	FT-FY25-12042024-009542-A	<2	FT-FY25-12042024-009542-B	<2
WS- 009543	5/13/2024	5/13/2025	1	Combo Fountain	In classroom 106	WF-05132024-009543	1/8/2025	FT-FY25-12042024-009543-A	<2	FT-FY25-12042024-009543-B	<2
WS- 009544	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 106	WF-09162024-009544	1/8/2025	FT-FY25-12042024-009544-A	<2	FT-FY25-12042024-009544-B	<2
WS- 009546	5/13/2024	5/13/2025	2	Health Suite	In health suite 202B	WF-05132024-009546	1/8/2025	FT-FY25-12042024-009546-A	<2	FT-FY25-12042024-009546-B	<2
WS- 009547	5/13/2024	5/13/2025	2	Break Room	In staff lounge	WF-05132024-009547	1/8/2025	FT-FY25-12042024-009547-A	<2	FT-FY25-12042024-009547-B	<2
WS- 009548	9/16/2024	9/16/2025	2	Combo Faucet	In classroom 206	WF-09162024-009548	1/8/2025	FT-FY25-12042024-009548-A	<2	FT-FY25-12042024-009548-B	<2
WS- 009549	5/13/2024	5/13/2025	2	Combo Fountain	In classroom 206	WF-05132024-009549	1/8/2025	FT-FY25-12042024-009549-A	<2	FT-FY25-12042024-009549-B	<2
WS- 009550	9/16/2024	9/16/2025	2	Combo Faucet	In classroom 207	WF-09162024-009550	1/8/2025	FT-FY25-12042024-009550-A	<2	FT-FY25-12042024-009550-B	<2
WS- 009551	5/13/2024	5/13/2025	2	Combo Fountain	In classroom 207	WF-05132024-009551	1/8/2025	FT-FY25-12042024-009551-A	<2	FT-FY25-12042024-009551-B	<2
WS- 009552	5/13/2024	5/13/2025	2	Combo Fountain	In classroom 203	WF-05132024-009552	1/8/2025	FT-FY25-12042024-009552-A	<2	FT-FY25-12042024-009552-B	<2
WS- 009553	9/16/2024	9/16/2025	2	Combo Faucet	In classroom 203	WF-09162024-009553	1/8/2025	FT-FY25-12042024-009553-A	<2	FT-FY25-12042024-009553-B	<2
WS- 009554	9/16/2024	9/16/2025	3	Combo Faucet	In classroom 307	WF-09162024-009554	1/8/2025	FT-FY25-12042024-009554-A	<2	FT-FY25-12042024-009554-B	<2
WS- 009555	5/13/2024	5/13/2025	3	Combo Fountain	In classroom 307	WF-05132024-009555	1/8/2025	FT-FY25-12042024-009555-A	<2	FT-FY25-12042024-009555-B	<2
WS- 009556	5/13/2024	5/13/2025	3	Combo Fountain	In classroom 303	WF-05132024-009556	1/8/2025	FT-FY25-12042024-009556-A	<2	FT-FY25-12042024-009556-B	<2
WS- 009557	9/16/2024	9/16/2025	3	Combo Faucet	In classroom 303	WF-09162024-009557	1/8/2025	FT-FY25-12042024-009557-A	2.5	FT-FY25-12042024-009557-B	<2
WS- 009558	9/16/2024	9/16/2025	3	Combo Faucet	In classroom 304 Left	WF-09162024-009558	1/8/2025	FT-FY25-12042024-009558-A	<2	FT-FY25-12042024-009558-B	<2
WS- 009559	5/13/2024	5/13/2025	3	Combo Fountain	In classroom 304 Right	WF-05132024-009559	1/8/2025	FT-FY25-12042024-009559-A	<2	FT-FY25-12042024-009559-B	<2
WS- 009560	9/16/2024	9/16/2025	3	Combo Faucet	In classroom 306	WF-09162024-009560	1/8/2025	FT-FY25-12042024-009560-A	<2	FT-FY25-12042024-009560-B	<2
WS- 009561	5/13/2024	5/13/2025	3	Combo Fountain	In classroom 306	WF-05132024-009561	1/8/2025	FT-FY25-12042024-009561-A	<2	FT-FY25-12042024-009561-B	<2
WS- 009562	9/16/2024	9/16/2025	4	Classroom Faucet	In library	WF-09162024-009562	1/8/2025	FT-FY25-12042024-009562-A	<2	FT-FY25-12042024-009562-B	<2
WS- 009563	9/16/2024	9/16/2025	2	Combo Faucet	In classroom 204 Left	WF-09162024-009563	1/8/2025	FT-FY25-12042024-009563-A	2.8	FT-FY25-12042024-009563-B	<2
WS- 009564	5/13/2024	5/13/2025	2	Combo Fountain	In classroom 204 Right	WF-05132024-009564	1/8/2025	FT-FY25-12042024-009564-A	<2	FT-FY25-12042024-009564-B	<2
WS- 009715	5/13/2024	5/13/2025	Basement	Bottle Filler	In hallway adjacent to girls' restroom	WF-05132024-009715	1/8/2025	FT-FY25-12042024-009715-A	<2	FT-FY25-12042024-009715-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009533	12/30/2024	12/30/2025	Basement	Food Prep Sink	In kitchen Left	WF-12302024-009533	1/8/2025	FT-FY25-12042024-009533-A	<2	FT-FY25-12042024-009533-B	<2
WS- 009534	12/30/2024	12/30/2025	Basement	Food Prep Sink	In kitchen (dishwashing hose)	WF-12302024-009534	1/8/2025	FT-FY25-12042024-009534-A	<2	FT-FY25-12042024-009534-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.