



Peabody ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009535	6/12/2019	6/12/2020	Basement	Cooler	In hallway adjacent to girls' restroom	High Left	WF-06122019-009535	10/22/2019	FT-FY20-102019-009535-A	<1	FT-FY20-102019-009535-B	<1
WS- 009536	6/12/2019	6/12/2020	Basement	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-06122019-009536	10/22/2019	FT-FY20-102019-009536-A	<1	FT-FY20-102019-009536-B	<1
WS- 009537	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 103		WF-09112019-009537	10/22/2019	FT-FY20-102019-009537-A	<1	FT-FY20-102019-009537-B	<1
WS- 009538	6/12/2019	6/12/2020	1	Combo Fountain	In classroom 103		WF-06122019-009538	10/22/2019	FT-FY20-102019-009538-A	<1	FT-FY20-102019-009538-B	<1
WS- 009539	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 104		WF-09112019-009539	10/22/2019	FT-FY20-102019-009539-A	<1	FT-FY20-102019-009539-B	<1
WS- 009540	6/12/2019	6/12/2020	1	Combo Fountain	In classroom 104		WF-06122019-009540	10/22/2019	FT-FY20-102019-009540-A	<1	FT-FY20-102019-009540-B	<1
WS- 009541	6/12/2019	6/12/2020	1	Combo Fountain	In classroom 107		WF-06122019-009541	10/22/2019	FT-FY20-102019-009541-A	<1	FT-FY20-102019-009541-B	<1
WS- 009542	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 107		WF-09112019-009542	10/22/2019	FT-FY20-102019-009542-A	<1	FT-FY20-102019-009542-B	<1
WS- 009543	6/12/2019	6/12/2020	1	Combo Fountain	In classroom 106		WF-06122019-009543	10/22/2019	FT-FY20-102019-009543-A	<1	FT-FY20-102019-009543-B	<1
WS- 009544	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 106		WF-09112019-009544	10/22/2019	FT-FY20-102019-009544-A	<1	FT-FY20-102019-009544-B	<1
WS- 009546	6/12/2019	6/12/2020	2	Health Suite	In health suite 202B		WF-06122019-009546	10/22/2019	FT-FY20-102019-009546-A	<1	FT-FY20-102019-009546-B	<1
WS- 009547	6/12/2019	6/12/2020	2	Break Room	In staff lounge		WF-06122019-009547	10/22/2019	FT-FY20-102019-009547-A	<1	FT-FY20-102019-009547-B	<1
WS- 009548	9/11/2019	9/11/2020	2	Combo Faucet	In classroom 206		WF-09112019-009548	10/22/2019	FT-FY20-102019-009548-A	<1	FT-FY20-102019-009548-B	<1
WS- 009549	6/12/2019	6/12/2020	2	Combo Fountain	In classroom 206		WF-06122019-009549	10/22/2019	FT-FY20-102019-009549-A	<1	FT-FY20-102019-009549-B	<1
WS- 009550	9/11/2019	9/11/2020	2	Combo Faucet	In classroom 207		WF-09112019-009550	10/22/2019	FT-FY20-102019-009550-A	<1	FT-FY20-102019-009550-B	<1
WS- 009551	6/12/2019	6/12/2020	2	Combo Fountain	In classroom 207		WF-06122019-009551	10/22/2019	FT-FY20-102019-009551-A	<1	FT-FY20-102019-009551-B	<1
WS- 009552	6/12/2019	6/12/2020	2	Combo Fountain	In classroom 203		WF-06122019-009552	10/22/2019	FT-FY20-102019-009552-A	<1	FT-FY20-102019-009552-B	<1
WS- 009553	9/11/2019	9/11/2020	2	Combo Faucet	In classroom 203		WF-09112019-009553	10/22/2019	FT-FY20-102019-009553-A	<1	FT-FY20-102019-009553-B	<1
WS- 009554	9/11/2019	9/11/2020	3	Combo Faucet	In classroom 307		WF-09112019-009554	10/22/2019	FT-FY20-102019-009554-A	<1	FT-FY20-102019-009554-B	<1
WS- 009555	6/12/2019	6/12/2020	3	Combo Fountain	In classroom 307		WF-06122019-009555	10/22/2019	FT-FY20-102019-009555-A	<1	FT-FY20-102019-009555-B	<1
WS- 009556	6/12/2019	6/12/2020	3	Combo Fountain	In classroom 303		WF-06122019-009556	10/22/2019	FT-FY20-102019-009556-A	<1	FT-FY20-102019-009556-B	<1
WS- 009557	9/11/2019	9/11/2020	3	Combo Faucet	In classroom 303		WF-09112019-009557	10/22/2019	FT-FY20-102019-009557-A	<1	FT-FY20-102019-009557-B	<1
WS- 009558	9/11/2019	9/11/2020	3	Combo Faucet	In classroom 304	Left	WF-09112019-009558	10/22/2019	FT-FY20-102019-009558-A	<1	FT-FY20-102019-009558-B	<1
WS- 009559	6/12/2019	6/12/2020	3	Combo Fountain	In classroom 304	Right	WF-06122019-009559	10/22/2019	FT-FY20-102019-009559-A	<1	FT-FY20-102019-009559-B	<1
WS- 009560	9/11/2019	9/11/2020	3	Combo Faucet	In classroom 306		WF-09112019-009560	10/22/2019	FT-FY20-102019-009560-A	<1	FT-FY20-102019-009560-B	<1
WS- 009561	6/12/2019	6/12/2020	3	Combo Fountain	In classroom 306		WF-06122019-009561	10/22/2019	FT-FY20-102019-009561-A	<1	FT-FY20-102019-009561-B	<1
WS- 009562	9/11/2019	9/11/2020	4	Classroom Faucet	In library		WF-09112019-009562	10/22/2019	FT-FY20-102019-009562-A	<1	FT-FY20-102019-009562-B	<1
WS- 009563	9/11/2019	9/11/2020	2	Combo Faucet	In classroom 204	Left	WF-09112019-009563	10/22/2019	FT-FY20-102019-009563-A	1.3	FT-FY20-102019-009563-B	<1
WS- 009564	6/12/2019	6/12/2020	2	Combo Fountain	In classroom 204	Right	WF-06122019-009564	10/22/2019	FT-FY20-102019-009564-A	<1	FT-FY20-102019-009564-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)

WS- 009533	7/3/2019	7/8/2020	Basement	Food Prep Sink	In kitchen	Left	WF-07032019-009533	10/22/2019	FT-FY20-102019-009533-A	<1	FT-FY20-102019-009533-B	<1
WS- 009534	7/3/2019	7/3/2020	Basement	Food Prep Sink	In kitchen (dishwashing hose)		WF-07032019-009534	10/22/2019	FT-FY20-102019-009534-A	<1	FT-FY20-102019-009534-B	<1