



PEABODY LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009532	Utility	Basement	In room 003B	WT-042916-9549- A	147	WT-042916-9549- B	1.9	Non-drinking water source turned off until further analysis complete			
2 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009533	Kitchen	Basement	In kitchen sink Left	WT-042916-9550- A	< 1	WT-042916-9550- B	< 1				
3 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009534	Kitchen	Basement	In kitchen sprayer	WT-042916-9551- A	< 1	WT-042916-9551- B	< 1				
4 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009535	Cooler	Basement	In hallway adjacent to girls restroom	WT-042916-9552- A	< 1	WT-042916-9552- B	< 1				
5 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009536	Cooler	Basement	In hallway adjacent to girls restroom.	WT-042916-9553- A	< 1	WT-042916-9553- B	< 1				
6 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009537	Classroom	1	In room 103	WT-042916-9554- A	< 1	WT-042916-9554- B	< 1				
7 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009538	Fountain	1	In room 103	WT-042916-9555- A	< 1	WT-042916-9555- B	< 1				
8 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009539	Classroom	1	In room 104	WT-042916-9556- A	< 1	WT-042916-9556- B	< 1				
9 PEABODY ELEMENTARY SCHOOL	5/12/2016	WS-009540	Fountain	1	In room 104	WT-042916-9557- A	< 1	WT-042916-9557- B	< 1				
10 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009541	Fountain	1	In classroom 107	WT-042916-9558- A	< 1	WT-042916-9558- B	< 1				
11 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009542	Classroom	1	In classroom 107	WT-042916-9559- A	< 1	WT-042916-9559- B	< 1				
12 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009543	Fountain	1	In classroom 106	WT-042916-9560- A	< 1	WT-042916-9560- B	< 1				
13 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009544	Classroom	1	In classroom 106	WT-042916-9561- A	< 1	WT-042916-9561- B	< 1				
14 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009546	Health Suite	2	In 202B	WT-042916-9563- A	< 1	WT-042916-9563- B	< 1				
15 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009547	Break Room	2	In break room sink	WT-042916-9564- A	< 1	WT-042916-9564- B	< 1				
16 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009548	Classroom	2	In classroom 206	WT-042916-9565- A	< 1	WT-042916-9565- B	< 1				
17 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009549	Fountain	2	In classroom 206	WT-042916-9566- A	< 1	WT-042916-9566- B	< 1				
18 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009550	Classroom	2	In classroom 207	WT-042916-9567- A	< 1	WT-042916-9567- B	< 1				
19 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009551	Fountain	2	In classroom 207	WT-042916-9568- A	< 1	WT-042916-9568- B	< 1				
20 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009552	Fountain	2	In classroom 203	WT-042916-9569- A	< 1	WT-042916-9569- B	< 1				
21 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009553	Classroom	2	In classroom 203	WT-042916-9570- A	< 1	WT-042916-9570- B	< 1				
22 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009554	Classroom	3	In classroom 307	WT-042916-9571- A	< 1	WT-042916-9571- B	< 1				
23 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009555	Fountain	3	In classroom 307	WT-042916-9572- A	< 1	WT-042916-9572- B	< 1				
24 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009556	Fountain	3	In classroom 303	WT-042916-9573- A	< 1	WT-042916-9573- B	< 1				
25 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009557	Classroom	3	In classroom 303	WT-042916-9574- A	< 1	WT-042916-9574- B	< 1				
26 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009558	Classroom	3	In classroom 304 Left	WT-042916-9575- A	< 1	WT-042916-9575- B	< 1				
27 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009559	Fountain	3	In classroom 304 Right	WT-042916-9576- A	< 1	WT-042916-9576- B	< 1				
28 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009560	Classroom	3	In classroom 306	WT-042916-9577- A	< 1	WT-042916-9577- B	< 1				
29 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009561	Fountain	3	In classroom 306	WT-042916-9578- A	< 1	WT-042916-9578- B	< 1				
30 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009562	Other	4	In the library sink	WT-042916-9579- A	< 1	WT-042916-9579- B	< 1				
31 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009563	Classroom	2	In classroom 204 Left	WT-042916-9580- A	< 1	WT-042916-9580- B	< 1				
32 PEABODY ELEMENTARY SCHOOL	5/11/2016	WS-009564	Fountain	2	In classroom 204 Right	WT-042916-9581- A	< 1	WT-042916-9581- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.