



# Petworth RC Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005392	12/2/2025	12/2/2026	1	Food Prep Sink	In kitchen	WF-12022025-005392	2/25/2026	FT-FY26-01282026-005392-A	<2	FT-FY26-01282026-005392-B	<2
WS- 005393	4/14/2025	4/14/2026	1	Cooler	In main hall	WF-04142025-005393	2/25/2026	FT-FY26-01282026-005393-A	<2	FT-FY26-01282026-005393-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.