



Phelps A.C.E. High School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010683	4/12/2023	4/12/2024	Basement	Cooler	In hallway adjacent to room S005	WF-04122023-010683	12/13/2023	FT-FY24-11012023-010683-A	<1	FT-FY24-11012023-010683-B	<1
WS- 010684	4/12/2023	4/12/2024	Basement	Cooler	In hallway across from gym S001	WF-04122023-010684	12/13/2023	FT-FY24-11012023-010684-A	<1	FT-FY24-11012023-010684-B	<1
WS- 010686	4/12/2023	4/12/2024	1	Break Room	In break room A103	WF-04122023-010686	12/13/2023	FT-FY24-11012023-010686-A	<1	FT-FY24-11012023-010686-B	<1
WS- 010687	4/12/2023	4/12/2024	1	Cooler	In hallway adjacent to room C110	WF-04122023-010687	12/13/2023	FT-FY24-11012023-010687-A	<1	FT-FY24-11012023-010687-B	<1
WS- 010688	4/12/2023	4/12/2024	1	Break Room	In break room C105	WF-04122023-010688	12/13/2023	FT-FY24-11012023-010688-A	<1	FT-FY24-11012023-010688-B	<1
WS- 010689	4/12/2023	4/12/2024	1	Cooler	In hallway adjacent to room C108	WF-04122023-010689	12/13/2023	FT-FY24-11012023-010689-A	<1	FT-FY24-11012023-010689-B	<1
WS- 010690	4/12/2023	4/12/2024	1	Break Room	In S106 in break room 106M	WF-04122023-010690	12/13/2023	FT-FY24-11012023-010690-A	<1	FT-FY24-11012023-010690-B	<1
WS- 010694	4/12/2023	4/12/2024	1	Ice Maker	In kitchen (ice maker)	WF-04122023-010694	12/13/2023	FT-FY24-11012023-010694-A	<1	FT-FY24-11012023-010694-B	<1
WS- 010698	4/12/2023	4/12/2024	1	Cooler	In hallway adjacent to room T104	WF-04122023-010698	12/13/2023	FT-FY24-11012023-010698-A	<1	FT-FY24-11012023-010698-B	<1
WS- 010700	4/12/2023	4/12/2024	1	Cooler	In hallway adjacent to room T106	WF-04122023-010700	12/13/2023	FT-FY24-11012023-010700-A	<1	FT-FY24-11012023-010700-B	<1
WS- 010703	4/12/2023	4/12/2024	1	Break Room	In break room 102A in library	WF-04122023-010703	12/13/2023	FT-FY24-11012023-010703-A	<1	FT-FY24-11012023-010703-B	<1
WS- 010704	4/12/2023	4/12/2024	1	Health Suite	In S106 in health suite 106E	WF-04122023-010704	12/13/2023	FT-FY24-11012023-010704-A	<1	FT-FY24-11012023-010704-B	<1
WS- 010967	4/12/2023	4/12/2024	Basement	Bottle Filler	In hallway adjacent to room S005	WF-04122023-010967	12/13/2023	FT-FY24-11012023-010967-A	<1	FT-FY24-11012023-010967-B	<1
WS- 010968	4/12/2023	4/12/2024	Basement	Bottle Filler	In hallway across from gym S001	WF-04122023-010968	12/13/2023	FT-FY24-11012023-010968-A	<1	FT-FY24-11012023-010968-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010691	1/10/2023	1/10/2024	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-01102023-010691	12/13/2023	FT-FY24-11012023-010691-A	<1	FT-FY24-11012023-010691-B	<1
WS- 010693	1/10/2023	1/10/2024	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-01102023-010693	12/13/2023	FT-FY24-11012023-010693-A	<1	FT-FY24-11012023-010693-B	<1