



# Phelps ACE High School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010683	4/27/2021	4/27/2022	Basement	Cooler	In hallway adjacent to room S005	WF-04272021-010683	3/15/2022	FT-FY22-02212022-010683-A	<1	FT-FY22-02212022-010683-B	<1
WS- 010684	4/27/2021	4/27/2022	Basement	Cooler	In hallway across from gym S001	WF-04272021-010684	3/15/2022	FT-FY22-02212022-010684-A	<1	FT-FY22-02212022-010684-B	<1
WS- 010686	4/27/2021	4/27/2022	1	Break Room	In break room A103	WF-04272021-010686	3/15/2022	FT-FY22-02212022-010686-A	<1	FT-FY22-02212022-010686-B	<1
WS- 010688	4/27/2021	4/27/2022	1	Break Room	In break room C105	WF-04272021-010688	3/15/2022	FT-FY22-02212022-010688-A	<1	FT-FY22-02212022-010688-B	<1
WS- 010689	4/27/2021	4/27/2022	1	Cooler	In hallway adjacent to room C108	WF-04272021-010689	3/15/2022	FT-FY22-02212022-010689-A	<1	FT-FY22-02212022-010689-B	<1
WS- 010694	4/27/2021	4/27/2022	1	Ice Maker	In kitchen (ice maker)	WF-04272021-010694	3/15/2022	FT-FY22-02212022-010694-A	<1	FT-FY22-02212022-010694-B	<1
WS- 010698	4/27/2021	4/27/2022	1	Cooler	In hallway adjacent to room T104	WF-04272021-010698	3/15/2022	FT-FY22-02212022-010698-A	<1	FT-FY22-02212022-010698-B	<1
WS- 010700	4/27/2021	4/27/2022	1	Cooler	In hallway adjacent to room T106	WF-04272021-010700	3/15/2022	FT-FY22-02212022-010700-A	<1	FT-FY22-02212022-010700-B	<1
WS- 010703	4/27/2021	4/27/2022	1	Break Room	In break room 102A in library	WF-04272021-010703	3/15/2022	FT-FY22-02212022-010703-A	1.1	FT-FY22-02212022-010703-B	<1
WS- 010704	4/27/2021	4/27/2022	1	Health Suite	In health suite 106E	WF-04272021-010704	3/15/2022	FT-FY22-02212022-010704-A	<1	FT-FY22-02212022-010704-B	<1
WS- 010707	4/27/2021	4/27/2022	2	Cooler	In hallway adjacent to room C211	WF-04272021-010707	3/15/2022	FT-FY22-02212022-010707-A	<1	FT-FY22-02212022-010707-B	<1
WS- 011468	4/27/2021	4/27/2022	2	Cooler	In hallway adjacent to room S206	WF-04272021-011468	3/15/2022	FT-FY22-02212022-011468-A	<1	FT-FY22-02212022-011468-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010691	1/31/2022	1/31/2023	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-01312022-010691	3/15/2022	FT-FY22-02212022-010691-A	<1	FT-FY22-02212022-010691-B	<1
WS- 010693	1/31/2022	1/31/2023	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-01312022-010693	3/15/2022	FT-FY22-02212022-010693-A	<1	FT-FY22-02212022-010693-B	<1