



Phelps Ace HS Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010683	4/2/2025	4/2/2026	Basement	Cooler	In hallway adjacent to room S005	WF-04022025-010683	12/19/2025	FT-FY26-12082025-010683-A	<2	FT-FY26-12082025-010683-B	<2
WS- 010686	6/5/2025	6/5/2026	1	Break Room	In break room A103	WF-06052025-010686	12/19/2025	FT-FY26-12082025-010686-A	<2	FT-FY26-12082025-010686-B	<2
WS- 010688	4/2/2025	4/2/2026	1	Break Room	In break room C105	WF-04022025-010688	12/19/2025	FT-FY26-12082025-010688-A	<2	FT-FY26-12082025-010688-B	<2
WS- 010690	4/2/2025	4/2/2026	1	Break Room	In S106 in break room 106M	WF-04022025-010690	12/19/2025	FT-FY26-12082025-010690-A	<2	FT-FY26-12082025-010690-B	<2
WS- 010698	4/2/2025	4/2/2026	1	Cooler	In hallway adjacent to room T104	WF-04022025-010698	12/19/2025	FT-FY26-12082025-010698-A	<2	FT-FY26-12082025-010698-B	<2
WS- 010700	4/2/2025	4/2/2026	1	Cooler	In hallway adjacent to room T106	WF-04022025-010700	12/19/2025	FT-FY26-12082025-010700-A	<2	FT-FY26-12082025-010700-B	<2
WS- 010703	4/2/2025	4/2/2026	1	Break Room	In break room 102A in library	WF-04022025-010703	12/19/2025	FT-FY26-12082025-010703-A	<2	FT-FY26-12082025-010703-B	<2
WS- 010704	4/2/2025	4/2/2026	1	Health Suite	In S106 in health suite 106E	WF-04022025-010704	12/19/2025	FT-FY26-12082025-010704-A	<2	FT-FY26-12082025-010704-B	<2
WS- 010707	4/2/2025	4/2/2026	2	Cooler	In hallway adjacent to room C211	WF-04022025-010707	12/19/2025	FT-FY26-12082025-010707-A	<2	FT-FY26-12082025-010707-B	<2
WS- 010967	4/2/2025	4/2/2026	Basement	Bottle Filler	In hallway adjacent to room S005	WF-04022025-010967	12/19/2025	FT-FY26-12082025-010967-A	<2	FT-FY26-12082025-010967-B	<2
WS- 011468	4/2/2025	4/2/2026	2	Cooler	In hallway adjacent to room S206	WF-04022025-011468	12/19/2025	FT-FY26-12082025-011468-A	<2	FT-FY26-12082025-011468-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010691	11/26/2025	11/26/2026	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-11262025-010691	12/19/2025	FT-FY26-12082025-010691-A	<2	FT-FY26-12082025-010691-B	<2
WS- 010693	11/26/2025	11/26/2026	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-11262025-010693	12/19/2025	FT-FY26-12082025-010693-A	<2	FT-FY26-12082025-010693-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.