



PHELPS HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	PHELPS A.C.E. HIGH SCHOOL	WS- 010683	8/18/2016	Basement	Cooler	In hallway adjacent to room S005	FT-82016-010683-A	< 1	FT-82016-010683-B	< 1
2	PHELPS A.C.E. HIGH SCHOOL	WS- 010684	8/18/2016	Basement	Cooler	In hallway across from gym S001	FT-82016-010684-A	< 1	FT-82016-010684-B	< 1
3	PHELPS A.C.E. HIGH SCHOOL	WS- 010687	8/18/2016	1	Cooler	In hallway adjacent to room C110	FT-82016-010687-A	< 1	FT-82016-010687-B	< 1
4	PHELPS A.C.E. HIGH SCHOOL	WS- 010689	8/18/2016	1	Cooler	In hallway adjacent to room C108	FT-82016-010689-A	< 1	FT-82016-010689-B	< 1
5	PHELPS A.C.E. HIGH SCHOOL	WS- 010691	8/18/2016	1	Food Prep Sink	In kitchen first clockwise from entry door	FT-82016-010691-A	< 1	FT-82016-010691-B	< 1
6	PHELPS A.C.E. HIGH SCHOOL	WS- 010693	8/18/2016	1	Food Prep Sink	In kitchen third clockwise from entry door	FT-82016-010693-A	< 1	FT-82016-010693-B	< 1
7	PHELPS A.C.E. HIGH SCHOOL	WS- 010694	8/18/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-010694-A	< 1	FT-82016-010694-B	< 1
8	PHELPS A.C.E. HIGH SCHOOL	WS- 010698	8/18/2016	1	Cooler	In hallway adjacent to room T104	FT-82016-010698-A	< 1	FT-82016-010698-B	< 1
9	PHELPS A.C.E. HIGH SCHOOL	WS- 010700	8/18/2016	1	Cooler	In hallway adjacent to room T106	FT-82016-010700-A	< 1	FT-82016-010700-B	< 1
10	PHELPS A.C.E. HIGH SCHOOL	WS- 010704	8/18/2016	1	Health Suite	In health suite 106E	FT-82016-010704-A	< 1	FT-82016-010704-B	< 1
11	PHELPS A.C.E. HIGH SCHOOL	WS- 010707	8/18/2016	2	Cooler	In hallway adjacent to room C211	FT-82016-010707-A	< 1	FT-82016-010707-B	< 1
12	PHELPS A.C.E. HIGH SCHOOL	WS- 011448	8/18/2016	2	Cooler	In hallway adjacent to room C207	FT-82016-011448-A	< 1	FT-82016-011448-B	< 1
13	PHELPS A.C.E. HIGH SCHOOL	WS- 011468	8/18/2016	2	Cooler	In hallway adjacent to room S206	FT-82016-011468-A	< 1	FT-82016-011468-B	< 1