



# PHELPS LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location | Sample Collected Date | Water Source ID | Device Type | Floor        | Device Location | 1st Draw - Sample ID                   | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-------------------|-----------------------|-----------------|-------------|--------------|-----------------|--|--------------------------------|----------------------|--------------------------------|-------------|-------------|-----------------|-----------------|
| 1                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010681   | Utility      | Basement        | In mechanical room C002 (water source) | WT-042916-10698-A              | < 1                  | WT-042916-10698-B              | < 1         |             |                 |                 |
| 2                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010682   | Utility      | Basement        | In room 004                            | WT-042916-10699-A              | < 1                  | WT-042916-10699-B              | < 1         |             |                 |                 |
| 3                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010683   | Cooler       | Basement        | In hallway adjacent to room S005       | WT-042916-10700-A              | < 1                  | WT-042916-10700-B              | < 1         |             |                 |                 |
| 4                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010684   | Cooler       | Basement        | In hallway adjacent to gymnasium S001  | WT-042916-10701-A              | < 1                  | WT-042916-10701-B              | < 1         |             |                 |                 |
| 5                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010685   | Other        | Basement        | In concessions                         | WT-042916-10702-A              | < 1                  | WT-042916-10702-B              | < 1         |             |                 |                 |
| 6                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010686   | Classroom    | 1               | In room A103                           | WT-042916-10703-A              | < 1                  | WT-042916-10703-B              | < 1         |             |                 |                 |
| 7                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010687   | Cooler       | 1               | In hallway adjacent to room C110       | WT-042916-10704-A              | < 1                  | WT-042916-10704-B              | < 1         |             |                 |                 |
| 8                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010688   | Other        | 1               | In room C105                           | WT-042916-10705-A              | < 1                  | WT-042916-10705-B              | < 1         |             |                 |                 |
| 9                 | PHELPS A.C.E. HS      | 5/17/2016       | WS-010689   | Cooler       | 1               | In hallway adjacent to room C108       | WT-042916-10706-A              | < 1                  | WT-042916-10706-B              | < 1         |             |                 |                 |
| 10                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010690   | Break Room   | 1               | In break room 106M                     | WT-042916-10707-A              | < 1                  | WT-042916-10707-B              | < 1         |             |                 |                 |
| 11                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010691   | Kitchen      | 1               | In kitchen 1                           | WT-042916-10708-A              | < 1                  | WT-042916-10708-B              | < 1         |             |                 |                 |
| 12                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010692   | Kitchen      | 1               | In kitchen 2                           | WT-042916-10709-A              | < 1                  | WT-042916-10709-B              | < 1         |             |                 |                 |
| 13                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010693   | Kitchen      | 1               | In kitchen 3                           | WT-042916-10710-A              | < 1                  | WT-042916-10710-B              | < 1         |             |                 |                 |
| 14                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010694   | Other        | 1               | In kitchen (ice maker)                 | WT-042916-10711-A              | < 1                  | WT-042916-10711-B              | < 1         |             |                 |                 |
| 15                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010695   | Other        | Basement        | In concession ice maker                | WT-042916-10712-A              | < 1                  | WT-042916-10712-B              | < 1         |             |                 |                 |
| 16                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010696   | Classroom    | 1               | In room T-103                          | WT-042916-10713-A              | 1.1                  | WT-042916-10713-B              | < 1         |             |                 |                 |
| 17                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010697   | Classroom    | 1               | In classroom T104                      | WT-042916-10714-A              | 3.3                  | WT-042916-10714-B              | 1.4         |             |                 |                 |
| 18                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010698   | Cooler       | 1               | In hallway adjacent to T104            | WT-042916-10715-A              | < 1                  | WT-042916-10715-B              | < 1         |             |                 |                 |
| 19                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010699   | Classroom    | 1               | In classroom T105                      | WT-042916-10716-A              | 4.8                  | WT-042916-10716-B              | 2.5         |             |                 |                 |
| 20                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010700   | Cooler       | 1               | In hallway adjacent to room T106       | WT-042916-10717-A              | < 1                  | WT-042916-10717-B              | < 1         |             |                 |                 |
| 21                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010701   | Classroom    | 1               | In classroom T106                      | WT-042916-10718-A              | < 1                  | WT-042916-10718-B              | < 1         |             |                 |                 |
| 22                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010702   | Classroom    | 1               | In classroom T101                      | WT-042916-10719-A              | 2.9                  | WT-042916-10719-B              | 1.4         |             |                 |                 |
| 23                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010703   | Break Room   | 1               | Room 102A, in library                  | WT-042916-10720-A              | < 1                  | WT-042916-10720-B              | < 1         |             |                 |                 |
| 24                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010704   | Health Suite | 1               | In room 106E health suit               | WT-042916-10721-A              | < 1                  | WT-042916-10721-B              | < 1         |             |                 |                 |
| 25                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010705   | Other        | 2               | In office room T209                    | WT-042916-10722-A              | < 1                  | WT-042916-10722-B              | < 1         |             |                 |                 |
| 26                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010706   | Other        | 2               | In office room A206                    | WT-042916-10723-A              | < 1                  | WT-042916-10723-B              | < 1         |             |                 |                 |
| 27                | PHELPS A.C.E. HS      | 5/17/2016       | WS-010707   | Cooler       | 2               | In hallway adjacent to room C211       | WT-042916-10724-A              | < 1                  | WT-042916-10724-B              | < 1         |             |                 |                 |
| 28                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011447   | Other        | 2               | In room C208                           | WT-042916-11464-A              | < 1                  | WT-042916-11464-B              | < 1         |             |                 |                 |
| 29                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011449   | Classroom    | 2               | In classroom S201                      | WT-042916-11466-A              | < 1                  | WT-042916-11466-B              | < 1         |             |                 |                 |
| 30                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011450   | Classroom    | 2               | In classroom S201                      | WT-042916-11467-A              | < 1                  | WT-042916-11467-B              | < 1         |             |                 |                 |
| 31                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011451   | Classroom    | 2               | In classroom S201                      | WT-042916-11468-A              | 1.5                  | WT-042916-11468-B              | < 1         |             |                 |                 |
| 32                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011452   | Classroom    | 2               | In classroom S202 - 1                  | WT-042916-11469-A              | < 1                  | WT-042916-11469-B              | < 1         |             |                 |                 |
| 33                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011453   | Classroom    | 2               | In room S202, 2                        | WT-042916-11470-A              | < 1                  | WT-042916-11470-B              | < 1         |             |                 |                 |
| 34                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011454   | Classroom    | 2               | In classroom S202, 3                   | WT-042916-11471-A              | < 1                  | WT-042916-11471-B              | < 1         |             |                 |                 |
| 35                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011455   | Classroom    | 2               | In classroom S202, 4                   | WT-042916-11472-A              | < 1                  | WT-042916-11472-B              | < 1         |             |                 |                 |
| 36                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011456   | Classroom    | 2               | In classroom S202, 5                   | WT-042916-11473-A              | < 1                  | WT-042916-11473-B              | < 1         |             |                 |                 |
| 37                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011457   | Classroom    | 2               | In classroom S202, 6                   | WT-042916-11474-A              | < 1                  | WT-042916-11474-B              | < 1         |             |                 |                 |
| 38                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011458   | Classroom    | 2               | In classroom S202 - 7                  | WT-042916-11475-A              | < 1                  | WT-042916-11475-B              | 1.5         |             |                 |                 |
| 39                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011459   | Classroom    | 2               | In classroom S203                      | WT-042916-11476-A              | 1.1                  | WT-042916-11476-B              | < 1         |             |                 |                 |
| 40                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011460   | Classroom    | 2               | In classroom S203                      | WT-042916-11477-A              | 3.2                  | WT-042916-11477-B              | < 1         |             |                 |                 |
| 41                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011461   | Classroom    | 2               | In classroom S204 - 1                  | WT-042916-11478-A              | 1                    | WT-042916-11478-B              | < 1         |             |                 |                 |
| 42                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011462   | Classroom    | 2               | In classroom S204 - 2                  | WT-042916-11479-A              | < 1                  | WT-042916-11479-B              | < 1         |             |                 |                 |
| 43                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011463   | Classroom    | 2               | In classroom S204 - 3                  | WT-042916-11480-A              | < 1                  | WT-042916-11480-B              | < 1         |             |                 |                 |
| 44                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011464   | Classroom    | 2               | In classroom S204 - 4                  | WT-042916-11481-A              | < 1                  | WT-042916-11481-B              | < 1         |             |                 |                 |
| 45                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011465   | Classroom    | 2               | In classroom S204                      | WT-042916-11482-A              | < 1                  | WT-042916-11482-B              | < 1         |             |                 |                 |
| 46                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011466   | Classroom    | 2               | In classroom S204 - 6                  | WT-042916-11483-A              | < 1                  | WT-042916-11483-B              | < 1         |             |                 |                 |
| 47                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011467   | Classroom    | 2               | In classroom S204 - 5                  | WT-042916-11484-A              | < 1                  | WT-042916-11484-B              | < 1         |             |                 |                 |
| 48                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011468   | Cooler       | 2               | In hallway adjacent to room S206       | WT-042916-11485-A              | < 1                  | WT-042916-11485-B              | < 1         |             |                 |                 |
| 49                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011469   | Classroom    | 2               | In classroom S210                      | WT-042916-11486-A              | < 1                  | WT-042916-11486-B              | < 1         |             |                 |                 |
| 50                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011470   | Classroom    | 2               | In classroom S210                      | WT-042916-11487-A              | < 1                  | WT-042916-11487-B              | < 1         |             |                 |                 |
| 51                | PHELPS A.C.E. HS      | 5/17/2016       | WS-011471   | Classroom    | 2               | In room 206                            | WT-042916-11488-A              | < 1                  | WT-042916-11488-B              | < 1         |             |                 |                 |

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.