



Phelps ACE Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-010684	6/28/17	6/28/18	Basement	Cooler	In hallway across from gym S001	WF-62017-010684	12/19/17	FT-FY18--62017-010684-A	<1	FT-FY18--62017-010684-B	<1	
WS-010688	6/28/17	6/28/18	1	Break Room	In break room C105	WF-62017-010688	12/19/17	FT-FY18--62017-010688-A	<1	FT-FY18--62017-010688-B	<1	
WS-010690	6/28/17	6/28/18	1	Break Room	In break room 106M	WF-62017-010690	12/19/17	FT-FY18--62017-010690-A	<1	FT-FY18--62017-010690-B	<1	
WS-010694	7/5/17	7/5/18	1	Ice Maker	In kitchen (ice maker)	WF-72017-010694	12/19/17	FT-FY18--72017-010694-A	<1	FT-FY18--72017-010694-B	<1	
WS-010698	6/28/17	6/28/18	1	Cooler	In hallway adjacent to room T104	WF-62017-010698	12/19/17	FT-FY18--62017-010698-A	<1	FT-FY18--62017-010698-B	<1	

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-010691	1	Food Prep Sink	In kitchen first clockwise from entry door	12/19/17	FT-FY18-102017-010691-A	<1	FT-FY18-102017-010691-B	<1	
WS-010693	1	Food Prep Sink	In kitchen third clockwise from entry door	12/19/17	FT-FY18-102017-010693-A	<1	FT-FY18-102017-010693-B	<1	