



Plummer Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|-----------|-----------------------|------------------------|-------|----------------|---------------------------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS-002650 | 5/19/2020 | 5/19/2021 | 1 | Break Room | In staff lounge 122 | WF-05192020-002650 | 2/25/2021 | FT-FY21-022021-002650-A | <1 | FT-FY21-022021-002650-B | <1 |
| WS-002651 | 5/19/2020 | 5/19/2021 | 1 | Cooler | In hallway adjacent to room 122 | WF-05192020-002651 | 2/25/2021 | FT-FY21-022021-002651-A | <1 | FT-FY21-022021-002651-B | <1 |
| WS-002652 | 5/19/2020 | 5/19/2021 | 1 | Cooler | In hallway adjacent to room 122 | WF-05192020-002652 | 2/25/2021 | FT-FY21-022021-002652-A | <1 | FT-FY21-022021-002652-B | <1 |
| WS-002653 | 5/19/2020 | 5/19/2021 | 1 | Health Suite | In health suite | WF-05192020-002653 | 2/25/2021 | FT-FY21-022021-002653-A | <1 | FT-FY21-022021-002653-B | <1 |
| WS-002656 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 201 | WF-05192020-002656 | 2/25/2021 | FT-FY21-022021-002656-A | <1 | FT-FY21-022021-002656-B | <1 |
| WS-002657 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 201 | WF-09252020-002657 | 2/25/2021 | FT-FY21-022021-002657-A | <1 | FT-FY21-022021-002657-B | <1 |
| WS-002658 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 202 | WF-05192020-002658 | 2/25/2021 | FT-FY21-022021-002658-A | <1 | FT-FY21-022021-002658-B | <1 |
| WS-002659 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 202 | WF-09252020-002659 | 2/25/2021 | FT-FY21-022021-002659-A | <1 | FT-FY21-022021-002659-B | <1 |
| WS-002660 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 203 | WF-05192020-002660 | 2/25/2021 | FT-FY21-022021-002660-A | <1 | FT-FY21-022021-002660-B | <1 |
| WS-002661 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 203 | WF-09252020-002661 | 2/25/2021 | FT-FY21-022021-002661-A | <1 | FT-FY21-022021-002661-B | <1 |
| WS-002662 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 204 | WF-05192020-002662 | 2/25/2021 | FT-FY21-022021-002662-A | <1 | FT-FY21-022021-002662-B | <1 |
| WS-002663 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 204 | WF-09252020-002663 | 2/25/2021 | FT-FY21-022021-002663-A | <1 | FT-FY21-022021-002663-B | <1 |
| WS-002664 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 206 | WF-05192020-002664 | 2/25/2021 | FT-FY21-022021-002664-A | <1 | FT-FY21-022021-002664-B | <1 |
| WS-002665 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 206 | WF-09252020-002665 | 2/25/2021 | FT-FY21-022021-002665-A | <1 | FT-FY21-022021-002665-B | <1 |
| WS-002666 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 212 | WF-05192020-002666 | 2/25/2021 | FT-FY21-022021-002666-A | <1 | FT-FY21-022021-002666-B | <1 |
| WS-002667 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 212 | WF-09252020-002667 | 2/25/2021 | FT-FY21-022021-002667-A | <1 | FT-FY21-022021-002667-B | <1 |
| WS-002668 | 5/19/2020 | 5/19/2021 | 2 | Cooler | In hallway adjacent to room 217 | WF-05192020-002668 | 2/25/2021 | FT-FY21-022021-002668-A | <1 | FT-FY21-022021-002668-B | <1 |
| WS-002669 | 5/19/2020 | 5/19/2021 | 2 | Cooler | In hallway adjacent to room 217 | WF-05192020-002669 | 2/25/2021 | FT-FY21-022021-002669-A | <1 | FT-FY21-022021-002669-B | <1 |
| WS-002670 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 214 | WF-05192020-002670 | 2/25/2021 | FT-FY21-022021-002670-A | <1 | FT-FY21-022021-002670-B | <1 |
| WS-002671 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 214 | WF-09252020-002671 | 2/25/2021 | FT-FY21-022021-002671-A | <1 | FT-FY21-022021-002671-B | <1 |
| WS-002672 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 219 | WF-05192020-002672 | 2/25/2021 | FT-FY21-022021-002672-A | <1 | FT-FY21-022021-002672-B | <1 |
| WS-002673 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 219 | WF-09252020-002673 | 2/25/2021 | FT-FY21-022021-002673-A | <1 | FT-FY21-022021-002673-B | <1 |
| WS-002674 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 216 | WF-05192020-002674 | 2/25/2021 | FT-FY21-022021-002674-A | <1 | FT-FY21-022021-002674-B | <1 |
| WS-002675 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 216 | WF-09252020-002675 | 2/25/2021 | FT-FY21-022021-002675-A | <1 | FT-FY21-022021-002675-B | <1 |
| WS-002676 | 5/19/2020 | 5/19/2021 | 2 | Combo Fountain | In classroom 221 | WF-05192020-002676 | 2/25/2021 | FT-FY21-022021-002676-A | <1 | FT-FY21-022021-002676-B | <1 |
| WS-002677 | 9/25/2020 | 9/25/2021 | 2 | Combo Faucet | In classroom 221 | WF-09252020-002677 | 2/25/2021 | FT-FY21-022021-002677-A | <1 | FT-FY21-022021-002677-B | <1 |
| WS-002678 | 5/19/2020 | 5/19/2021 | 2 | Cooler | In cafeteria | WF-05192020-002678 | 2/25/2021 | FT-FY21-022021-002678-A | <1 | FT-FY21-022021-002678-B | <1 |
| WS-002680 | 5/19/2020 | 5/19/2021 | 3 | Cooler | In hallway adjacent to room 309 | WF-05192020-002680 | 2/25/2021 | FT-FY21-022021-002680-A | <1 | FT-FY21-022021-002680-B | <1 |
| WS-002681 | 5/19/2020 | 5/19/2021 | 3 | Cooler | In hallway adjacent to room 309 | WF-05192020-002681 | 2/25/2021 | FT-FY21-022021-002681-A | <1 | FT-FY21-022021-002681-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|-----------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 002679 | 2/17/2021 | 2/17/2022 | 2 | Food Prep Sink | In kitchen | WF-02172021-002679 | 2/25/2021 | FT-FY21-022021-002679-A | <1 | FT-FY21-022021-002679-B | <1 |