



Plummer Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002651	3/25/2024	3/25/2025	1	Cooler	In hallway adjacent to room 122	WF-03252024-002651	1/12/2025	FT-FY25-12042024-002651-A	<2	FT-FY25-12042024-002651-B	<2
WS- 002652	3/25/2024	3/25/2025	1	Cooler	In hallway adjacent to room 122	WF-03252024-002652	1/12/2025	FT-FY25-12042024-002652-A	2.7	FT-FY25-12042024-002652-B	<2
WS- 002653	3/25/2024	3/25/2025	1	Health Suite	In health suite	WF-03252024-002653	1/12/2025	FT-FY25-12042024-002653-A	<2	FT-FY25-12042024-002653-B	<2
WS- 002654	3/25/2024	3/25/2025	1	Cooler	In auditorium	WF-03252024-002654	1/12/2025	FT-FY25-12042024-002654-A	<2	FT-FY25-12042024-002654-B	<2
WS- 002655	3/25/2024	3/25/2025	1	Cooler	In auditorium	WF-03252024-002655	1/12/2025	FT-FY25-12042024-002655-A	<2	FT-FY25-12042024-002655-B	<2
WS- 002656	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 201	WF-03252024-002656	1/12/2025	FT-FY25-12042024-002656-A	<2	FT-FY25-12042024-002656-B	<2
WS- 002657	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 201	WF-08282024-002657	1/12/2025	FT-FY25-12042024-002657-A	<2	FT-FY25-12042024-002657-B	<2
WS- 002658	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 202	WF-03252024-002658	1/12/2025	FT-FY25-12042024-002658-A	<2	FT-FY25-12042024-002658-B	<2
WS- 002659	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 202	WF-08282024-002659	1/12/2025	FT-FY25-12042024-002659-A	<2	FT-FY25-12042024-002659-B	<2
WS- 002660	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 203	WF-03252024-002660	1/12/2025	FT-FY25-12042024-002660-A	<2	FT-FY25-12042024-002660-B	<2
WS- 002661	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 203	WF-08282024-002661	1/12/2025	FT-FY25-12042024-002661-A	<2	FT-FY25-12042024-002661-B	<2
WS- 002662	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 204	WF-03252024-002662	1/12/2025	FT-FY25-12042024-002662-A	<2	FT-FY25-12042024-002662-B	<2
WS- 002663	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 204	WF-08282024-002663	1/12/2025	FT-FY25-12042024-002663-A	2.9	FT-FY25-12042024-002663-B	<2
WS- 002664	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 206	WF-03252024-002664	1/12/2025	FT-FY25-12042024-002664-A	<2	FT-FY25-12042024-002664-B	<2
WS- 002666	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 212	WF-03252024-002666	1/12/2025	FT-FY25-12042024-002666-A	<2	FT-FY25-12042024-002666-B	<2
WS- 002667	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 212	WF-08282024-002667	1/12/2025	FT-FY25-12042024-002667-A	2.1	FT-FY25-12042024-002667-B	<2
WS- 002668	3/25/2024	3/25/2025	2	Cooler	In hallway adjacent to room 217	WF-03252024-002668	1/12/2025	FT-FY25-12042024-002668-A	<2	FT-FY25-12042024-002668-B	<2
WS- 002669	3/25/2024	3/25/2025	2	Cooler	In hallway adjacent to room 217	WF-03252024-002669	1/12/2025	FT-FY25-12042024-002669-A	<2	FT-FY25-12042024-002669-B	<2
WS- 002670	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 214	WF-03252024-002670	1/12/2025	FT-FY25-12042024-002670-A	<2	FT-FY25-12042024-002670-B	<2
WS- 002672	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 219	WF-03252024-002672	1/12/2025	FT-FY25-12042024-002672-A	<2	FT-FY25-12042024-002672-B	<2
WS- 002673	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 219	WF-08282024-002673	1/12/2025	FT-FY25-12042024-002673-A	<2	FT-FY25-12042024-002673-B	<2
WS- 002674	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 216	WF-03252024-002674	1/12/2025	FT-FY25-12042024-002674-A	<2	FT-FY25-12042024-002674-B	<2
WS- 002675	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 216	WF-08282024-002675	1/12/2025	FT-FY25-12042024-002675-A	<2	FT-FY25-12042024-002675-B	<2
WS- 002676	3/25/2024	3/25/2025	2	Combo Fountain	In classroom 221	WF-03252024-002676	1/12/2025	FT-FY25-12042024-002676-A	<2	FT-FY25-12042024-002676-B	<2
WS- 002677	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 221	WF-08282024-002677	1/12/2025	FT-FY25-12042024-002677-A	<2	FT-FY25-12042024-002677-B	<2
WS- 002678	3/25/2024	3/25/2025	2	Cooler	In cafeteria	WF-03252024-002678	1/12/2025	FT-FY25-12042024-002678-A	<2	FT-FY25-12042024-002678-B	<2
WS- 002680	3/25/2024	3/25/2025	3	Cooler	In hallway adjacent to room 309	WF-03252024-002680	1/12/2025	FT-FY25-12042024-002680-A	<2	FT-FY25-12042024-002680-B	<2
WS- 002684	3/25/2024	3/25/2025	2	Bottle Filler	In cafeteria	WF-03252024-002684	1/12/2025	FT-FY25-12042024-002684-A	<2	FT-FY25-12042024-002684-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002679	1/8/2025	1/8/2026	2	Food Prep Sink	In kitchen	WF-01082025-002679	1/12/2025	FT-FY25-12042024-002679-A	<2	FT-FY25-12042024-002679-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002671	8/28/2024	8/28/2025	2	Combo Faucet	In classroom 214	Left	WF-08282024-002671	1/12/2025	FT-FY25-12042024-002671-A	5.7	FT-FY25-12042024-002671-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.