



# PLUMMER ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	PLUMMER ELEMENTARY SCHOOL	WS- 002650	8/18/2016	1	Break Room	In staff lounge 122	FT-92016-002650-A	< 1	FT-92016-002650-B	< 1
2	PLUMMER ELEMENTARY SCHOOL	WS- 002651	8/18/2016	1	Cooler	In hallway adjacent to room 122 Low Left	FT-82016-002651-A	< 1	FT-82016-002651-B	< 1
3	PLUMMER ELEMENTARY SCHOOL	WS- 002652	8/18/2016	1	Cooler	In hallway adjacent to room 122 High Right	FT-82016-002652-A	< 1	FT-82016-002652-B	< 1
4	PLUMMER ELEMENTARY SCHOOL	WS- 002653	8/18/2016	1	Health Suite	In health suite	FT-82016-002653-A	< 1	FT-82016-002653-B	< 1
5	PLUMMER ELEMENTARY SCHOOL	WS- 002654	8/18/2016	1	Cooler	In auditorium Low Left	FT-82016-002654-A	< 1	FT-82016-002654-B	< 1
6	PLUMMER ELEMENTARY SCHOOL	WS- 002655	8/18/2016	1	Cooler	In auditorium High Right	FT-82016-002655-A	< 1	FT-82016-002655-B	< 1
7	PLUMMER ELEMENTARY SCHOOL	WS- 002656	8/18/2016	2	Fountain	In classroom 201 Right	FT-82016-002656-A	< 1	FT-82016-002656-B	< 1
8	PLUMMER ELEMENTARY SCHOOL	WS- 002658	8/18/2016	2	Fountain	In classroom 202 Right	FT-82016-002658-A	< 1	FT-82016-002658-B	< 1
9	PLUMMER ELEMENTARY SCHOOL	WS- 002660	8/18/2016	2	Fountain	In classroom 203 Right	FT-82016-002660-A	< 1	FT-82016-002660-B	< 1
10	PLUMMER ELEMENTARY SCHOOL	WS- 002662	8/18/2016	2	Fountain	In classroom 204 Right	FT-82016-002662-A	< 1	FT-82016-002662-B	< 1
11	PLUMMER ELEMENTARY SCHOOL	WS- 002664	8/18/2016	2	Fountain	In classroom 206 Right	FT-82016-002664-A	< 1	FT-82016-002664-B	< 1
12	PLUMMER ELEMENTARY SCHOOL	WS- 002666	8/18/2016	2	Fountain	In classroom 212 High Right	FT-82016-002666-A	< 1	FT-82016-002666-B	< 1
13	PLUMMER ELEMENTARY SCHOOL	WS- 002667	8/18/2016	2	Classroom Faucet	In classroom 212 Left	FT-92016-002667-A	< 1	FT-92016-002667-B	< 1
14	PLUMMER ELEMENTARY SCHOOL	WS- 002668	8/18/2016	2	Cooler	In hallway adjacent to room 217 Low Left	FT-82016-002668-A	< 1	FT-82016-002668-B	< 1
15	PLUMMER ELEMENTARY SCHOOL	WS- 002669	8/18/2016	2	Cooler	In hallway adjacent to room 217 High Right	FT-82016-002669-A	< 1	FT-82016-002669-B	< 1
16	PLUMMER ELEMENTARY SCHOOL	WS- 002670	8/18/2016	2	Fountain	In classroom 214 Right	FT-82016-002670-A	< 1	FT-82016-002670-B	< 1
17	PLUMMER ELEMENTARY SCHOOL	WS- 002672	8/18/2016	2	Fountain	In classroom 219 Right	FT-82016-002672-A	< 1	FT-82016-002672-B	< 1
18	PLUMMER ELEMENTARY SCHOOL	WS- 002674	8/18/2016	2	Fountain	In classroom 216 Right	FT-82016-002674-A	< 1	FT-82016-002674-B	< 1
19	PLUMMER ELEMENTARY SCHOOL	WS- 002676	8/18/2016	2	Fountain	In classroom 221 Right	FT-82016-002676-A	< 1	FT-82016-002676-B	< 1
20	PLUMMER ELEMENTARY SCHOOL	WS- 002678	8/18/2016	2	Cooler	In cafeteria	FT-82016-002678-A	< 1	FT-82016-002678-B	< 1
21	PLUMMER ELEMENTARY SCHOOL	WS- 002679	8/18/2016	2	Food Prep Sink	In kitchen	FT-82016-002679-A	< 1	FT-82016-002679-B	< 1
22	PLUMMER ELEMENTARY SCHOOL	WS- 002680	8/18/2016	3	Cooler	In hallway adjacent to room 309 Low Left	FT-82016-002680-A	< 1	FT-82016-002680-B	< 1
23	PLUMMER ELEMENTARY SCHOOL	WS- 002681	8/18/2016	3	Cooler	In hallway adjacent to room 309 High Right	FT-82016-002681-A	< 1	FT-82016-002681-B	< 1