



PLUMMER ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	PLUMMER ELEMENTARY SCHOOL	WS- 002650	12/23/2016	1	Break Room	In staff lounge 122	FT-92016-002650-A	< 1	FT-92016-002650-B	< 1
2	PLUMMER ELEMENTARY SCHOOL	WS- 002673	12/23/2016	2	Combo Faucet	In classroom 219	FT-122016-002673-A	< 1	FT-122016-002673-B	< 1
3	PLUMMER ELEMENTARY SCHOOL	WS- 002675	12/23/2016	2	Combo Faucet	In classroom 216 Mid	FT-122016-002675-A	< 1	FT-122016-002675-B	< 1
4	PLUMMER ELEMENTARY SCHOOL	WS- 002657	12/23/2016	2	Combo Faucet	In classroom 201 Left	FT-122016-002657-A	< 1	FT-122016-002657-B	< 1
5	PLUMMER ELEMENTARY SCHOOL	WS- 002677	12/23/2016	2	Combo Faucet	In classroom 221 Left	FT-122016-002677-A	< 1	FT-122016-002677-B	< 1
6	PLUMMER ELEMENTARY SCHOOL	WS- 002661	12/23/2016	2	Combo Faucet	In classroom 203 Left	FT-122016-002661-A	< 1	FT-122016-002661-B	< 1
7	PLUMMER ELEMENTARY SCHOOL	WS- 002659	12/23/2016	2	Combo Faucet	In classroom 202 Left	FT-122016-002659-A	< 1	FT-122016-002659-B	< 1
8	PLUMMER ELEMENTARY SCHOOL	WS- 002671	12/23/2016	2	Combo Faucet	In classroom 214 Left	FT-122016-002671-A	< 1	FT-122016-002671-B	< 1
9	PLUMMER ELEMENTARY SCHOOL	WS- 002667	12/23/2016	2	Combo Faucet	In classroom 212 Left	FT-122016-002667-A	< 1	FT-122016-002667-B	< 1
10	PLUMMER ELEMENTARY SCHOOL	WS- 002665	12/23/2016	2	Combo Faucet	In classroom 206 Left	FT-122016-002665-A	< 1	FT-122016-002665-B	< 1
11	PLUMMER ELEMENTARY SCHOOL	WS- 002663	12/23/2016	2	Combo Faucet	In classroom 204 Left	FT-122016-002663-A	< 1	FT-122016-002663-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb