



Plummer ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002650	6/4/2018	6/4/2019	1	Break Room	In staff lounge 122	WF-06042018-002650	11/22/2018	FT-FY19-112018-002650-A	<1	FT-FY19-112018-002650-B	<1
WS- 002651	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room 122 Low Left	WF-06042018-002651	11/22/2018	FT-FY19-112018-002651-A	<1	FT-FY19-112018-002651-B	<1
WS- 002652	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room 122 High Right	WF-06042018-002652	11/22/2018	FT-FY19-112018-002652-A	<1	FT-FY19-112018-002652-B	<1
WS- 002653	6/4/2018	6/4/2019	1	Health Suite	In health suite	WF-06042018-002653	11/22/2018	FT-FY19-112018-002653-A	<1	FT-FY19-112018-002653-B	<1
WS- 002656	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 201 Right	WF-06042018-002656	11/22/2018	FT-FY19-112018-002656-A	<1	FT-FY19-112018-002656-B	<1
WS- 002657	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 201 Left	WF-10092018-002657	11/22/2018	FT-FY19-112018-002657-A	<1	FT-FY19-112018-002657-B	<1
WS- 002658	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 202 Right	WF-06042018-002658	11/22/2018	FT-FY19-112018-002658-A	<1	FT-FY19-112018-002658-B	<1
WS- 002659	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 202 Left	WF-10092018-002659	11/22/2018	FT-FY19-112018-002659-A	<1	FT-FY19-112018-002659-B	<1
WS- 002660	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 203 Right	WF-06042018-002660	11/22/2018	FT-FY19-112018-002660-A	<1	FT-FY19-112018-002660-B	<1
WS- 002661	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 203 Left	WF-10092018-002661	11/22/2018	FT-FY19-112018-002661-A	<1	FT-FY19-112018-002661-B	<1
WS- 002662	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 204 Right	WF-06042018-002662	11/22/2018	FT-FY19-112018-002662-A	<1	FT-FY19-112018-002662-B	<1
WS- 002663	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 204 Left	WF-10092018-002663	11/22/2018	FT-FY19-112018-002663-A	<1	FT-FY19-112018-002663-B	<1
WS- 002664	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 206 Right	WF-06042018-002664	11/22/2018	FT-FY19-112018-002664-A	<1	FT-FY19-112018-002664-B	<1
WS- 002665	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 206 Left	WF-10092018-002665	11/22/2018	FT-FY19-112018-002665-A	<1	FT-FY19-112018-002665-B	<1
WS- 002666	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 212 High Right	WF-06042018-002666	11/22/2018	FT-FY19-112018-002666-A	<1	FT-FY19-112018-002666-B	<1
WS- 002667	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 212 Left	WF-10092018-002667	11/22/2018	FT-FY19-112018-002667-A	<1	FT-FY19-112018-002667-B	<1
WS- 002668	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room 217 Low Left	WF-06042018-002668	11/22/2018	FT-FY19-112018-002668-A	<1	FT-FY19-112018-002668-B	<1
WS- 002669	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to room 217 High Right	WF-06042018-002669	11/22/2018	FT-FY19-112018-002669-A	<1	FT-FY19-112018-002669-B	<1
WS- 002670	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 214 Right	WF-06042018-002670	11/22/2018	FT-FY19-112018-002670-A	<1	FT-FY19-112018-002670-B	<1
WS- 002671	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 214 Left	WF-10092018-002671	11/22/2018	FT-FY19-112018-002671-A	<1	FT-FY19-112018-002671-B	<1
WS- 002672	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 219 Right	WF-06042018-002672	11/22/2018	FT-FY19-112018-002672-A	<1	FT-FY19-112018-002672-B	<1
WS- 002673	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 219	WF-10092018-002673	11/22/2018	FT-FY19-112018-002673-A	<1	FT-FY19-112018-002673-B	<1
WS- 002674	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 216 Right	WF-06042018-002674	11/22/2018	FT-FY19-112018-002674-A	<1	FT-FY19-112018-002674-B	<1
WS- 002675	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 216 Mid	WF-10092018-002675	11/22/2018	FT-FY19-112018-002675-A	<1	FT-FY19-112018-002675-B	<1
WS- 002676	6/4/2018	6/4/2019	2	Combo Fountain	In classroom 221 Right	WF-06042018-002676	11/22/2018	FT-FY19-112018-002676-A	<1	FT-FY19-112018-002676-B	<1
WS- 002677	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 221 Left	WF-10092018-002677	11/22/2018	FT-FY19-112018-002677-A	<1	FT-FY19-112018-002677-B	<1
WS- 002678	6/4/2018	6/4/2019	2	Cooler	In cafeteria	WF-06042018-002678	11/22/2018	FT-FY19-112018-002678-A	<1	FT-FY19-112018-002678-B	<1
WS- 002680	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room 309 Low Left	WF-06042018-002680	11/22/2018	FT-FY19-112018-002680-A	<1	FT-FY19-112018-002680-B	<1
WS- 002681	6/4/2018	6/4/2019	3	Cooler	In hallway adjacent to room 309 High Right	WF-06042018-002681	11/22/2018	FT-FY19-112018-002681-A	<1	FT-FY19-112018-002681-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002679	2	Food Prep Sink	In kitchen	11/22/2018	FT-FY19-112018-002679-A	<1	FT-FY19-112018-002679-B	<1