



Powell Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001752	3/30/2021	3/30/2022	1	Cooler	In multi-purpose room	WF-03302021-001752	12/17/2021	FT-FY22-12012021-001752-A	<1	FT-FY22-12012021-001752-B	<1
WS-001753	3/30/2021	3/30/2022	1	Health Suite	In health suite B109	WF-03302021-001753	12/17/2021	FT-FY22-12012021-001753-A	<1	FT-FY22-12012021-001753-B	<1
WS-001754	9/15/2021	9/15/2022	1	Combo Faucet	In classroom B108	Left WF-09152021-001754	12/17/2021	FT-FY22-12012021-001754-A	<1	FT-FY22-12012021-001754-B	<1
WS-001755	3/30/2021	3/30/2022	1	Combo Fountain	In classroom B108	Right WF-03302021-001755	12/17/2021	FT-FY22-12012021-001755-A	<1	FT-FY22-12012021-001755-B	<1
WS-001756	3/30/2021	3/30/2022	1	Cooler	In hallway adjacent to room A105	High Left WF-03302021-001756	12/17/2021	FT-FY22-12012021-001756-A	<1	FT-FY22-12012021-001756-B	<1
WS-001757	3/30/2021	3/30/2022	1	Cooler	In hallway adjacent to room A105	Low Right WF-03302021-001757	12/17/2021	FT-FY22-12012021-001757-A	<1	FT-FY22-12012021-001757-B	<1
WS-001758	9/15/2021	9/15/2022	1	Combo Faucet	In classroom A105	Left WF-09152021-001758	12/17/2021	FT-FY22-12012021-001758-A	<1	FT-FY22-12012021-001758-B	<1
WS-001759	3/30/2021	3/30/2022	1	Combo Fountain	In classroom A105	Right WF-03302021-001759	12/17/2021	FT-FY22-12012021-001759-A	<1	FT-FY22-12012021-001759-B	<1
WS-001760	3/30/2021	3/30/2022	1	Cooler	In hallway across from room A103	High Left WF-03302021-001760	12/17/2021	FT-FY22-12012021-001760-A	<1	FT-FY22-12012021-001760-B	<1
WS-001761	3/30/2021	3/30/2022	1	Cooler	In hallway across from room A103	Low Right WF-03302021-001761	12/17/2021	FT-FY22-12012021-001761-A	<1	FT-FY22-12012021-001761-B	<1
WS-001762	9/15/2021	9/15/2022	1	Combo Faucet	In classroom A101	Left WF-09152021-001762	12/17/2021	FT-FY22-12012021-001762-A	<1	FT-FY22-12012021-001762-B	<1
WS-001763	3/30/2021	3/30/2022	1	Combo Fountain	In classroom A101	Right WF-03302021-001763	12/17/2021	FT-FY22-12012021-001763-A	<1	FT-FY22-12012021-001763-B	<1
WS-001764	3/30/2021	3/30/2022	1	Combo Fountain	In classroom A102	Right WF-03302021-001764	12/17/2021	FT-FY22-12012021-001764-A	<1	FT-FY22-12012021-001764-B	<1
WS-001765	9/15/2021	9/15/2022	1	Combo Faucet	In classroom A102	Left WF-09152021-001765	12/17/2021	FT-FY22-12012021-001765-A	<1	FT-FY22-12012021-001765-B	<1
WS-001766	3/30/2021	3/30/2022	1	Combo Fountain	In classroom A104	Right WF-03302021-001766	12/17/2021	FT-FY22-12012021-001766-A	<1	FT-FY22-12012021-001766-B	<1
WS-001767	9/15/2021	9/15/2022	1	Combo Faucet	In classroom A104	Left WF-09152021-001767	12/17/2021	FT-FY22-12012021-001767-A	<1	FT-FY22-12012021-001767-B	<1
WS-001768	9/15/2021	9/15/2022	1	Combo Faucet	In classroom A106	Left WF-09152021-001768	12/17/2021	FT-FY22-12012021-001768-A	<1	FT-FY22-12012021-001768-B	<1
WS-001769	3/30/2021	3/30/2022	1	Combo Fountain	In classroom A106	Right WF-03302021-001769	12/17/2021	FT-FY22-12012021-001769-A	<1	FT-FY22-12012021-001769-B	<1
WS-001770	9/15/2021	9/15/2022	1	Combo Faucet	In classroom B107	Left WF-09152021-001770	12/17/2021	FT-FY22-12012021-001770-A	<1	FT-FY22-12012021-001770-B	<1
WS-001771	3/30/2021	3/30/2022	1	Combo Fountain	In classroom B107	Right WF-03302021-001771	12/17/2021	FT-FY22-12012021-001771-A	2.2	FT-FY22-12012021-001771-B	<1
WS-001772	3/30/2021	3/30/2022	1	Cooler	In hallway across from B109	WF-03302021-001772	12/17/2021	FT-FY22-12012021-001772-A	<1	FT-FY22-12012021-001772-B	<1
WS-001773	9/15/2021	9/15/2022	1	Combo Faucet	In classroom B110	Left WF-09152021-001773	12/17/2021	FT-FY22-12012021-001773-A	<1	FT-FY22-12012021-001773-B	<1
WS-001774	3/30/2021	3/30/2022	1	Combo Fountain	In classroom B110	Right WF-03302021-001774	12/17/2021	FT-FY22-12012021-001774-A	<1	FT-FY22-12012021-001774-B	<1
WS-001775	3/30/2021	3/30/2022	1	Cooler	In hallway across from main office	WF-03302021-001775	12/17/2021	FT-FY22-12012021-001775-A	<1	FT-FY22-12012021-001775-B	<1
WS-001776	9/15/2021	9/15/2022	1	Combo Faucet	In classroom C113	Left WF-09152021-001776	12/17/2021	FT-FY22-12012021-001776-A	<1	FT-FY22-12012021-001776-B	<1
WS-001777	3/30/2021	3/30/2022	1	Combo Fountain	In classroom C113	Right WF-03302021-001777	12/17/2021	FT-FY22-12012021-001777-A	<1	FT-FY22-12012021-001777-B	<1
WS-001778	9/15/2021	9/15/2022	1	Combo Faucet	In classroom C114	Left WF-09152021-001778	12/17/2021	FT-FY22-12012021-001778-A	<1	FT-FY22-12012021-001778-B	<1
WS-001779	3/30/2021	3/30/2022	1	Combo Fountain	In classroom C114	Right WF-03302021-001779	12/17/2021	FT-FY22-12012021-001779-A	<1	FT-FY22-12012021-001779-B	<1
WS-001780	9/15/2021	9/15/2022	1	Combo Faucet	In classroom C115	Left WF-09152021-001780	12/17/2021	FT-FY22-12012021-001780-A	<1	FT-FY22-12012021-001780-B	<1
WS-001781	3/30/2021	3/30/2022	1	Combo Fountain	In classroom C115	Right WF-03302021-001781	12/17/2021	FT-FY22-12012021-001781-A	<1	FT-FY22-12012021-001781-B	<1
WS-001782	9/15/2021	9/15/2022	1	Combo Faucet	In classroom C116	Left WF-09152021-001782	12/17/2021	FT-FY22-12012021-001782-A	<1	FT-FY22-12012021-001782-B	<1
WS-001783	3/30/2021	3/30/2022	1	Combo Fountain	In classroom C116	Right WF-03302021-001783	12/17/2021	FT-FY22-12012021-001783-A	<1	FT-FY22-12012021-001783-B	<1
WS-001784	3/30/2021	3/30/2022	1	Combo Fountain	In classroom C117	Right WF-03302021-001784	12/17/2021	FT-FY22-12012021-001784-A	<1	FT-FY22-12012021-001784-B	<1
WS-001785	9/15/2021	9/15/2022	1	Combo Faucet	In classroom C117	WF-09152021-001785	12/17/2021	FT-FY22-12012021-001785-A	<1	FT-FY22-12012021-001785-B	<1
WS-001786	3/30/2021	3/30/2022	1	Combo Fountain	In classroom C118	Right WF-03302021-001786	12/17/2021	FT-FY22-12012021-001786-A	<1	FT-FY22-12012021-001786-B	<1
WS-001787	9/15/2021	9/15/2022	1	Combo Faucet	In classroom C118	Left WF-09152021-001787	12/17/2021	FT-FY22-12012021-001787-A	<1	FT-FY22-12012021-001787-B	<1
WS-001788	3/30/2021	3/30/2022	2	Break Room	In breakroom B216	Left WF-03302021-001788	12/17/2021	FT-FY22-12012021-001788-A	<1	FT-FY22-12012021-001788-B	<1

WS-001789	3/30/2021	3/30/2022	2	Combo Fountain	In classroom B216	Right	WF-03302021-001789	12/17/2021	FT-FY22-12012021-001789-A	<1	FT-FY22-12012021-001789-B	<1
WS-001790	3/30/2021	3/30/2022	2	Cooler	In hallway adjacent to room B216		WF-03302021-001790	12/17/2021	FT-FY22-12012021-001790-A	<1	FT-FY22-12012021-001790-B	<1
WS-001791	3/30/2021	3/30/2022	2	Combo Fountain	In classroom C221	Right	WF-03302021-001791	12/17/2021	FT-FY22-12012021-001791-A	<1	FT-FY22-12012021-001791-B	<1
WS-001792	9/15/2021	9/15/2022	2	Combo Faucet	In classroom C221	Left	WF-09152021-001792	12/17/2021	FT-FY22-12012021-001792-A	<1	FT-FY22-12012021-001792-B	<1
WS-001793	9/15/2021	9/15/2022	2	Combo Faucet	In classroom C222	Left	WF-09152021-001793	12/17/2021	FT-FY22-12012021-001793-A	<1	FT-FY22-12012021-001793-B	<1
WS-001794	3/30/2021	3/30/2022	2	Combo Fountain	In classroom C222	Right	WF-03302021-001794	12/17/2021	FT-FY22-12012021-001794-A	<1	FT-FY22-12012021-001794-B	<1
WS-001795	3/30/2021	3/30/2022	2	Combo Fountain	In classroom C223	Right	WF-03302021-001795	12/17/2021	FT-FY22-12012021-001795-A	<1	FT-FY22-12012021-001795-B	<1
WS-001796	9/15/2021	9/15/2022	2	Combo Faucet	In classroom C223	Left	WF-09152021-001796	12/17/2021	FT-FY22-12012021-001796-A	<1	FT-FY22-12012021-001796-B	<1
WS-001797	3/30/2021	3/30/2022	2	Combo Fountain	In classroom C224	Right	WF-03302021-001797	12/17/2021	FT-FY22-12012021-001797-A	<1	FT-FY22-12012021-001797-B	<1
WS-001798	9/15/2021	9/15/2022	2	Combo Faucet	In classroom C224	Left	WF-09152021-001798	12/17/2021	FT-FY22-12012021-001798-A	<1	FT-FY22-12012021-001798-B	<1
WS-001799	9/15/2021	9/15/2022	2	Combo Faucet	In classroom A201	Left	WF-09152021-001799	12/17/2021	FT-FY22-12012021-001799-A	<1	FT-FY22-12012021-001799-B	<1
WS-001800	3/30/2021	3/30/2022	2	Combo Fountain	In classroom A201	Left	WF-03302021-001800	12/17/2021	FT-FY22-12012021-001800-A	<1	FT-FY22-12012021-001800-B	<1
WS-001801	3/30/2021	3/30/2022	2	Cooler	In hallway across from room A204	High Left	WF-03302021-001801	12/17/2021	FT-FY22-12012021-001801-A	<1	FT-FY22-12012021-001801-B	<1
WS-001802	3/30/2021	3/30/2022	2	Cooler	In hallway across from room A204	Low Right	WF-03302021-001802	12/17/2021	FT-FY22-12012021-001802-A	<1	FT-FY22-12012021-001802-B	<1
WS-001803	9/15/2021	9/15/2022	2	Combo Faucet	In classroom A202	Left	WF-09152021-001803	12/17/2021	FT-FY22-12012021-001803-A	<1	FT-FY22-12012021-001803-B	<1
WS-001804	3/30/2021	3/30/2022	2	Combo Fountain	In classroom A202	Right	WF-03302021-001804	12/17/2021	FT-FY22-12012021-001804-A	<1	FT-FY22-12012021-001804-B	<1
WS-001805	9/15/2021	9/15/2022	2	Combo Faucet	In classroom A204	Left	WF-09152021-001805	12/17/2021	FT-FY22-12012021-001805-A	<1	FT-FY22-12012021-001805-B	<1
WS-001807	9/15/2021	9/15/2022	2	Combo Faucet	In classroom A206	Right	WF-09152021-001807	12/17/2021	FT-FY22-12012021-001807-A	<1	FT-FY22-12012021-001807-B	<1
WS-001808	3/30/2021	3/30/2022	2	Combo Fountain	In classroom A206	Right	WF-03302021-001808	12/17/2021	FT-FY22-12012021-001808-A	<1	FT-FY22-12012021-001808-B	<1
WS-001809	3/30/2021	3/30/2022	2	Cooler	In hallway adjacent to room A206	High Left	WF-03302021-001809	12/17/2021	FT-FY22-12012021-001809-A	<1	FT-FY22-12012021-001809-B	<1
WS-001810	3/30/2021	3/30/2022	2	Cooler	In hallway adjacent to room A206	Low Right	WF-03302021-001810	12/17/2021	FT-FY22-12012021-001810-A	<1	FT-FY22-12012021-001810-B	<1
WS-001811	9/15/2021	9/15/2022	2	Combo Faucet	In classroom A207	Left	WF-09152021-001811	12/17/2021	FT-FY22-12012021-001811-A	<1	FT-FY22-12012021-001811-B	<1
WS-001812	3/30/2021	3/30/2022	2	Combo Fountain	In classroom A207	Right	WF-03302021-001812	12/17/2021	FT-FY22-12012021-001812-A	<1	FT-FY22-12012021-001812-B	<1
WS-001813	9/15/2021	9/15/2022	2	Combo Faucet	In classroom B208	Left	WF-09152021-001813	12/17/2021	FT-FY22-12012021-001813-A	<1	FT-FY22-12012021-001813-B	<1
WS-001814	3/30/2021	3/30/2022	2	Combo Fountain	In classroom B208	Right	WF-03302021-001814	12/17/2021	FT-FY22-12012021-001814-A	<1	FT-FY22-12012021-001814-B	<1
WS-001815	3/30/2021	3/30/2022	2	Cooler	In hallway adjacent to room 210		WF-03302021-001815	12/17/2021	FT-FY22-12012021-001815-A	<1	FT-FY22-12012021-001815-B	<1
WS-001816	9/15/2021	9/15/2022	2	Combo Faucet	In classroom B211	Left	WF-09152021-001816	12/17/2021	FT-FY22-12012021-001816-A	<1	FT-FY22-12012021-001816-B	<1
WS-001817	3/30/2021	3/30/2022	2	Combo Fountain	In classroom B211	Right	WF-03302021-001817	12/17/2021	FT-FY22-12012021-001817-A	<1	FT-FY22-12012021-001817-B	<1
WS-001818	9/15/2021	9/15/2022	2	Combo Faucet	In classroom B212	Left	WF-09152021-001818	12/17/2021	FT-FY22-12012021-001818-A	<1	FT-FY22-12012021-001818-B	<1
WS-001819	3/30/2021	3/30/2022	2	Combo Fountain	In classroom B212	Right	WF-03302021-001819	12/17/2021	FT-FY22-12012021-001819-A	<1	FT-FY22-12012021-001819-B	<1
WS-001820	3/30/2021	3/30/2022	2	Combo Fountain	In classroom 229D		WF-03302021-001820	12/17/2021	FT-FY22-12012021-001820-A	<1	FT-FY22-12012021-001820-B	<1
WS-002445	3/30/2021	3/30/2022	2	Break Room	In break room B213	Left	WF-03302021-002445	12/17/2021	FT-FY22-12012021-002445-A	<1	FT-FY22-12012021-002445-B	<1
WS-002446	3/30/2021	3/30/2022	2	Combo Fountain	In break room B213	Right	WF-03302021-002446	12/17/2021	FT-FY22-12012021-002446-A	<1	FT-FY22-12012021-002446-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001823	2/2/2021	2/2/2022	Ground Floor	Food Prep Sink	In kitchen first sink clockwise from cafeteria entrance	WF-02022021-001823	12/17/2021	FT-FY22-12012021-001823-A	<1	FT-FY22-12012021-001823-B	<1
WS-001824	2/2/2021	2/2/2022	Ground Floor	Food Prep Sink	In kitchen second sink clockwise from cafeteria entrance	WF-02022021-001824	12/17/2021	FT-FY22-12012021-001824-A	<1	FT-FY22-12012021-001824-B	<1
WS-001825	2/2/2021	2/2/2022	Ground Floor	Food Prep Sink	In kitchen third sink clockwise from cafeteria entrance	Left WF-02022021-001825	12/17/2021	FT-FY22-12012021-001825-A	<1	FT-FY22-12012021-001825-B	<1