



Powell Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001753	3/20/2022	3/20/2023	1	Health Suite	In health suite B109	WF-03202022-001753	1/10/2023	FT-FY23-11182022-001753-A	<1	FT-FY23-11182022-001753-B	<1
WS-001754	9/7/2022	9/7/2023	1	Combo Faucet	In classroom B108 Left	WF-09072022-001754	1/10/2023	FT-FY23-11182022-001754-A	<1	FT-FY23-11182022-001754-B	<1
WS-001755	3/20/2022	3/20/2023	1	Combo Fountain	In classroom B108 Right	WF-03202022-001755	1/10/2023	FT-FY23-11182022-001755-A	<1	FT-FY23-11182022-001755-B	<1
WS-001756	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to room A105 High Left	WF-03202022-001756	1/10/2023	FT-FY23-11182022-001756-A	<1	FT-FY23-11182022-001756-B	<1
WS-001757	3/20/2022	3/20/2023	1	Cooler	In hallway adjacent to room A105 Low Right	WF-03202022-001757	1/10/2023	FT-FY23-11182022-001757-A	<1	FT-FY23-11182022-001757-B	<1
WS-001758	9/7/2022	9/7/2023	1	Combo Faucet	In classroom A105 Left	WF-09072022-001758	1/10/2023	FT-FY23-11182022-001758-A	<1	FT-FY23-11182022-001758-B	<1
WS-001759	3/20/2022	3/20/2023	1	Combo Fountain	In classroom A105 Right	WF-03202022-001759	1/10/2023	FT-FY23-11182022-001759-A	<1	FT-FY23-11182022-001759-B	<1
WS-001760	3/20/2022	3/20/2023	1	Cooler	In hallway across from room A103 High Left	WF-03202022-001760	1/10/2023	FT-FY23-11182022-001760-A	<1	FT-FY23-11182022-001760-B	<1
WS-001761	3/20/2022	3/20/2023	1	Cooler	In hallway across from room A103 Low Right	WF-03202022-001761	1/10/2023	FT-FY23-11182022-001761-A	<1	FT-FY23-11182022-001761-B	<1
WS-001764	3/20/2022	3/20/2023	1	Combo Fountain	In classroom A102 Right	WF-03202022-001764	1/10/2023	FT-FY23-11182022-001764-A	1.1	FT-FY23-11182022-001764-B	<1
WS-001765	9/7/2022	9/7/2023	1	Combo Faucet	In classroom A102 Left	WF-09072022-001765	1/10/2023	FT-FY23-11182022-001765-A	<1	FT-FY23-11182022-001765-B	<1
WS-001767	9/7/2022	9/7/2023	1	Combo Faucet	In classroom A104 Left	WF-09072022-001767	1/10/2023	FT-FY23-11182022-001767-A	<1	FT-FY23-11182022-001767-B	<1
WS-001768	9/7/2022	9/7/2023	1	Combo Faucet	In classroom A106 Left	WF-09072022-001768	1/10/2023	FT-FY23-11182022-001768-A	<1	FT-FY23-11182022-001768-B	<1
WS-001769	3/20/2022	3/20/2023	1	Combo Fountain	In classroom A106 Right	WF-03202022-001769	1/10/2023	FT-FY23-11182022-001769-A	<1	FT-FY23-11182022-001769-B	<1
WS-001770	9/7/2022	9/7/2023	1	Combo Faucet	In classroom B107 Left	WF-09072022-001770	1/10/2023	FT-FY23-11182022-001770-A	<1	FT-FY23-11182022-001770-B	<1
WS-001771	3/20/2022	3/20/2023	1	Combo Fountain	In classroom B107 Right	WF-03202022-001771	1/10/2023	FT-FY23-11182022-001771-A	<1	FT-FY23-11182022-001771-B	<1
WS-001772	3/20/2022	3/20/2023	1	Cooler	In hallway across from B109	WF-03202022-001772	1/10/2023	FT-FY23-11182022-001772-A	<1	FT-FY23-11182022-001772-B	<1
WS-001773	9/7/2022	9/7/2023	1	Combo Faucet	In classroom B110 Left	WF-09072022-001773	1/10/2023	FT-FY23-11182022-001773-A	<1	FT-FY23-11182022-001773-B	<1
WS-001774	3/20/2022	3/20/2023	1	Combo Fountain	In classroom B110 Right	WF-03202022-001774	1/10/2023	FT-FY23-11182022-001774-A	<1	FT-FY23-11182022-001774-B	<1
WS-001775	3/20/2022	3/20/2023	1	Cooler	In hallway across from main office	WF-03202022-001775	1/10/2023	FT-FY23-11182022-001775-A	<1	FT-FY23-11182022-001775-B	<1
WS-001776	9/7/2022	9/7/2023	1	Combo Faucet	In classroom C113 Left	WF-09072022-001776	1/10/2023	FT-FY23-11182022-001776-A	<1	FT-FY23-11182022-001776-B	<1
WS-001777	3/20/2022	3/20/2023	1	Combo Fountain	In classroom C113 Right	WF-03202022-001777	1/10/2023	FT-FY23-11182022-001777-A	<1	FT-FY23-11182022-001777-B	<1
WS-001778	9/7/2022	9/7/2023	1	Combo Faucet	In classroom C114 Left	WF-09072022-001778	1/10/2023	FT-FY23-11182022-001778-A	<1	FT-FY23-11182022-001778-B	<1
WS-001779	3/20/2022	3/20/2023	1	Combo Fountain	In classroom C114 Right	WF-03202022-001779	1/10/2023	FT-FY23-11182022-001779-A	<1	FT-FY23-11182022-001779-B	<1
WS-001780	9/7/2022	9/7/2023	1	Combo Faucet	In classroom C115 Left	WF-09072022-001780	1/10/2023	FT-FY23-11182022-001780-A	<1	FT-FY23-11182022-001780-B	<1
WS-001781	3/20/2022	3/20/2023	1	Combo Fountain	In classroom C115 Right	WF-03202022-001781	1/10/2023	FT-FY23-11182022-001781-A	<1	FT-FY23-11182022-001781-B	<1
WS-001782	9/7/2022	9/7/2023	1	Combo Faucet	In classroom C116 Left	WF-09072022-001782	1/10/2023	FT-FY23-11182022-001782-A	<1	FT-FY23-11182022-001782-B	<1
WS-001783	3/20/2022	3/20/2023	1	Combo Fountain	In classroom C116 Right	WF-03202022-001783	1/10/2023	FT-FY23-11182022-001783-A	<1	FT-FY23-11182022-001783-B	<1
WS-001784	3/20/2022	3/20/2023	1	Combo Fountain	In classroom C117 Right	WF-03202022-001784	1/10/2023	FT-FY23-11182022-001784-A	<1	FT-FY23-11182022-001784-B	<1
WS-001785	9/7/2022	9/7/2023	1	Combo Faucet	In classroom C117	WF-09072022-001785	1/10/2023	FT-FY23-11182022-001785-A	<1	FT-FY23-11182022-001785-B	<1
WS-001786	3/20/2022	3/20/2023	1	Combo Fountain	In classroom C118 Right	WF-03202022-001786	1/10/2023	FT-FY23-11182022-001786-A	<1	FT-FY23-11182022-001786-B	<1
WS-001787	9/7/2022	9/7/2023	1	Combo Faucet	In classroom C118 Left	WF-09072022-001787	1/10/2023	FT-FY23-11182022-001787-A	<1	FT-FY23-11182022-001787-B	<1
WS-001788	3/20/2022	3/20/2023	2	Break Room	In breakroom B216 Left	WF-03202022-001788	1/10/2023	FT-FY23-11182022-001788-A	<1	FT-FY23-11182022-001788-B	<1
WS-001790	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to room B216	WF-03202022-001790	1/10/2023	FT-FY23-11182022-001790-A	<1	FT-FY23-11182022-001790-B	<1
WS-001793	9/7/2022	9/7/2023	2	Combo Faucet	In classroom C222 Left	WF-09072022-001793	1/10/2023	FT-FY23-11182022-001793-A	<1	FT-FY23-11182022-001793-B	<1
WS-001794	3/20/2022	3/20/2023	2	Combo Fountain	In classroom C222 Right	WF-03202022-001794	1/10/2023	FT-FY23-11182022-001794-A	<1	FT-FY23-11182022-001794-B	<1

WS-001795	3/20/2022	3/20/2023	2	Combo Fountain	In classroom C223	Right	WF-03202022-001795	1/10/2023	FT-FY23-11182022-001795-A	<1	FT-FY23-11182022-001795-B	<1
WS-001796	9/7/2022	9/7/2023	2	Combo Faucet	In classroom C223	Left	WF-09072022-001796	1/10/2023	FT-FY23-11182022-001796-A	<1	FT-FY23-11182022-001796-B	<1
WS-001797	3/20/2022	3/20/2023	2	Combo Fountain	In classroom C224	Right	WF-03202022-001797	1/10/2023	FT-FY23-11182022-001797-A	1.8	FT-FY23-11182022-001797-B	<1
WS-001798	9/7/2022	9/7/2023	2	Combo Faucet	In classroom C224	Left	WF-09072022-001798	1/10/2023	FT-FY23-11182022-001798-A	<1	FT-FY23-11182022-001798-B	<1
WS-001799	9/7/2022	9/7/2023	2	Combo Faucet	In classroom A201	Left	WF-09072022-001799	1/10/2023	FT-FY23-11182022-001799-A	<1	FT-FY23-11182022-001799-B	<1
WS-001800	3/20/2022	3/20/2023	2	Combo Fountain	In classroom A201	Left	WF-03202022-001800	1/10/2023	FT-FY23-11182022-001800-A	<1	FT-FY23-11182022-001800-B	<1
WS-001801	3/20/2022	3/20/2023	2	Cooler	In hallway across from room A204	High Left	WF-03202022-001801	1/10/2023	FT-FY23-11182022-001801-A	<1	FT-FY23-11182022-001801-B	<1
WS-001802	3/20/2022	3/20/2023	2	Cooler	In hallway across from room A204	Low Right	WF-03202022-001802	1/10/2023	FT-FY23-11182022-001802-A	<1	FT-FY23-11182022-001802-B	<1
WS-001803	9/7/2022	9/7/2023	2	Combo Faucet	In classroom A202	Left	WF-09072022-001803	1/10/2023	FT-FY23-11182022-001803-A	<1	FT-FY23-11182022-001803-B	<1
WS-001804	3/20/2022	3/20/2023	2	Combo Fountain	In classroom A202	Right	WF-03202022-001804	1/10/2023	FT-FY23-11182022-001804-A	<1	FT-FY23-11182022-001804-B	<1
WS-001805	9/7/2022	9/7/2023	2	Combo Faucet	In classroom A204	Left	WF-09072022-001805	1/10/2023	FT-FY23-11182022-001805-A	<1	FT-FY23-11182022-001805-B	<1
WS-001806	3/20/2022	3/20/2023	2	Combo Fountain	In classroom A204	Right	WF-03202022-001806	1/10/2023	FT-FY23-11182022-001806-A	<1	FT-FY23-11182022-001806-B	<1
WS-001807	9/7/2022	9/7/2023	2	Combo Faucet	In classroom A206	Right	WF-09072022-001807	1/10/2023	FT-FY23-11182022-001807-A	<1	FT-FY23-11182022-001807-B	<1
WS-001808	3/20/2022	3/20/2023	2	Combo Fountain	In classroom A206	Right	WF-03202022-001808	1/10/2023	FT-FY23-11182022-001808-A	<1	FT-FY23-11182022-001808-B	<1
WS-001809	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to room A206	High Left	WF-03202022-001809	1/10/2023	FT-FY23-11182022-001809-A	<1	FT-FY23-11182022-001809-B	<1
WS-001810	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to room A206	Low Right	WF-03202022-001810	1/10/2023	FT-FY23-11182022-001810-A	<1	FT-FY23-11182022-001810-B	<1
WS-001811	9/7/2022	9/7/2023	2	Combo Faucet	In classroom A207	Left	WF-09072022-001811	1/10/2023	FT-FY23-11182022-001811-A	<1	FT-FY23-11182022-001811-B	<1
WS-001812	3/20/2022	3/20/2023	2	Combo Fountain	In classroom A207	Right	WF-03202022-001812	1/10/2023	FT-FY23-11182022-001812-A	<1	FT-FY23-11182022-001812-B	<1
WS-001813	9/7/2022	9/7/2023	2	Combo Faucet	In classroom B208	Left	WF-09072022-001813	1/10/2023	FT-FY23-11182022-001813-A	<1	FT-FY23-11182022-001813-B	<1
WS-001814	3/20/2022	3/20/2023	2	Combo Fountain	In classroom B208	Right	WF-03202022-001814	1/10/2023	FT-FY23-11182022-001814-A	<1	FT-FY23-11182022-001814-B	<1
WS-001815	3/20/2022	3/20/2023	2	Cooler	In hallway adjacent to room 210		WF-03202022-001815	1/10/2023	FT-FY23-11182022-001815-A	<1	FT-FY23-11182022-001815-B	<1
WS-001816	9/7/2022	9/7/2023	2	Combo Faucet	In classroom B211	Left	WF-09072022-001816	1/10/2023	FT-FY23-11182022-001816-A	<1	FT-FY23-11182022-001816-B	<1
WS-001817	3/20/2022	3/20/2023	2	Combo Fountain	In classroom B211	Right	WF-03202022-001817	1/10/2023	FT-FY23-11182022-001817-A	<1	FT-FY23-11182022-001817-B	<1
WS-001818	9/7/2022	9/7/2023	2	Combo Faucet	In classroom B212	Left	WF-09072022-001818	1/10/2023	FT-FY23-11182022-001818-A	<1	FT-FY23-11182022-001818-B	<1
WS-001819	3/20/2022	3/20/2023	2	Combo Fountain	In classroom B212	Right	WF-03202022-001819	1/10/2023	FT-FY23-11182022-001819-A	<1	FT-FY23-11182022-001819-B	<1
WS-001820	3/20/2022	3/20/2023	2	Combo Fountain	In classroom 229D		WF-03202022-001820	1/10/2023	FT-FY23-11182022-001820-A	<1	FT-FY23-11182022-001820-B	<1
WS-002445	3/20/2022	3/20/2023	2	Break Room	In break room B213	Left	WF-03202022-002445	1/10/2023	FT-FY23-11182022-002445-A	<1	FT-FY23-11182022-002445-B	<1
WS-002446	3/20/2022	3/20/2023	2	Combo Fountain	In break room B213	Right	WF-03202022-002446	1/10/2023	FT-FY23-11182022-002446-A	<1	FT-FY23-11182022-002446-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001823	1/25/2022	1/25/2023	Ground Floor	Food Prep Sink	In kitchen first sink clockwise from cafeteria entrance	WF-01252022-001823	1/10/2023	FT-FY23-11182022-001823-A	<1	FT-FY23-11182022-001823-B	<1
WS-001824	1/25/2022	1/25/2023	Ground Floor	Food Prep Sink	In kitchen second sink clockwise from cafeteria entrance	WF-01252022-001824	1/10/2023	FT-FY23-11182022-001824-A	<1	FT-FY23-11182022-001824-B	<1
WS-001825	1/25/2022	1/25/2023	Ground Floor	Food Prep Sink	In kitchen third sink clockwise from cafeteria entrance	Left WF-01252022-001825	1/10/2023	FT-FY23-11182022-001825-A	<1	FT-FY23-11182022-001825-B	<1