



Powell Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001753	4/6/2020	4/6/2021	1	Health Suite	In health suite B109	WF-04062020-001753	3/5/2021	FT-FY21-022021-001753-A	<1	FT-FY21-022021-001753-B	<1	
WS-001754	9/21/2020	9/21/2021	1	Combo Faucet	In classroom B108	Left	WF-09212020-001754	3/5/2021	FT-FY21-022021-001754-A	<1	FT-FY21-022021-001754-B	<1
WS-001755	4/6/2020	4/6/2021	1	Combo Fountain	In classroom B108	Right	WF-04062020-001755	3/5/2021	FT-FY21-022021-001755-A	<1	FT-FY21-022021-001755-B	<1
WS-001756	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room A105	High Left	WF-04062020-001756	3/5/2021	FT-FY21-022021-001756-A	<1	FT-FY21-022021-001756-B	<1
WS-001757	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room A105	Low Right	WF-04062020-001757	3/5/2021	FT-FY21-022021-001757-A	<1	FT-FY21-022021-001757-B	<1
WS-001758	9/21/2020	9/21/2021	1	Combo Faucet	In classroom A105	Left	WF-09212020-001758	3/5/2021	FT-FY21-022021-001758-A	<1	FT-FY21-022021-001758-B	<1
WS-001759	4/6/2020	4/6/2021	1	Combo Fountain	In classroom A105	Right	WF-04062020-001759	3/5/2021	FT-FY21-022021-001759-A	<1	FT-FY21-022021-001759-B	<1
WS-001760	4/6/2020	4/6/2021	1	Cooler	In hallway across from room A103	High Left	WF-04062020-001760	3/5/2021	FT-FY21-022021-001760-A	<1	FT-FY21-022021-001760-B	<1
WS-001761	4/6/2020	4/6/2021	1	Cooler	In hallway across from room A103	Low Right	WF-04062020-001761	3/5/2021	FT-FY21-022021-001761-A	<1	FT-FY21-022021-001761-B	<1
WS-001762	9/21/2020	9/21/2021	1	Combo Faucet	In classroom A101	Left	WF-09212020-001762	3/5/2021	FT-FY21-022021-001762-A	<1	FT-FY21-022021-001762-B	<1
WS-001763	4/6/2020	4/6/2021	1	Combo Fountain	In classroom A101	Right	WF-04062020-001763	3/5/2021	FT-FY21-022021-001763-A	<1	FT-FY21-022021-001763-B	<1
WS-001764	4/6/2020	4/6/2021	1	Combo Fountain	In classroom A102	Right	WF-04062020-001764	3/5/2021	FT-FY21-022021-001764-A	<1	FT-FY21-022021-001764-B	<1
WS-001765	9/21/2020	9/21/2021	1	Combo Faucet	In classroom A102	Left	WF-09212020-001765	3/5/2021	FT-FY21-022021-001765-A	<1	FT-FY21-022021-001765-B	<1
WS-001766	4/6/2020	4/6/2021	1	Combo Fountain	In classroom A104	Right	WF-04062020-001766	3/5/2021	FT-FY21-022021-001766-A	<1	FT-FY21-022021-001766-B	<1
WS-001767	9/21/2020	9/21/2021	1	Combo Faucet	In classroom A104	Left	WF-09212020-001767	3/5/2021	FT-FY21-022021-001767-A	<1	FT-FY21-022021-001767-B	<1
WS-001768	9/21/2020	9/21/2021	1	Combo Faucet	In classroom A106	Left	WF-09212020-001768	3/5/2021	FT-FY21-022021-001768-A	<1	FT-FY21-022021-001768-B	<1
WS-001769	4/6/2020	4/6/2021	1	Combo Fountain	In classroom A106	Right	WF-04062020-001769	3/5/2021	FT-FY21-022021-001769-A	<1	FT-FY21-022021-001769-B	<1
WS-001770	9/21/2020	9/21/2021	1	Combo Faucet	In classroom B107	Left	WF-09212020-001770	3/5/2021	FT-FY21-022021-001770-A	<1	FT-FY21-022021-001770-B	<1
WS-001771	4/6/2020	4/6/2021	1	Combo Fountain	In classroom B107	Right	WF-04062020-001771	3/5/2021	FT-FY21-022021-001771-A	<1	FT-FY21-022021-001771-B	<1
WS-001772	4/6/2020	4/6/2021	1	Cooler	In hallway across from B109		WF-04062020-001772	3/5/2021	FT-FY21-022021-001772-A	<1	FT-FY21-022021-001772-B	<1
WS-001773	9/21/2020	9/21/2021	1	Combo Faucet	In classroom B110	Left	WF-09212020-001773	3/5/2021	FT-FY21-022021-001773-A	<1	FT-FY21-022021-001773-B	<1
WS-001774	4/6/2020	4/6/2021	1	Combo Fountain	In classroom B110	Right	WF-04062020-001774	3/5/2021	FT-FY21-022021-001774-A	<1	FT-FY21-022021-001774-B	<1
WS-001775	4/6/2020	4/6/2021	1	Cooler	In hallway across from main office		WF-04062020-001775	3/5/2021	FT-FY21-022021-001775-A	<1	FT-FY21-022021-001775-B	<1
WS-001776	9/21/2020	9/21/2021	1	Combo Faucet	In classroom C113	Left	WF-09212020-001776	3/5/2021	FT-FY21-022021-001776-A	<1	FT-FY21-022021-001776-B	<1
WS-001777	4/6/2020	4/6/2021	1	Combo Fountain	In classroom C113	Right	WF-04062020-001777	3/5/2021	FT-FY21-022021-001777-A	<1	FT-FY21-022021-001777-B	<1
WS-001778	9/21/2020	9/21/2021	1	Combo Faucet	In classroom C114	Left	WF-09212020-001778	3/5/2021	FT-FY21-022021-001778-A	<1	FT-FY21-022021-001778-B	<1
WS-001779	4/6/2020	4/6/2021	1	Combo Fountain	In classroom C114	Right	WF-04062020-001779	3/5/2021	FT-FY21-022021-001779-A	<1	FT-FY21-022021-001779-B	<1
WS-001780	9/21/2020	9/21/2021	1	Combo Faucet	In classroom C115	Left	WF-09212020-001780	3/5/2021	FT-FY21-022021-001780-A	<1	FT-FY21-022021-001780-B	<1
WS-001781	4/6/2020	4/6/2021	1	Combo Fountain	In classroom C115	Right	WF-04062020-001781	3/5/2021	FT-FY21-022021-001781-A	<1	FT-FY21-022021-001781-B	<1
WS-001782	9/21/2020	9/21/2021	1	Combo Faucet	In classroom C116	Left	WF-09212020-001782	3/5/2021	FT-FY21-022021-001782-A	<1	FT-FY21-022021-001782-B	<1
WS-001783	4/6/2020	4/6/2021	1	Combo Fountain	In classroom C116	Right	WF-04062020-001783	3/5/2021	FT-FY21-022021-001783-A	<1	FT-FY21-022021-001783-B	<1
WS-001784	4/6/2020	4/6/2021	1	Combo Fountain	In classroom C117	Right	WF-04062020-001784	3/5/2021	FT-FY21-022021-001784-A	<1	FT-FY21-022021-001784-B	<1

WS-001785	9/21/2020	9/21/2021	1	Combo Faucet	In classroom C117		WF-09212020-001785	3/5/2021	FT-FY21-022021-001785-A	<1	FT-FY21-022021-001785-B	<1
WS-001786	4/6/2020	4/6/2021	1	Combo Fountain	In classroom C118	Right	WF-04062020-001786	3/5/2021	FT-FY21-022021-001786-A	<1	FT-FY21-022021-001786-B	<1
WS-001787	9/21/2020	9/21/2021	1	Combo Faucet	In classroom C118	Left	WF-09212020-001787	3/5/2021	FT-FY21-022021-001787-A	<1	FT-FY21-022021-001787-B	<1
WS-001788	4/6/2020	4/6/2021	2	Break Room	In breakroom B216	Left	WF-04062020-001788	3/5/2021	FT-FY21-022021-001788-A	<1	FT-FY21-022021-001788-B	<1
WS-001789	4/6/2020	4/6/2021	2	Combo Fountain	In classroom B216	Right	WF-04062020-001789	3/5/2021	FT-FY21-022021-001789-A	<1	FT-FY21-022021-001789-B	<1
WS-001790	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room B216		WF-04062020-001790	3/5/2021	FT-FY21-022021-001790-A	<1	FT-FY21-022021-001790-B	<1
WS-001791	4/6/2020	4/6/2021	2	Combo Fountain	In classroom C221	Right	WF-04062020-001791	3/5/2021	FT-FY21-022021-001791-A	<1	FT-FY21-022021-001791-B	<1
WS-001792	9/21/2020	9/21/2021	2	Combo Faucet	In classroom C221	Left	WF-09212020-001792	3/5/2021	FT-FY21-022021-001792-A	<1	FT-FY21-022021-001792-B	<1
WS-001793	9/21/2020	9/21/2021	2	Combo Faucet	In classroom C222	Left	WF-09212020-001793	3/5/2021	FT-FY21-022021-001793-A	<1	FT-FY21-022021-001793-B	<1
WS-001794	4/6/2020	4/6/2021	2	Combo Fountain	In classroom C222	Right	WF-04062020-001794	3/5/2021	FT-FY21-022021-001794-A	<1	FT-FY21-022021-001794-B	<1
WS-001795	4/6/2020	4/6/2021	2	Combo Fountain	In classroom C223	Right	WF-04062020-001795	3/5/2021	FT-FY21-022021-001795-A	<1	FT-FY21-022021-001795-B	<1
WS-001796	9/21/2020	9/21/2021	2	Combo Faucet	In classroom C223	Left	WF-09212020-001796	3/5/2021	FT-FY21-022021-001796-A	<1	FT-FY21-022021-001796-B	<1
WS-001797	4/6/2020	4/6/2021	2	Combo Fountain	In classroom C224	Right	WF-04062020-001797	3/5/2021	FT-FY21-022021-001797-A	<1	FT-FY21-022021-001797-B	<1
WS-001798	9/21/2020	9/21/2021	2	Combo Faucet	In classroom C224	Left	WF-09212020-001798	3/5/2021	FT-FY21-022021-001798-A	<1	FT-FY21-022021-001798-B	<1
WS-001799	9/21/2020	9/21/2021	2	Combo Faucet	In classroom A201	Left	WF-09212020-001799	3/5/2021	FT-FY21-022021-001799-A	<1	FT-FY21-022021-001799-B	<1
WS-001800	4/6/2020	4/6/2021	2	Combo Fountain	In classroom A201	Left	WF-04062020-001800	3/5/2021	FT-FY21-022021-001800-A	<1	FT-FY21-022021-001800-B	<1
WS-001801	4/6/2020	4/6/2021	2	Cooler	In hallway across from room A204	High Left	WF-04062020-001801	3/5/2021	FT-FY21-022021-001801-A	<1	FT-FY21-022021-001801-B	<1
WS-001802	4/6/2020	4/6/2021	2	Cooler	In hallway across from room A204	Low Right	WF-04062020-001802	3/5/2021	FT-FY21-022021-001802-A	<1	FT-FY21-022021-001802-B	<1
WS-001803	9/21/2020	9/21/2021	2	Combo Faucet	In classroom A202	Left	WF-09212020-001803	3/5/2021	FT-FY21-022021-001803-A	<1	FT-FY21-022021-001803-B	<1
WS-001804	4/6/2020	4/6/2021	2	Combo Fountain	In classroom A202	Right	WF-04062020-001804	3/5/2021	FT-FY21-022021-001804-A	<1	FT-FY21-022021-001804-B	<1
WS-001805	9/21/2020	9/21/2021	2	Combo Faucet	In classroom A204	Left	WF-09212020-001805	3/5/2021	FT-FY21-022021-001805-A	<1	FT-FY21-022021-001805-B	<1
WS-001806	4/6/2020	4/6/2021	2	Combo Fountain	In classroom A204	Right	WF-04062020-001806	3/5/2021	FT-FY21-022021-001806-A	1.5	FT-FY21-022021-001806-B	<1
WS-001807	9/21/2020	9/21/2021	2	Combo Faucet	In classroom A206	Right	WF-09212020-001807	3/5/2021	FT-FY21-022021-001807-A	<1	FT-FY21-022021-001807-B	<1
WS-001808	4/6/2020	4/6/2021	2	Combo Fountain	In classroom A206	Right	WF-04062020-001808	3/5/2021	FT-FY21-022021-001808-A	<1	FT-FY21-022021-001808-B	<1
WS-001809	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room A206	High Left	WF-04062020-001809	3/5/2021	FT-FY21-022021-001809-A	<1	FT-FY21-022021-001809-B	<1
WS-001810	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room A206	Low Right	WF-04062020-001810	3/5/2021	FT-FY21-022021-001810-A	<1	FT-FY21-022021-001810-B	<1
WS-001811	9/21/2020	9/21/2021	2	Combo Faucet	In classroom A207	Left	WF-09212020-001811	3/5/2021	FT-FY21-022021-001811-A	<1	FT-FY21-022021-001811-B	<1
WS-001812	4/6/2020	4/6/2021	2	Combo Fountain	In classroom A207	Right	WF-04062020-001812	3/5/2021	FT-FY21-022021-001812-A	<1	FT-FY21-022021-001812-B	<1
WS-001813	9/21/2020	9/21/2021	2	Combo Faucet	In classroom B208	Left	WF-09212020-001813	3/5/2021	FT-FY21-022021-001813-A	<1	FT-FY21-022021-001813-B	<1
WS-001814	4/6/2020	4/6/2021	2	Combo Fountain	In classroom B208	Right	WF-04062020-001814	3/5/2021	FT-FY21-022021-001814-A	<1	FT-FY21-022021-001814-B	<1
WS-001815	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room 210		WF-04062020-001815	3/5/2021	FT-FY21-022021-001815-A	<1	FT-FY21-022021-001815-B	<1
WS-001816	9/21/2020	9/21/2021	2	Combo Faucet	In classroom B211	Left	WF-09212020-001816	3/5/2021	FT-FY21-022021-001816-A	<1	FT-FY21-022021-001816-B	<1
WS-001817	4/6/2020	4/6/2021	2	Combo Fountain	In classroom B211	Right	WF-04062020-001817	3/5/2021	FT-FY21-022021-001817-A	<1	FT-FY21-022021-001817-B	<1
WS-001818	9/21/2020	9/21/2021	2	Combo Faucet	In classroom B212	Left	WF-09212020-001818	3/5/2021	FT-FY21-022021-001818-A	<1	FT-FY21-022021-001818-B	<1
WS-001819	4/6/2020	4/6/2021	2	Combo Fountain	In classroom B212	Right	WF-04062020-001819	3/5/2021	FT-FY21-022021-001819-A	<1	FT-FY21-022021-001819-B	<1
WS-001820	4/6/2020	4/6/2021	2	Combo Fountain	In classroom 229D		WF-04062020-001820	3/5/2021	FT-FY21-022021-001820-A	<1	FT-FY21-022021-001820-B	<1
WS-002445	4/6/2020	4/6/2021	2	Break Room	In break room B213	Left	WF-04062020-002445	3/5/2021	FT-FY21-022021-002445-A	<1	FT-FY21-022021-002445-B	<1
WS-002446	4/6/2020	4/6/2021	2	Combo Fountain	In break room B213	Right	WF-04062020-002446	3/5/2021	FT-FY21-022021-002446-A	<1	FT-FY21-022021-002446-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001823	2/2/2021	2/2/2022	Ground Floor	Food Prep Sink	In kitchen first sink clockwise from cafeteria entrance	WF-02022021-001823	3/5/2021	FT-FY21-022021-001823-A	<1	FT-FY21-022021-001823-B	<1
WS- 001824	2/2/2021	2/2/2022	Ground Floor	Food Prep Sink	In kitchen second sink clockwise from cafeteria entrance	WF-02022021-001824	3/5/2021	FT-FY21-022021-001824-A	<1	FT-FY21-022021-001824-B	<1
WS- 001825	2/2/2021	2/2/2022	Ground Floor	Food Prep Sink	In kitchen third sink clockwise from cafeteria entrance Left	WF-02022021-001825	3/5/2021	FT-FY21-022021-001825-A	<1	FT-FY21-022021-001825-B	<1