



Powell ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001752	4/15/2019	4/15/2020	1	Cooler	In multi-purpose room	WF-04152019-001752	12/9/2019	FT-FY20-112019-001752-A	<1	FT-FY20-112019-001752-B	<1	
WS-001753	4/15/2019	4/15/2020	1	Health Suite	In health suite B109	WF-04152019-001753	12/9/2019	FT-FY20-112019-001753-A	<1	FT-FY20-112019-001753-B	<1	
WS-001754	9/25/2019	9/25/2020	1	Combo Faucet	In classroom B108	Left	WF-09252019-001754	12/9/2019	FT-FY20-112019-001754-A	<1	FT-FY20-112019-001754-B	<1
WS-001755	4/15/2019	4/15/2020	1	Combo Fountain	In classroom B108	Right	WF-04152019-001755	12/9/2019	FT-FY20-112019-001755-A	<1	FT-FY20-112019-001755-B	<1
WS-001756	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room A105	High Left	WF-04152019-001756	12/9/2019	FT-FY20-112019-001756-A	<1	FT-FY20-112019-001756-B	<1
WS-001757	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room A105	Low Right	WF-04152019-001757	12/9/2019	FT-FY20-112019-001757-A	<1	FT-FY20-112019-001757-B	<1
WS-001758	9/25/2019	9/25/2020	1	Combo Faucet	In classroom A105	Left	WF-09252019-001758	12/9/2019	FT-FY20-112019-001758-A	<1	FT-FY20-112019-001758-B	<1
WS-001759	4/15/2019	4/15/2020	1	Combo Fountain	In classroom A105	Right	WF-04152019-001759	12/9/2019	FT-FY20-112019-001759-A	<1	FT-FY20-112019-001759-B	<1
WS-001760	4/15/2019	4/15/2020	1	Cooler	In hallway across from room A103	High Left	WF-04152019-001760	12/9/2019	FT-FY20-112019-001760-A	<1	FT-FY20-112019-001760-B	<1
WS-001761	4/15/2019	4/15/2020	1	Cooler	In hallway across from room A103	Low Right	WF-04152019-001761	12/9/2019	FT-FY20-112019-001761-A	<1	FT-FY20-112019-001761-B	<1
WS-001763	4/15/2019	4/15/2020	1	Combo Fountain	In classroom A101	Right	WF-04152019-001763	12/9/2019	FT-FY20-112019-001763-A	<1	FT-FY20-112019-001763-B	<1
WS-001764	4/15/2019	4/15/2020	1	Combo Fountain	In classroom A102	Right	WF-04152019-001764	12/9/2019	FT-FY20-112019-001764-A	<1	FT-FY20-112019-001764-B	<1
WS-001765	9/25/2019	9/25/2020	1	Combo Faucet	In classroom A102	Left	WF-09252019-001765	12/9/2019	FT-FY20-112019-001765-A	3.2	FT-FY20-112019-001765-B	<1
WS-001766	4/15/2019	4/15/2020	1	Combo Fountain	In classroom A104	Right	WF-04152019-001766	12/9/2019	FT-FY20-112019-001766-A	<1	FT-FY20-112019-001766-B	<1
WS-001767	9/25/2019	9/25/2020	1	Combo Faucet	In classroom A104	Left	WF-09252019-001767	12/9/2019	FT-FY20-112019-001767-A	<1	FT-FY20-112019-001767-B	<1
WS-001768	9/25/2019	9/25/2020	1	Combo Faucet	In classroom A106	Left	WF-09252019-001768	12/9/2019	FT-FY20-112019-001768-A	<1	FT-FY20-112019-001768-B	<1
WS-001769	4/15/2019	4/15/2020	1	Combo Fountain	In classroom A106	Right	WF-04152019-001769	12/9/2019	FT-FY20-112019-001769-A	<1	FT-FY20-112019-001769-B	<1
WS-001770	9/25/2019	9/25/2020	1	Combo Faucet	In classroom B107	Left	WF-09252019-001770	12/9/2019	FT-FY20-112019-001770-A	<1	FT-FY20-112019-001770-B	<1
WS-001771	4/15/2019	4/15/2020	1	Combo Fountain	In classroom B107	Right	WF-04152019-001771	12/9/2019	FT-FY20-112019-001771-A	<1	FT-FY20-112019-001771-B	<1
WS-001772	4/15/2019	4/15/2020	1	Cooler	In hallway across from B109		WF-04152019-001772	12/9/2019	FT-FY20-112019-001772-A	<1	FT-FY20-112019-001772-B	<1
WS-001773	9/25/2019	9/25/2020	1	Combo Faucet	In classroom B110	Left	WF-09252019-001773	12/9/2019	FT-FY20-112019-001773-A	<1	FT-FY20-112019-001773-B	<1
WS-001774	4/15/2019	4/15/2020	1	Combo Fountain	In classroom B110	Right	WF-04152019-001774	12/9/2019	FT-FY20-112019-001774-A	<1	FT-FY20-112019-001774-B	<1
WS-001775	4/15/2019	4/15/2020	1	Cooler	In hallway across from main office		WF-04152019-001775	12/9/2019	FT-FY20-112019-001775-A	<1	FT-FY20-112019-001775-B	<1
WS-001776	9/25/2019	9/25/2020	1	Combo Faucet	In classroom C113	Left	WF-09252019-001776	12/9/2019	FT-FY20-112019-001776-A	<1	FT-FY20-112019-001776-B	<1
WS-001777	4/15/2019	4/15/2020	1	Combo Fountain	In classroom C113	Right	WF-04152019-001777	12/9/2019	FT-FY20-112019-001777-A	<1	FT-FY20-112019-001777-B	<1
WS-001778	9/25/2019	9/25/2020	1	Combo Faucet	In classroom C114	Left	WF-09252019-001778	12/9/2019	FT-FY20-112019-001778-A	<1	FT-FY20-112019-001778-B	<1
WS-001779	4/15/2019	4/15/2020	1	Combo Fountain	In classroom C114	Right	WF-04152019-001779	12/9/2019	FT-FY20-112019-001779-A	<1	FT-FY20-112019-001779-B	<1
WS-001780	9/25/2019	9/25/2020	1	Combo Faucet	In classroom C115	Left	WF-09252019-001780	12/9/2019	FT-FY20-112019-001780-A	<1	FT-FY20-112019-001780-B	<1
WS-001781	4/15/2019	4/15/2020	1	Combo Fountain	In classroom C115	Right	WF-04152019-001781	12/9/2019	FT-FY20-112019-001781-A	<1	FT-FY20-112019-001781-B	<1
WS-001782	9/25/2019	9/25/2020	1	Combo Faucet	In classroom C116	Left	WF-09252019-001782	12/9/2019	FT-FY20-112019-001782-A	1.1	FT-FY20-112019-001782-B	<1
WS-001783	4/15/2019	4/15/2020	1	Combo Fountain	In classroom C116	Right	WF-04152019-001783	12/9/2019	FT-FY20-112019-001783-A	<1	FT-FY20-112019-001783-B	<1
WS-001784	4/15/2019	4/15/2020	1	Combo Fountain	In classroom C117	Right	WF-04152019-001784	12/9/2019	FT-FY20-112019-001784-A	<1	FT-FY20-112019-001784-B	<1
WS-001785	9/25/2019	9/25/2020	1	Combo Faucet	In classroom C117		WF-09252019-001785	12/9/2019	FT-FY20-112019-001785-A	<1	FT-FY20-112019-001785-B	<1
WS-001786	4/15/2019	4/15/2020	1	Combo Fountain	In classroom C118	Right	WF-04152019-001786	12/9/2019	FT-FY20-112019-001786-A	<1	FT-FY20-112019-001786-B	<1
WS-001787	9/25/2019	9/25/2020	1	Combo Faucet	In classroom C118	Left	WF-09252019-001787	12/9/2019	FT-FY20-112019-001787-A	<1	FT-FY20-112019-001787-B	<1
WS-001788	4/15/2019	4/15/2020	2	Break Room	In breakroom B216	Left	WF-04152019-001788	12/9/2019	FT-FY20-112019-001788-A	<1	FT-FY20-112019-001788-B	<1

WS- 001789	4/15/2019	4/15/2020	2	Combo Fountain	In classroom B216	Right	WF-04152019-001789	12/9/2019	FT-FY20-112019-001789-A	<1	FT-FY20-112019-001789-B	<1
WS- 001790	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room B216		WF-04152019-001790	12/9/2019	FT-FY20-112019-001790-A	<1	FT-FY20-112019-001790-B	<1
WS- 001791	4/15/2019	4/15/2020	2	Combo Fountain	In classroom C221	Right	WF-04152019-001791	12/9/2019	FT-FY20-112019-001791-A	<1	FT-FY20-112019-001791-B	<1
WS- 001792	9/25/2019	9/25/2020	2	Combo Faucet	In classroom C221	Left	WF-09252019-001792	12/9/2019	FT-FY20-112019-001792-A	<1	FT-FY20-112019-001792-B	<1
WS- 001793	9/25/2019	9/25/2020	2	Combo Faucet	In classroom C222	Left	WF-09252019-001793	12/9/2019	FT-FY20-112019-001793-A	<1	FT-FY20-112019-001793-B	<1
WS- 001794	4/15/2019	4/15/2020	2	Combo Fountain	In classroom C222	Right	WF-04152019-001794	12/9/2019	FT-FY20-112019-001794-A	<1	FT-FY20-112019-001794-B	<1
WS- 001795	4/15/2019	4/15/2020	2	Combo Fountain	In classroom C223	Right	WF-04152019-001795	12/9/2019	FT-FY20-112019-001795-A	<1	FT-FY20-112019-001795-B	<1
WS- 001796	9/25/2019	9/25/2020	2	Combo Faucet	In classroom C223	Left	WF-09252019-001796	12/9/2019	FT-FY20-112019-001796-A	<1	FT-FY20-112019-001796-B	<1
WS- 001797	4/15/2019	4/15/2020	2	Combo Fountain	In classroom C224	Right	WF-04152019-001797	12/9/2019	FT-FY20-112019-001797-A	<1	FT-FY20-112019-001797-B	<1
WS- 001798	9/25/2019	9/25/2020	2	Combo Faucet	In classroom C224	Left	WF-09252019-001798	12/9/2019	FT-FY20-112019-001798-A	<1	FT-FY20-112019-001798-B	<1
WS- 001799	9/25/2019	9/25/2020	2	Combo Faucet	In classroom A201	Left	WF-09252019-001799	12/9/2019	FT-FY20-112019-001799-A	<1	FT-FY20-112019-001799-B	<1
WS- 001801	4/15/2019	4/15/2020	2	Cooler	In hallway across from room A204	High Left	WF-04152019-001801	12/9/2019	FT-FY20-112019-001801-A	<1	FT-FY20-112019-001801-B	<1
WS- 001802	4/15/2019	4/15/2020	2	Cooler	In hallway across from room A204	Low Right	WF-04152019-001802	12/9/2019	FT-FY20-112019-001802-A	<1	FT-FY20-112019-001802-B	<1
WS- 001803	9/25/2019	9/25/2020	2	Combo Faucet	In classroom A202	Left	WF-09252019-001803	12/9/2019	FT-FY20-112019-001803-A	1.7	FT-FY20-112019-001803-B	<1
WS- 001804	4/15/2019	4/15/2020	2	Combo Fountain	In classroom A202	Right	WF-04152019-001804	12/9/2019	FT-FY20-112019-001804-A	<1	FT-FY20-112019-001804-B	<1
WS- 001805	9/25/2019	9/25/2020	2	Combo Faucet	In classroom A204	Left	WF-09252019-001805	12/9/2019	FT-FY20-112019-001805-A	<1	FT-FY20-112019-001805-B	<1
WS- 001806	4/15/2019	4/15/2020	2	Combo Fountain	In classroom A204	Right	WF-04152019-001806	12/9/2019	FT-FY20-112019-001806-A	<1	FT-FY20-112019-001806-B	<1
WS- 001807	9/25/2019	9/25/2020	2	Combo Faucet	In classroom A206	Right	WF-09252019-001807	12/9/2019	FT-FY20-112019-001807-A	2.8	FT-FY20-112019-001807-B	<1
WS- 001808	4/15/2019	4/15/2020	2	Combo Fountain	In classroom A206	Right	WF-04152019-001808	12/9/2019	FT-FY20-112019-001808-A	<1	FT-FY20-112019-001808-B	<1
WS- 001809	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room A206	High Left	WF-04152019-001809	12/9/2019	FT-FY20-112019-001809-A	<1	FT-FY20-112019-001809-B	<1
WS- 001810	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room A206	Low Right	WF-04152019-001810	12/9/2019	FT-FY20-112019-001810-A	<1	FT-FY20-112019-001810-B	<1
WS- 001811	9/25/2019	9/25/2020	2	Combo Faucet	In classroom A207	Left	WF-09252019-001811	12/9/2019	FT-FY20-112019-001811-A	<1	FT-FY20-112019-001811-B	<1
WS- 001812	4/15/2019	4/15/2020	2	Combo Fountain	In classroom A207	Right	WF-04152019-001812	12/9/2019	FT-FY20-112019-001812-A	<1	FT-FY20-112019-001812-B	<1
WS- 001813	9/25/2019	9/25/2020	2	Combo Faucet	In classroom B208	Left	WF-09252019-001813	12/9/2019	FT-FY20-112019-001813-A	<1	FT-FY20-112019-001813-B	<1
WS- 001814	4/15/2019	4/15/2020	2	Combo Fountain	In classroom B208	Right	WF-04152019-001814	12/9/2019	FT-FY20-112019-001814-A	<1	FT-FY20-112019-001814-B	<1
WS- 001815	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room 210		WF-04152019-001815	12/9/2019	FT-FY20-112019-001815-A	<1	FT-FY20-112019-001815-B	<1
WS- 001816	9/25/2019	9/25/2020	2	Combo Faucet	In classroom B211	Left	WF-09252019-001816	12/9/2019	FT-FY20-112019-001816-A	2.6	FT-FY20-112019-001816-B	<1
WS- 001817	4/15/2019	4/15/2020	2	Combo Fountain	In classroom B211	Right	WF-04152019-001817	12/9/2019	FT-FY20-112019-001817-A	<1	FT-FY20-112019-001817-B	<1
WS- 001818	9/25/2019	9/25/2020	2	Combo Faucet	In classroom B212	Left	WF-09252019-001818	12/9/2019	FT-FY20-112019-001818-A	<1	FT-FY20-112019-001818-B	<1
WS- 001819	4/15/2019	4/15/2020	2	Combo Fountain	In classroom B212	Right	WF-04152019-001819	12/9/2019	FT-FY20-112019-001819-A	<1	FT-FY20-112019-001819-B	<1
WS- 001820	4/15/2019	4/15/2020	2	Combo Fountain	In classroom 229D		WF-04152019-001820	12/9/2019	FT-FY20-112019-001820-A	<1	FT-FY20-112019-001820-B	<1
WS- 002445	4/15/2019	4/15/2020	2	Break Room	In break room B213	Left	WF-04152019-002445	12/9/2019	FT-FY20-112019-002445-A	<1	FT-FY20-112019-002445-B	<1
WS- 002446	4/15/2019	4/15/2020	2	Combo Fountain	In break room B213	Right	WF-04152019-002446	12/9/2019	FT-FY20-112019-002446-A	<1	FT-FY20-112019-002446-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001823	7/22/2019	7/22/2020	Ground Floor	Food Prep Sink	In kitchen first sink clockwise from cafeteria entrance	WF-07222019-001823	12/9/2019	FT-FY20-112019-001823-A	<1	FT-FY20-112019-001823-B	<1
WS- 001824	7/22/2019	7/22/2020	Ground Floor	Food Prep Sink	In kitchen second sink clockwise from cafeteria entrance	WF-07222019-001824	12/9/2019	FT-FY20-112019-001824-A	<1	FT-FY20-112019-001824-B	<1
WS- 001825	7/22/2019	7/22/2020	Ground Floor	Food Prep Sink	In kitchen third sink clockwise from cafeteria entrance	Left WF-07222019-001825	12/9/2019	FT-FY20-112019-001825-A	<1	FT-FY20-112019-001825-B	<1