



# POWELL ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	POWELL ELEMENTARY SCHOOL	WS-001750	8/19/2016	1	Other	In kitchen (dishwashing hose)	High	FT-72016-001750-A	< 1	FT-72016-001750-B	< 1
2	POWELL ELEMENTARY SCHOOL	WS-001751	8/19/2016	1	Food Prep Sink	In kitchen	Low	FT-82016-001751-A	< 1	FT-82016-001751-B	< 1
3	POWELL ELEMENTARY SCHOOL	WS-001752	8/19/2016	1	Cooler	In multi-purpose room		FT-72016-001752-A	< 1	FT-72016-001752-B	< 1
4	POWELL ELEMENTARY SCHOOL	WS-001753	8/19/2016	1	Health Suite	In health suite B109		FT-82016-001753-A	< 1	FT-82016-001753-B	< 1
5	POWELL ELEMENTARY SCHOOL	WS-001755	8/19/2016	1	Fountain	In kindergarten room B108	Right	FT-72016-001755-A	< 1	FT-72016-001755-B	< 1
6	POWELL ELEMENTARY SCHOOL	WS-001756	8/19/2016	1	Cooler	In hallway adjacent to room A105	High Left	FT-72016-001756-A	< 1	FT-72016-001756-B	< 1
7	POWELL ELEMENTARY SCHOOL	WS-001757	8/19/2016	1	Cooler	In hallway adjacent to room A105	Low Right	FT-82016-001757-A	< 1	FT-82016-001757-B	< 1
8	POWELL ELEMENTARY SCHOOL	WS-001759	8/19/2016	1	Fountain	In classroom 105	Right	FT-72016-001759-A	< 1	FT-72016-001759-B	< 1
9	POWELL ELEMENTARY SCHOOL	WS-001760	8/19/2016	1	Cooler	In hallway across from room A103	High Left	FT-82016-001760-A	< 1	FT-82016-001760-B	< 1
10	POWELL ELEMENTARY SCHOOL	WS-001761	8/19/2016	1	Cooler	In hallway across from room A103	Low Right	FT-72016-001761-A	< 1	FT-72016-001761-B	< 1
11	POWELL ELEMENTARY SCHOOL	WS-001763	8/19/2016	1	Fountain	In classroom A101	Right	FT-72016-001763-A	< 1	FT-72016-001763-B	< 1
12	POWELL ELEMENTARY SCHOOL	WS-001764	8/19/2016	1	Fountain	In classroom A102	Right	FT-72016-001764-A	< 1	FT-72016-001764-B	< 1
13	POWELL ELEMENTARY SCHOOL	WS-001766	8/19/2016	1	Fountain	In classroom A104	Right	FT-82016-001766-A	< 1	FT-82016-001766-B	< 1
14	POWELL ELEMENTARY SCHOOL	WS-001769	8/19/2016	1	Fountain	In classroom A106	Right	FT-72016-001769-A	< 1	FT-72016-001769-B	< 1
15	POWELL ELEMENTARY SCHOOL	WS-001771	8/19/2016	1	Fountain	In classroom B107	Right	FT-72016-001771-A	< 1	FT-72016-001771-B	< 1
16	POWELL ELEMENTARY SCHOOL	WS-001772	8/19/2016	1	Cooler	In hallway across from B109		FT-72016-001772-A	< 1	FT-72016-001772-B	< 1
17	POWELL ELEMENTARY SCHOOL	WS-001774	8/19/2016	1	Fountain	In classroom B110	Right	FT-72016-001774-A	< 1	FT-72016-001774-B	< 1
18	POWELL ELEMENTARY SCHOOL	WS-001775	8/19/2016	1	Cooler	In hallway across from main office		FT-72016-001775-A	< 1	FT-72016-001775-B	< 1
19	POWELL ELEMENTARY SCHOOL	WS-001777	8/19/2016	1	Fountain	In classroom C113	Right	FT-72016-001777-A	< 1	FT-72016-001777-B	< 1
20	POWELL ELEMENTARY SCHOOL	WS-001779	8/19/2016	1	Fountain	In classroom C114	Right	FT-72016-001779-A	< 1	FT-72016-001779-B	< 1
21	POWELL ELEMENTARY SCHOOL	WS-001781	8/19/2016	1	Fountain	In classroom C115	Right	FT-72016-001781-A	< 1	FT-72016-001781-B	< 1
22	POWELL ELEMENTARY SCHOOL	WS-001783	8/19/2016	1	Fountain	In classroom C116	Right	FT-72016-001783-A	< 1	FT-72016-001783-B	< 1
23	POWELL ELEMENTARY SCHOOL	WS-001784	8/19/2016	1	Classroom Faucet	In classroom C116	Right	FT-72016-001784-A	< 1	FT-72016-001784-B	< 1
24	POWELL ELEMENTARY SCHOOL	WS-001786	8/19/2016	1	Fountain	In classroom C118	Right	FT-72016-001786-A	< 1	FT-72016-001786-B	< 1
25	POWELL ELEMENTARY SCHOOL	WS-001789	8/19/2016	2	Fountain	In classroom B216	Right	FT-72016-001789-A	< 1	FT-72016-001789-B	< 1
26	POWELL ELEMENTARY SCHOOL	WS-001790	8/19/2016	2	Fountain	In hallways adjacent to room B216		FT-82016-001790-A	< 1	FT-82016-001790-B	< 1
27	POWELL ELEMENTARY SCHOOL	WS-001791	8/19/2016	2	Fountain	In classroom C221	Right	FT-72016-001791-A	< 1	FT-72016-001791-B	< 1
28	POWELL ELEMENTARY SCHOOL	WS-001794	8/19/2016	2	Fountain	In classroom C222	Right	FT-72016-001794-A	< 1	FT-72016-001794-B	< 1
29	POWELL ELEMENTARY SCHOOL	WS-001795	8/19/2016	2	Fountain	In classroom C223	Right	FT-72016-001795-A	< 1	FT-72016-001795-B	< 1
30	POWELL ELEMENTARY SCHOOL	WS-001797	8/19/2016	2	Fountain	In classroom C224	Right	FT-72016-001797-A	< 1	FT-72016-001797-B	< 1
31	POWELL ELEMENTARY SCHOOL	WS-001800	8/19/2016	2	Fountain	In classroom A201	Left	FT-72016-001800-A	< 1	FT-72016-001800-B	< 1
32	POWELL ELEMENTARY SCHOOL	WS-001801	8/19/2016	2	Cooler	In hallway across from room A204	High Left	FT-72016-001801-A	< 1	FT-72016-001801-B	< 1
33	POWELL ELEMENTARY SCHOOL	WS-001802	8/19/2016	2	Cooler	In hallway across from room A204	Low Right	FT-72016-001802-A	< 1	FT-72016-001802-B	< 1
34	POWELL ELEMENTARY SCHOOL	WS-001804	8/19/2016	2	Fountain	In classroom A202	Right	FT-72016-001804-A	< 1	FT-72016-001804-B	< 1
35	POWELL ELEMENTARY SCHOOL	WS-001806	8/19/2016	2	Fountain	In classroom A204	Right	FT-72016-001806-A	< 1	FT-72016-001806-B	< 1
36	POWELL ELEMENTARY SCHOOL	WS-001808	8/19/2016	2	Fountain	In classroom A206	Right	FT-72016-001808-A	< 1	FT-72016-001808-B	< 1
37	POWELL ELEMENTARY SCHOOL	WS-001809	8/19/2016	2	Cooler	In hallway adjacent to room A206	High Left	FT-72016-001809-A	< 1	FT-72016-001809-B	< 1
38	POWELL ELEMENTARY SCHOOL	WS-001810	8/19/2016	2	Cooler	In hallway adjacent to room A206	Low Right	FT-72016-001810-A	< 1	FT-72016-001810-B	< 1
39	POWELL ELEMENTARY SCHOOL	WS-001812	8/19/2016	2	Fountain	In classroom A207	Right	FT-72016-001812-A	< 1	FT-72016-001812-B	< 1
40	POWELL ELEMENTARY SCHOOL	WS-001814	8/19/2016	2	Fountain	In classroom B208	Right	FT-72016-001814-A	< 1	FT-72016-001814-B	< 1
41	POWELL ELEMENTARY SCHOOL	WS-001815	8/19/2016	2	Cooler	In hallway adjacent to room 210		FT-72016-001815-A	< 1	FT-72016-001815-B	< 1
42	POWELL ELEMENTARY SCHOOL	WS-001817	8/19/2016	2	Fountain	In classroom B211	Right	FT-72016-001817-A	< 1	FT-72016-001817-B	< 1
43	POWELL ELEMENTARY SCHOOL	WS-001819	8/19/2016	2	Fountain	In classroom B212	Right	FT-72016-001819-A	< 1	FT-72016-001819-B	< 1
44	POWELL ELEMENTARY SCHOOL	WS-002446	8/19/2016	2	Fountain	In break room B213	Right	FT-72016-002446-A	< 1	FT-72016-002446-B	< 1