



# POWELL LEAD WATER TEST RESULTS

May 12th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
1	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001819	Fountain	2	In room 212 Right	WT-042916-1836- A	< 1	WT-042916-1836- B	< 1			
2	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001818	Classroom	2	In room 212 Left	WT-042916-1835- A	< 1	WT-042916-1835- B	< 1			
3	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001817	Fountain	2	In room B211 Right	WT-042916-1834- A	< 1	WT-042916-1834- B	< 1			
4	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001816	Classroom	2	In room B211 Left	WT-042916-1833- A	< 1	WT-042916-1833- B	< 1			
5	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001815	Cooler	2	In hallway adjacent to room 210	WT-042916-1832- A	< 1	WT-042916-1832- B	< 1			
6	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001814	Fountain	2	In room B208 Right	WT-042916-1831- A	< 1	WT-042916-1831- B	< 1			
7	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001813	Classroom	2	In room B208 Left	WT-042916-1830- A	1.14	WT-042916-1830- B	< 1			
8	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001812	Fountain	2	In room A207 Right	WT-042916-1829- A	< 1	WT-042916-1829- B	< 1			
9	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001811	Classroom	2	In room A207 Left	WT-042916-1828- A	< 1	WT-042916-1828- B	< 1			
10	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001810	Cooler	2	In hallway adjacent to room A206 Right Low	WT-042916-1827- A	< 1	WT-042916-1827- B	< 1			
11	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001809	Cooler	2	In hallway adjacent to room A206 Left High	WT-042916-1826- A	< 1	WT-042916-1826- B	< 1			
12	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001808	Fountain	2	In room A206 Right	WT-042916-1825- A	< 1	WT-042916-1825- B	< 1			
13	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001807	Classroom	2	In room A206 Right	WT-042916-1824- A	< 1	WT-042916-1824- B	< 1			
14	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001806	Fountain	2	In room 204 Right	WT-042916-1823- A	2.49	WT-042916-1823- B	< 1			
15	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001805	Classroom	2	In room 204 Left	WT-042916-1822- A	< 1	WT-042916-1822- B	< 1			
16	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001804	Fountain	2	In room A202 Right	WT-042916-1821- A	< 1	WT-042916-1821- B	< 1			
17	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001803	Classroom	2	In room A202 Left	WT-042916-1820- A	< 1	WT-042916-1820- B	< 1			
18	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001802	Cooler	2	In hallway across from A204 Right Low	WT-042916-1819- A	< 1	WT-042916-1819- B	< 1			
19	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001801	Cooler	2	In hallway across from A204 Left High	WT-042916-1818- A	< 1	WT-042916-1818- B	< 1			
20	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001800	Fountain	2	In room A201 Left	WT-042916-1817- A	< 1	WT-042916-1817- B	< 1			
21	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001799	Classroom	2	In room A201 Left	WT-042916-1816- A	3.32	WT-042916-1816- B	< 1			
22	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001798	Classroom	2	In room C224 Left	WT-042916-1815- A	< 1	WT-042916-1815- B	< 1			
23	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001797	Fountain	2	In room C224 Right	WT-042916-1814- A	< 1	WT-042916-1814- B	< 1			
24	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001796	Classroom	1	In room C223 Left	WT-042916-1813- A	< 1	WT-042916-1813- B	< 1			
25	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001795	Fountain	2	In room C223 Right	WT-042916-1812- A	< 1	WT-042916-1812- B	< 1			
26	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001794	Fountain	2	In room C122 Right	WT-042916-1811- A	< 1	WT-042916-1811- B	< 1			
27	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001793	Classroom	2	In room C122 Left	WT-042916-1810- A	< 1	WT-042916-1810- B	< 1			



# POWELL LEAD WATER TEST RESULTS

May 12th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
28	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001792	Classroom	2	In room C221 Left	WT-042916-1809- A	< 1	WT-042916-1809- B	< 1			
29	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001791	Fountain	2	In room C221 Right	WT-042916-1808- A	< 1	WT-042916-1808- B	< 1			
30	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001790	Fountain	2	In hallways adjacent to classroom B216	WT-042916-1807- A	< 1	WT-042916-1807- B	< 1			
31	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001789	Fountain	2	In room B216 Right	WT-042916-1806- A	< 1	WT-042916-1806- B	< 1			
32	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001788	Classroom	2	In room B216 Left	WT-042916-1805- A	< 1	WT-042916-1805- B	< 1			
33	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001787	Classroom	2	In room C118 Left	WT-042916-1804- A	< 1	WT-042916-1804- B	< 1			
34	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001786	Fountain	1	In room C118 Right	WT-042916-1803- A	< 1	WT-042916-1803- B	< 1			
35	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001785	Classroom	1	In room C117	WT-042916-1802- A	< 1	WT-042916-1802- B	< 1			
36	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001784	Classroom	1	In room C117 Right	WT-042916-1801- A	< 1	WT-042916-1801- B	< 1			
37	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001783	Fountain	1	In classroom C116 soth wall bubbler Right	WT-042916-1800- A	< 1	WT-042916-1800- B	< 1			
38	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001782	Classroom	1	In class room C116 south wall sink Left	WT-042916-1799- A	< 1	WT-042916-1799- B	< 1			
39	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001781	Fountain	1	In room C115 Right	WT-042916-1798- A	< 1	WT-042916-1798- B	< 1			
40	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001780	Classroom	1	In room C115 Left	WT-042916-1797- A	< 1	WT-042916-1797- B	< 1			
41	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001779	Fountain	1	In room 114 Right	WT-042916-1796- A	< 1	WT-042916-1796- B	< 1			
42	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001778	Classroom	1	In room 114 Left	WT-042916-1795- A	< 1	WT-042916-1795- B	< 1			
43	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001777	Fountain	1	In room C113 Right	WT-042916-1794- A	< 1	WT-042916-1794- B	< 1			
44	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001776	Classroom	1	In room C113 Left	WT-042916-1793- A	< 1	WT-042916-1793- B	< 1			
45	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001775	Fountain	1	In hallway across from main office	WT-042916-1792- A	< 1	WT-042916-1792- B	< 1			
46	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001774	Fountain	1	In room 110 Right	WT-042916-1791- A	< 1	WT-042916-1791- B	< 1			
47	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001773	Classroom	1	In room 110 Left	WT-042916-1790- A	< 1	WT-042916-1790- B	< 1			
48	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001772	Fountain	1	In hallway across from B109	WT-042916-1789- A	< 1	WT-042916-1789- B	< 1			
49	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001771	Fountain	1	In room B107 Right	WT-042916-1788- A	< 1	WT-042916-1788- B	< 1			
50	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001770	Classroom	1	In room B107 Left	WT-042916-1787- A	< 1	WT-042916-1787- B	< 1			
51	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001769	Fountain	1	In classroom A106 Right	WT-042916-1786- A	< 1	WT-042916-1786- B	< 1			
52	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001768	Classroom	1	In classroom A106 Left	WT-042916-1785- A	< 1	WT-042916-1785- B	< 1			
53	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001767	Classroom	1	In classroom A104 Left	WT-042916-1784- A	< 1	WT-042916-1784- B	< 1			
54	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001766	Fountain	1	In classroom A104 Right	WT-042916-1783- A	< 1	WT-042916-1783- B	< 1			



# POWELL LEAD WATER TEST RESULTS

May 12th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
55	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001765	Classroom	1	In classroom A102 Left	WT-042916-1782- A	< 1	WT-042916-1782- B	< 1			
56	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001764	Fountain	1	In classroom A102 Right	WT-042916-1781- A	< 1	WT-042916-1781- B	< 1			
57	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001763	Fountain	1	In room A101 Right	WT-042916-1780- A	< 1	WT-042916-1780- B	< 1			
58	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001762	Classroom	1	In room A101 Left	WT-042916-1779- A	< 1	WT-042916-1779- B	< 1			
59	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001761	Fountain	1	In hallway across from A105 Right Low	WT-042916-1778- A	< 1	WT-042916-1778- B	< 1			
60	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001760	Fountain	1	In hallway across from room A105 Left High	WT-042916-1777- A	< 1	WT-042916-1777- B	< 1			
61	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001759	Fountain	1	In room 105 Right	WT-042916-1776- A	< 1	WT-042916-1776- B	< 1			
62	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001758	Classroom	1	In room 105 Left	WT-042916-1775- A	< 1	WT-042916-1775- B	< 1			
63	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001757	Fountain	1	In hallway adjacent to room 105 Right Low	WT-042916-1774- A	< 1	WT-042916-1774- B	< 1			
64	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001756	Fountain	1	In hallway adjacent to room 105 Left High	WT-042916-1773- A	< 1	WT-042916-1773- B	< 1			
65	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001755	Fountain	1	In kindergarten room 108 Right	WT-042916-1772- A	< 1	WT-042916-1772- B	< 1			
66	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001754	Classroom	1	In kindergarten room 108 Left	WT-042916-1771- A	< 1	WT-042916-1771- B	< 1			
67	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001753	Health Suite	1	In health suite # b109	WT-042916-1770- A	< 1	WT-042916-1770- B	< 1			
68	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001752	Cooler	1	In multi-purpose room	WT-042916-1769- A	< 1	WT-042916-1769- B	< 1			
69	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001751	Kitchen	1	In kitchen Low	WT-042916-1768- A	< 1	WT-042916-1768- B	< 1			
70	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001750	Kitchen	1	In kitchen wall (spray nozzle) High	WT-042916-1767- A	< 1	WT-042916-1767- B	< 1			
71	POWELL ELEMENTARY SCHOOL	5/3/2016	WS- 001749	Utility	Basement	In boiler room before water heater net east wall water entry point (water source)	WT-042916-1766- A	10.7	WT-042916-1766- B	7.81			

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.