



Powell ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001752	5/31/2017	5/31/2018	1	Cooler	In multi-purpose room	WF-52017-001752	11/8/2017	FT-FY18--52017-001752-A	<1	FT-FY18--52017-001752-B	<1
WS- 001754	10/26/2017	10/26/2018	1	Combo Faucet	In classroom B108	WF-102017-001754	11/8/2017	FT-FY18-102017-001754-A	<1	FT-FY18-102017-001754-B	<1
WS- 001757	5/31/2017	5/31/2018	1	Cooler	In hallway adjacent to room A105	WF-52017-001757	11/8/2017	FT-FY18--52017-001757-A	<1	FT-FY18--52017-001757-B	<1
WS- 001760	5/31/2017	5/31/2018	1	Cooler	In hallway across from room A103	WF-52017-001760	11/8/2017	FT-FY18--52017-001760-A	<1	FT-FY18--52017-001760-B	<1
WS- 001764	5/31/2017	5/31/2018	1	Combo Fountain	In classroom A102	WF-52017-001764	11/8/2017	FT-FY18--52017-001764-A	<1	FT-FY18--52017-001764-B	<1
WS- 001767	10/26/2017	10/26/2018	1	Combo Faucet	In classroom A104	WF-102017-001767	11/8/2017	FT-FY18-102017-001767-A	<1	FT-FY18-102017-001767-B	<1
WS- 001770	10/26/2017	10/26/2018	1	Combo Faucet	In classroom B107	WF-102017-001770	11/8/2017	FT-FY18-102017-001770-A	<1	FT-FY18-102017-001770-B	<1
WS- 001772	5/31/2017	5/31/2018	1	Cooler	In hallway across from B109	WF-52017-001772	11/8/2017	FT-FY18--52017-001772-A	<1	FT-FY18--52017-001772-B	<1
WS- 001773	10/26/2017	10/26/2018	1	Combo Faucet	In classroom B110	WF-102017-001773	11/8/2017	FT-FY18-102017-001773-A	<1	FT-FY18-102017-001773-B	<1
WS- 001777	5/31/2017	5/31/2018	1	Combo Fountain	In classroom C113	WF-52017-001777	11/8/2017	FT-FY18--52017-001777-A	<1	FT-FY18--52017-001777-B	<1
WS- 001781	5/31/2017	5/31/2018	1	Combo Fountain	In classroom C115	WF-52017-001781	11/8/2017	FT-FY18--52017-001781-A	<1	FT-FY18--52017-001781-B	<1
WS- 001784	5/31/2017	5/31/2018	1	Combo Fountain	In classroom C117	WF-52017-001784	11/8/2017	FT-FY18--52017-001784-A	<1	FT-FY18--52017-001784-B	<1
WS- 001785	10/26/2017	10/26/2018	1	Combo Faucet	In classroom C117	WF-102017-001785	11/8/2017	FT-FY18-102017-001785-A	<1	FT-FY18-102017-001785-B	<1
WS- 001791	5/31/2017	5/31/2018	2	Combo Fountain	In classroom C221	WF-52017-001791	11/8/2017	FT-FY18--52017-001791-A	<1	FT-FY18--52017-001791-B	<1
WS- 001792	10/26/2017	10/26/2018	2	Combo Faucet	In classroom C221	WF-102017-001792	11/8/2017	FT-FY18-102017-001792-A	<1	FT-FY18-102017-001792-B	<1
WS- 001795	5/31/2017	5/31/2018	2	Combo Fountain	In classroom C223	WF-52017-001795	11/8/2017	FT-FY18--52017-001795-A	<1	FT-FY18--52017-001795-B	<1
WS- 001799	10/26/2017	10/26/2018	2	Combo Faucet	In classroom A201	WF-102017-001799	11/8/2017	FT-FY18-102017-001799-A	1.4	FT-FY18-102017-001799-B	<1
WS- 001800	5/31/2017	5/31/2018	2	Combo Fountain	In classroom A201	WF-52017-001800	11/8/2017	FT-FY18--52017-001800-A	<1	FT-FY18--52017-001800-B	<1
WS- 001806	5/31/2017	5/31/2018	2	Combo Fountain	In classroom A204	WF-52017-001806	11/8/2017	FT-FY18--52017-001806-A	<1	FT-FY18--52017-001806-B	<1
WS- 001810	5/31/2017	5/31/2018	2	Cooler	In hallway adjacent to room A206	WF-52017-001810	11/8/2017	FT-FY18--52017-001810-A	<1	FT-FY18--52017-001810-B	<1
WS- 001812	5/31/2017	5/31/2018	2	Combo Fountain	In classroom A207	WF-52017-001812	11/8/2017	FT-FY18--52017-001812-A	<1	FT-FY18--52017-001812-B	<1
WS- 001819	5/31/2017	5/31/2018	2	Combo Fountain	In classroom B212	WF-52017-001819	11/8/2017	FT-FY18--52017-001819-A	<1	FT-FY18--52017-001819-B	<1
WS- 001820	5/31/2017	5/31/2018	2	Combo Fountain	In classroom 229D	WF-52017-001820	11/8/2017	FT-FY18--52017-001820-A	<1	FT-FY18--52017-001820-B	<1
WS- 002446	5/31/2017	5/31/2018	2	Combo Fountain	In break room B213	WF-52017-002446	11/8/2017	FT-FY18--52017-002446-A	<1	FT-FY18--52017-002446-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 001824	Ground Floor	Food Prep Sink	In kitchen second sink clockwise from cafeteria entrance	11/8/2017	FT-FY18-112017-001824-A	<1	FT-FY18-112017-001824-B	<1		