



Powell ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001752	4/25/2018	4/25/2019	1	Cooler	In multi-purpose room	WF-04252018-001752	11/19/2018	FT-FY19-112018-001752-A	< 1	FT-FY19-112018-001752-B	< 1
WS- 001753	4/25/2018	4/25/2019	1	Health Suite	In health suite B109	WF-04252018-001753	11/19/2018	FT-FY19-112018-001753-A	< 1	FT-FY19-112018-001753-B	< 1
WS- 001754	10/1/2018	10/1/2019	1	Combo Faucet	In classroom B108	Left WF-10012018-001754	11/19/2018	FT-FY19-112018-001754-A	< 1	FT-FY19-112018-001754-B	< 1
WS- 001755	4/25/2018	4/25/2019	1	Combo Fountain	In classroom B108	Right WF-04252018-001755	11/19/2018	FT-FY19-112018-001755-A	< 1	FT-FY19-112018-001755-B	< 1
WS- 001756	4/25/2018	4/25/2019	1	Cooler	In hallway adjacent to room A105	High Left WF-04252018-001756	11/19/2018	FT-FY19-112018-001756-A	< 1	FT-FY19-112018-001756-B	< 1
WS- 001757	4/25/2018	4/25/2019	1	Cooler	In hallway adjacent to room A105	Low Right WF-04252018-001757	11/19/2018	FT-FY19-112018-001757-A	< 1	FT-FY19-112018-001757-B	< 1
WS- 001758	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A105	Left WF-10012018-001758	11/19/2018	FT-FY19-112018-001758-A	< 1	FT-FY19-112018-001758-B	< 1
WS- 001759	4/25/2018	4/25/2019	1	Combo Fountain	In classroom A105	Right WF-04252018-001759	11/19/2018	FT-FY19-112018-001759-A	< 1	FT-FY19-112018-001759-B	< 1
WS- 001760	4/25/2018	4/25/2019	1	Cooler	In hallway across from room A103	High Left WF-04252018-001760	11/19/2018	FT-FY19-112018-001760-A	< 1	FT-FY19-112018-001760-B	< 1
WS- 001761	4/25/2018	4/25/2019	1	Cooler	In hallway across from room A103	Low Right WF-04252018-001761	11/19/2018	FT-FY19-112018-001761-A	< 1	FT-FY19-112018-001761-B	< 1
WS- 001762	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A101	Left WF-10012018-001762	11/19/2018	FT-FY19-112018-001762-A	< 1	FT-FY19-112018-001762-B	< 1
WS- 001763	4/25/2018	4/25/2019	1	Combo Fountain	In classroom A101	Right WF-04252018-001763	11/19/2018	FT-FY19-112018-001763-A	< 1	FT-FY19-112018-001763-B	< 1
WS- 001764	4/25/2018	4/25/2019	1	Combo Fountain	In classroom A102	Right WF-04252018-001764	11/19/2018	FT-FY19-112018-001764-A	< 1	FT-FY19-112018-001764-B	< 1
WS- 001765	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A102	Left WF-10012018-001765	11/19/2018	FT-FY19-112018-001765-A	< 1	FT-FY19-112018-001765-B	< 1
WS- 001766	4/25/2018	4/25/2019	1	Combo Fountain	In classroom A104	Right WF-04252018-001766	11/19/2018	FT-FY19-112018-001766-A	< 1	FT-FY19-112018-001766-B	< 1
WS- 001767	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A104	Left WF-10012018-001767	11/19/2018	FT-FY19-112018-001767-A	< 1	FT-FY19-112018-001767-B	< 1
WS- 001768	10/1/2018	10/1/2019	1	Combo Faucet	In classroom A106	Left WF-10012018-001768	11/19/2018	FT-FY19-112018-001768-A	< 1	FT-FY19-112018-001768-B	< 1
WS- 001769	4/25/2018	4/25/2019	1	Combo Fountain	In classroom A106	Right WF-04252018-001769	11/19/2018	FT-FY19-112018-001769-A	< 1	FT-FY19-112018-001769-B	< 1
WS- 001770	10/1/2018	10/1/2019	1	Combo Faucet	In classroom B107	Left WF-10012018-001770	11/19/2018	FT-FY19-112018-001770-A	< 1	FT-FY19-112018-001770-B	< 1
WS- 001771	4/25/2018	4/25/2019	1	Combo Fountain	In classroom B107	Right WF-04252018-001771	11/19/2018	FT-FY19-112018-001771-A	< 1	FT-FY19-112018-001771-B	< 1
WS- 001772	4/25/2018	4/25/2019	1	Cooler	In hallway across from B109	WF-04252018-001772	11/19/2018	FT-FY19-112018-001772-A	< 1	FT-FY19-112018-001772-B	< 1
WS- 001773	10/1/2018	10/1/2019	1	Combo Faucet	In classroom B110	Left WF-10012018-001773	11/19/2018	FT-FY19-112018-001773-A	< 1	FT-FY19-112018-001773-B	< 1
WS- 001774	4/25/2018	4/25/2019	1	Combo Fountain	In classroom B110	Right WF-04252018-001774	11/19/2018	FT-FY19-112018-001774-A	< 1	FT-FY19-112018-001774-B	< 1
WS- 001775	4/25/2018	4/25/2019	1	Cooler	In hallway across from main office	WF-04252018-001775	11/19/2018	FT-FY19-112018-001775-A	< 1	FT-FY19-112018-001775-B	< 1
WS- 001776	10/1/2018	10/1/2019	1	Combo Faucet	In classroom C113	Left WF-10012018-001776	11/19/2018	FT-FY19-112018-001776-A	< 1	FT-FY19-112018-001776-B	< 1
WS- 001777	4/25/2018	4/25/2019	1	Combo Fountain	In classroom C113	Right WF-04252018-001777	11/19/2018	FT-FY19-112018-001777-A	< 1	FT-FY19-112018-001777-B	< 1
WS- 001778	10/1/2018	10/1/2019	1	Combo Faucet	In classroom C114	Left WF-10012018-001778	11/19/2018	FT-FY19-112018-001778-A	< 1	FT-FY19-112018-001778-B	< 1
WS- 001779	4/25/2018	4/25/2019	1	Combo Fountain	In classroom C114	Right WF-04252018-001779	11/19/2018	FT-FY19-112018-001779-A	< 1	FT-FY19-112018-001779-B	< 1
WS- 001780	10/1/2018	10/1/2019	1	Combo Faucet	In classroom C115	Left WF-10012018-001780	11/19/2018	FT-FY19-112018-001780-A	< 1	FT-FY19-112018-001780-B	< 1
WS- 001781	4/25/2018	4/25/2019	1	Combo Fountain	In classroom C115	Right WF-04252018-001781	11/19/2018	FT-FY19-112018-001781-A	< 1	FT-FY19-112018-001781-B	< 1
WS- 001782	10/1/2018	10/1/2019	1	Combo Faucet	In classroom C116	Left WF-10012018-001782	11/19/2018	FT-FY19-112018-001782-A	< 1	FT-FY19-112018-001782-B	< 1
WS- 001783	4/25/2018	4/25/2019	1	Combo Fountain	In classroom C116	Right WF-04252018-001783	11/19/2018	FT-FY19-112018-001783-A	< 1	FT-FY19-112018-001783-B	< 1
WS- 001784	4/25/2018	4/25/2019	1	Combo Fountain	In classroom C117	Right WF-04252018-001784	11/19/2018	FT-FY19-112018-001784-A	< 1	FT-FY19-112018-001784-B	< 1
WS- 001785	10/1/2018	10/1/2019	1	Combo Faucet	In classroom C117	WF-10012018-001785	11/19/2018	FT-FY19-112018-001785-A	< 1	FT-FY19-112018-001785-B	< 1
WS- 001786	4/25/2018	4/25/2019	1	Combo Fountain	In classroom C118	Right WF-04252018-001786	11/19/2018	FT-FY19-112018-001786-A	< 1	FT-FY19-112018-001786-B	< 1

WS-001787	10/1/2018	10/1/2019	1	Combo Faucet	In classroom C118	Left	WF-10012018-001787	11/19/2018	FT-FY19-112018-001787-A	< 1	FT-FY19-112018-001787-B	< 1
WS-001788	4/25/2018	4/25/2019	2	Break Room	In breakroom B216	Left	WF-04252018-001788	11/19/2018	FT-FY19-112018-001788-A	< 1	FT-FY19-112018-001788-B	< 1
WS-001789	4/25/2018	4/25/2019	2	Combo Fountain	In classroom B216	Right	WF-04252018-001789	11/19/2018	FT-FY19-112018-001789-A	< 1	FT-FY19-112018-001789-B	< 1
WS-001790	4/25/2018	4/25/2019	2	Cooler	In hallway adjacent to room B216		WF-04252018-001790	11/19/2018	FT-FY19-112018-001790-A	< 1	FT-FY19-112018-001790-B	< 1
WS-001791	4/25/2018	4/25/2019	2	Combo Fountain	In classroom C221	Right	WF-04252018-001791	11/19/2018	FT-FY19-112018-001791-A	< 1	FT-FY19-112018-001791-B	< 1
WS-001792	10/1/2018	10/1/2019	2	Combo Faucet	In classroom C221	Left	WF-10012018-001792	11/19/2018	FT-FY19-112018-001792-A	< 1	FT-FY19-112018-001792-B	< 1
WS-001793	10/1/2018	10/1/2019	2	Combo Faucet	In classroom C222	Left	WF-10012018-001793	11/19/2018	FT-FY19-112018-001793-A	< 1	FT-FY19-112018-001793-B	< 1
WS-001794	4/25/2018	4/25/2019	2	Combo Fountain	In classroom C222	Right	WF-04252018-001794	11/19/2018	FT-FY19-112018-001794-A	< 1	FT-FY19-112018-001794-B	< 1
WS-001795	4/25/2018	4/25/2019	2	Combo Fountain	In classroom C223	Right	WF-04252018-001795	11/19/2018	FT-FY19-112018-001795-A	< 1	FT-FY19-112018-001795-B	< 1
WS-001796	10/1/2018	10/1/2019	2	Combo Faucet	In classroom C223	Left	WF-10012018-001796	11/19/2018	FT-FY19-112018-001796-A	< 1	FT-FY19-112018-001796-B	< 1
WS-001797	4/25/2018	4/25/2019	2	Combo Fountain	In classroom C224	Right	WF-04252018-001797	11/19/2018	FT-FY19-112018-001797-A	< 1	FT-FY19-112018-001797-B	< 1
WS-001798	10/1/2018	10/1/2019	2	Combo Faucet	In classroom C224	Left	WF-10012018-001798	11/19/2018	FT-FY19-112018-001798-A	< 1	FT-FY19-112018-001798-B	< 1
WS-001799	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A201	Left	WF-10012018-001799	11/19/2018	FT-FY19-112018-001799-A	< 1	FT-FY19-112018-001799-B	< 1
WS-001800	4/25/2018	4/25/2019	2	Combo Fountain	In classroom A201	Left	WF-04252018-001800	11/19/2018	FT-FY19-112018-001800-A	< 1	FT-FY19-112018-001800-B	< 1
WS-001801	4/25/2018	4/25/2019	2	Cooler	In hallway across from room A204	High Left	WF-04252018-001801	11/19/2018	FT-FY19-112018-001801-A	< 1	FT-FY19-112018-001801-B	< 1
WS-001802	4/25/2018	4/25/2019	2	Cooler	In hallway across from room A204	Low Right	WF-04252018-001802	11/19/2018	FT-FY19-112018-001802-A	< 1	FT-FY19-112018-001802-B	< 1
WS-001803	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A202	Left	WF-10012018-001803	11/19/2018	FT-FY19-112018-001803-A	< 1	FT-FY19-112018-001803-B	< 1
WS-001804	4/25/2018	4/25/2019	2	Combo Fountain	In classroom A202	Right	WF-04252018-001804	11/19/2018	FT-FY19-112018-001804-A	< 1	FT-FY19-112018-001804-B	< 1
WS-001805	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A204	Left	WF-10012018-001805	11/19/2018	FT-FY19-112018-001805-A	< 1	FT-FY19-112018-001805-B	< 1
WS-001806	4/25/2018	4/25/2019	2	Combo Fountain	In classroom A204	Right	WF-04252018-001806	11/19/2018	FT-FY19-112018-001806-A	< 1	FT-FY19-112018-001806-B	< 1
WS-001807	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A206	Right	WF-10012018-001807	11/19/2018	FT-FY19-112018-001807-A	< 1	FT-FY19-112018-001807-B	< 1
WS-001808	4/25/2018	4/25/2019	2	Combo Fountain	In classroom A206	Right	WF-04252018-001808	11/19/2018	FT-FY19-112018-001808-A	< 1	FT-FY19-112018-001808-B	< 1
WS-001809	4/25/2018	4/25/2019	2	Cooler	In hallway adjacent to room A206	High Left	WF-04252018-001809	11/19/2018	FT-FY19-112018-001809-A	< 1	FT-FY19-112018-001809-B	< 1
WS-001810	4/25/2018	4/25/2019	2	Cooler	In hallway adjacent to room A206	Low Right	WF-04252018-001810	11/19/2018	FT-FY19-112018-001810-A	< 1	FT-FY19-112018-001810-B	< 1
WS-001811	10/1/2018	10/1/2019	2	Combo Faucet	In classroom A207	Left	WF-10012018-001811	11/19/2018	FT-FY19-112018-001811-A	< 1	FT-FY19-112018-001811-B	< 1
WS-001812	4/25/2018	4/25/2019	2	Combo Fountain	In classroom A207	Right	WF-04252018-001812	11/19/2018	FT-FY19-112018-001812-A	< 1	FT-FY19-112018-001812-B	< 1
WS-001813	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B208	Left	WF-10012018-001813	11/19/2018	FT-FY19-112018-001813-A	< 1	FT-FY19-112018-001813-B	< 1
WS-001814	4/25/2018	4/25/2019	2	Combo Fountain	In classroom B208	Right	WF-04252018-001814	11/19/2018	FT-FY19-112018-001814-A	< 1	FT-FY19-112018-001814-B	< 1
WS-001815	4/25/2018	4/25/2019	2	Cooler	In hallway adjacent to room 210		WF-04252018-001815	11/19/2018	FT-FY19-112018-001815-A	< 1	FT-FY19-112018-001815-B	< 1
WS-001816	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B211	Left	WF-10012018-001816	11/19/2018	FT-FY19-112018-001816-A	< 1	FT-FY19-112018-001816-B	< 1
WS-001817	4/25/2018	4/25/2019	2	Combo Fountain	In classroom B211	Right	WF-04252018-001817	11/19/2018	FT-FY19-112018-001817-A	< 1	FT-FY19-112018-001817-B	< 1
WS-001818	10/1/2018	10/1/2019	2	Combo Faucet	In classroom B212	Left	WF-10012018-001818	11/19/2018	FT-FY19-112018-001818-A	< 1	FT-FY19-112018-001818-B	< 1
WS-001819	4/25/2018	4/25/2019	2	Combo Fountain	In classroom B212	Right	WF-04252018-001819	11/19/2018	FT-FY19-112018-001819-A	< 1	FT-FY19-112018-001819-B	< 1
WS-001820	4/25/2018	4/25/2019	2	Combo Fountain	In classroom 229D		WF-04252018-001820	11/19/2018	FT-FY19-112018-001820-A	< 1	FT-FY19-112018-001820-B	< 1
WS-002445	4/25/2018	4/25/2019	2	Break Room	In break room B213	Left	WF-04252018-002445	11/19/2018	FT-FY19-112018-002445-A	< 1	FT-FY19-112018-002445-B	< 1
WS-002446	4/25/2018	4/25/2019	2	Combo Fountain	In break room B213	Right	WF-04252018-002446	11/19/2018	FT-FY19-112018-002446-A	< 1	FT-FY19-112018-002446-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001824	Ground Floor	Food Prep Sink	In kitchen second sink clockwise from cafeteria entrance	11/19/2018	FT-FY19-112018-001824-A	< 1	FT-FY19-112018-001824-B	< 1