



RANDALL HIGHLANDS ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004142	8/8/2016	2	Cooler	In hallway adjacent to 2214 High Left	FT-72016-004142-A	< 1	FT-72016-004142-B	< 1
2	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004143	8/8/2016	2	Cooler	In hallway adjacent to 2214 Low Right	FT-72016-004143-A	< 1	FT-72016-004143-B	< 1
3	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004145	8/8/2016	2	Cooler	In classroom 2201 connecting hallway High Left	FT-72016-004145-A	< 1	FT-72016-004145-B	< 1
4	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004146	8/8/2016	2	Cooler	In classroom 2201 connecting hallway Low Right	FT-72016-004146-A	< 1	FT-72016-004146-B	< 1
5	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004150	8/8/2016	1	Cooler	In classroom 2109 connecting hallway High Left	FT-72016-004150-A	< 1	FT-72016-004150-B	< 1
6	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004151	8/8/2016	1	Cooler	In classroom 2109 connecting hallway Low Right	FT-72016-004151-A	< 1	FT-72016-004151-B	< 1
7	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004153	8/8/2016	1	Cooler	In hallway adjacent to room 2114 High Left	FT-72016-004153-A	< 1	FT-72016-004153-B	< 1
8	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004154	8/8/2016	1	Cooler	In hallway adjacent to room 2114 Low Right	FT-72016-004154-A	< 1	FT-72016-004154-B	< 1
9	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004157	8/8/2016	1	Cooler	In classroom 2104 connecting hallway High Left	FT-72016-004157-A	< 1	FT-72016-004157-B	< 1
10	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004158	8/8/2016	1	Cooler	In classroom 2104 connecting hallway Low Right	FT-72016-004158-A	< 1	FT-72016-004158-B	< 1
11	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004161	8/8/2016	1	Cooler	In classroom 2101 connecting hallway High Left	FT-72016-004161-A	< 1	FT-72016-004161-B	< 1
12	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004162	8/8/2016	1	Cooler	In classroom 2101 connecting hallway High Left	FT-72016-004162-A	< 1	FT-72016-004162-B	< 1
13	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004175	8/8/2016	2	Cooler	In classroom 2209 connecting hallway High Left	FT-72016-004175-A	< 1	FT-72016-004175-B	< 1
14	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004176	8/8/2016	2	Cooler	In classroom 2209 connecting hallway Low Right	FT-72016-004176-A	< 1	FT-72016-004176-B	< 1
15	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004180	8/8/2016	2	Cooler	In classroom 2204 connecting hallway High Left	FT-72016-004180-A	< 1	FT-72016-004180-B	< 1
16	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004181	8/8/2016	2	Cooler	In classroom 2204 connecting hallway Low Right	FT-72016-004181-A	< 1	FT-72016-004181-B	< 1
17	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004184	8/8/2016	Ground Floor	Cooler	In classroom 2009 connecting hallway High Left	FT-72016-004184-A	< 1	FT-72016-004184-B	< 1
18	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004185	8/8/2016	Ground Floor	Cooler	In classroom 2009 connecting hallway Low Right	FT-72016-004185-A	< 1	FT-72016-004185-B	< 1
19	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004187	8/8/2016	Ground Floor	Health Suite	In health suite 2007	FT-72016-004187-A	< 1	FT-72016-004187-B	< 1
20	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004189	8/8/2016	Ground Floor	Cooler	In classroom 2004 connecting hallway High Left	FT-72016-004189-A	< 1	FT-72016-004189-B	< 1
21	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004190	8/8/2016	Ground Floor	Cooler	In classroom 2004 connecting hallway Low Right	FT-72016-004190-A	< 1	FT-72016-004190-B	< 1
22	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004193	8/8/2016	Ground Floor	Cooler	In classroom 2001 connecting hallway High Left	FT-72016-004193-A	< 1	FT-72016-004193-B	< 1
23	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004194	8/8/2016	Ground Floor	Cooler	In classroom 2001 connecting hallway Low Right	FT-72016-004194-A	< 1	FT-72016-004194-B	< 1
24	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004196	8/8/2016	Ground Floor	Cooler	In hallway adjacent to room 2014 High Left	FT-72016-004196-A	< 1	FT-72016-004196-B	< 1

25	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004197	8/8/2016	Ground Floor	Cooler	In hallway adjacent to room 2014	Low Right	FT-72016-004197-A	< 1	FT-72016-004197-B	< 1
26	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004198	8/8/2016	Basement	Cooler	In hallway adjacent to room 2B14	High Left	FT-72016-004198-A	< 1	FT-72016-004198-B	< 1
27	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004199	8/8/2016	Basement	Cooler	In hallway adjacent to room 2B14	Low Right	FT-72016-004199-A	< 1	FT-72016-004199-B	< 1
28	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004202	8/8/2016	Basement	Cooler	In classroom 2B09 connecting hallway	High Left	FT-72016-004202-A	< 1	FT-72016-004202-B	< 1
29	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004203	8/8/2016	Basement	Cooler	In classroom 2B09 connecting hallway	Low Right	FT-72016-004203-A	< 1	FT-72016-004203-B	< 1
30	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004205	8/8/2016	Basement	Cooler	In classroom 2B04 connecting hallway	High Left	FT-72016-004205-A	< 1	FT-72016-004205-B	< 1
31	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004206	8/8/2016	Basement	Cooler	In classroom 2B04 connecting hallway	Low Right	FT-72016-004206-A	< 1	FT-72016-004206-B	< 1
32	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004210	8/8/2016	Basement	Cooler	In classroom 2B01 connecting hallway	High Left	FT-72016-004210-A	< 1	FT-72016-004210-B	< 1
33	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004211	8/8/2016	Basement	Cooler	In classroom 2B01 connecting hallway	Low Right	FT-72016-004211-A	< 1	FT-72016-004211-B	< 1
34	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004213	8/8/2016	Ground Floor	Food Prep Sink	In kitchen room 2038	Left	FT-72016-004213-A	< 1	FT-72016-004213-B	< 1
35	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004214	8/8/2016	Ground Floor	Food Prep Sink	In kitchen 2038	Right	FT-72016-004214-A	< 1	FT-72016-004214-B	< 1
36	RANDALL HIGHLANDS ELEMENTARY SCHOOL	WS- 004215	8/8/2016	Ground Floor	Cooler	In hallway adjacent to 3001		FT-72016-004215-A	< 1	FT-72016-004215-B	< 1