



RANDALL HIGHLANDS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004215	Cooler	Ground Floor	In hallway adjacent to 3001	WT-042916-4232- A	< 2	WT-042916-4232- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004214	Kitchen	Ground Floor	In kitchen 2038 Right	WT-042916-4231- A	< 2	WT-042916-4231- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004213	Kitchen	Ground Floor	In kitchen 2038 Left	WT-042916-4230- A	< 2	WT-042916-4230- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004212	Classroom	Basement	In classroom 2B01	WT-042916-4229- A	< 2	WT-042916-4229- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004211	Fountain	Basement	In room 2B01 connecting hallway Right Low	WT-042916-4228- A	< 2	WT-042916-4228- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004210	Fountain	Basement	In room 2B01 connecting hallway Left High	WT-042916-4227- A	< 2	WT-042916-4227- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004209	Classroom	Basement	In classroom 2B03	WT-042916-4226- A	5.9	WT-042916-4226- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004207	Classroom	Basement	In classroom 2B04	WT-042916-4224- A	< 2	WT-042916-4224- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004206	Fountain	Basement	In classroom 2B06 connecting hallway Right Low	WT-042916-4223- A	< 2	WT-042916-4223- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004205	Fountain	Basement	In classroom 2B04 connecting hallway Left High	WT-042916-4222- A	< 2	WT-042916-4222- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004204	Classroom	Basement	In classroom 2B09	WT-042916-4221- A	< 2	WT-042916-4221- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004203	Fountain	Basement	In classroom 2B09 connecting hallway Right Low	WT-042916-4220- A	< 2	WT-042916-4220- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004202	Fountain	Basement	In classroom 2B09 connecting hallway Left High	WT-042916-4219- A	< 2	WT-042916-4219- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004201	Classroom	Basement	In classroom 2B11	WT-042916-4218- A	< 2	WT-042916-4218- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004200	Classroom	Basement	In room 2B07	WT-042916-4217- A	< 2	WT-042916-4217- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004199	Cooler	Basement	In hallway adjacent to room 2B14 Right Low	WT-042916-4216- A	< 2	WT-042916-4216- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004198	Cooler	Basement	In hallway adjacent to 2B13 Left High	WT-042916-4215- A	< 2	WT-042916-4215- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004197	Cooler	Ground Floor	In hallway adjacent to 2014 Right Low	WT-042916-4214- A	< 2	WT-042916-4214- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004196	Cooler	Ground Floor	In hallway adjacent to 2014 Left High	WT-042916-4213- A	< 2	WT-042916-4213- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004195	Classroom	Ground Floor	In classroom 2001	WT-042916-4212- A	< 2	WT-042916-4212- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004194	Fountain	Ground Floor	In room 2001 connecting hallway Right Low	WT-042916-4211- A	< 2	WT-042916-4211- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004193	Fountain	Ground Floor	In room 2001 connecting hallway Left High	WT-042916-4210- A	< 2	WT-042916-4210- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004192	Classroom	Ground Floor	In classroom 2003	WT-042916-4209- A	< 2	WT-042916-4209- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004191	Classroom	Ground Floor	In classroom 2004	WT-042916-4208- A	< 2	WT-042916-4208- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004190	Fountain	Ground Floor	In room 2004 connecting hallway Right Low	WT-042916-4207- A	< 2	WT-042916-4207- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004189	Fountain	Ground Floor	In room 2004 connecting hallway Left High	WT-042916-4206- A	< 2	WT-042916-4206- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004188	Classroom	Ground Floor	In classroom 2006	WT-042916-4205- A	< 2	WT-042916-4205- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004187	Health Suite	Ground Floor	In health suite 2007	WT-042916-4204- A	< 2	WT-042916-4204- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004186	Classroom	Ground Floor	In classroom 2009	WT-042916-4203- A	< 2	WT-042916-4203- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004185	Fountain	Ground Floor	In room 2009 connecting hallway Right Low	WT-042916-4202- A	< 2	WT-042916-4202- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004184	Fountain	Ground Floor	In room 2009 connecting hallway Left High	WT-042916-4201- A	< 2	WT-042916-4201- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004183	Classroom	Ground Floor	In classroom 2011	WT-042916-4200- A	< 2	WT-042916-4200- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004182	Classroom	2	In classroom 2204	WT-042916-4199- A	< 2	WT-042916-4199- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004181	Fountain	2	In room 2204 connecting hallway Right Low	WT-042916-4198- A	< 2	WT-042916-4198- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS-004180	Fountain	2	In room 2204 connecting hallway Left High	WT-042916-4197- A	< 2	WT-042916-4197- B	< 2				



RANDALL HIGHLANDS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004179	Classroom	2	In classroom 2204	WT-042916-4196- A	< 2	WT-042916-4196- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004178	Classroom	2	In room 2207	WT-042916-4195- A	< 2	WT-042916-4195- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004177	Classroom	2	In classroom 2209	WT-042916-4194- A	< 2	WT-042916-4194- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004176	Fountain	2	In classroom 2209 connecting hallway	Right Low	WT-042916-4193- A	< 2	WT-042916-4193- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004175	Fountain	2	In classroom 2209 connecting hallway	Left High	WT-042916-4192- A	< 2	WT-042916-4192- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004174	Classroom	2	In classroom 2211		WT-042916-4191- A	< 2	WT-042916-4191- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004173	Classroom	1	In room 2114 last from left		WT-042916-4190- A	< 2	WT-042916-4190- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004172	Classroom	1	In room 2114 forth from left	Right	WT-042916-4189- A	3.5	WT-042916-4189- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004171	Classroom	1	In room 2114 third from left		WT-042916-4188- A	3.1	WT-042916-4188- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004170	Classroom	1	In room 2114 second from left	Left	WT-042916-4187- A	2.3	WT-042916-4187- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004169	Classroom	1	In room 2114 first from left	Left	WT-042916-4186- A	18	WT-042916-4186- B	4.6	Filter will be installed and then retested		
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004168	Classroom	1	In art room 2117 first from left	Left	WT-042916-4185- A	4.7	WT-042916-4185- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004167	Classroom	1	In art room 2117 second from left		WT-042916-4184- A	< 2	WT-042916-4184- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004166	Classroom	1	In art room 2117 last from left	Right	WT-042916-4183- A	9.2	WT-042916-4183- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004165	Classroom	1	In art room 2117 forth from left	Mid	WT-042916-4182- A	7	WT-042916-4182- B	4.4			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004164	Classroom	1	In art room 2117 third from left	Left	WT-042916-4181- A	< 2	WT-042916-4181- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004163	Classroom	1	In classroom 2101		WT-042916-4180- A	3.1	WT-042916-4180- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004162	Fountain	1	In classroom 2101 connecting hallway	Left High	WT-042916-4179- A	< 2	WT-042916-4179- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004161	Fountain	1	In classroom 2101 connecting hallway	Left High	WT-042916-4178- A	< 2	WT-042916-4178- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004160	Classroom	1	In classroom 2103		WT-042916-4177- A	< 2	WT-042916-4177- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004159	Classroom	1	In classroom 2104		WT-042916-4176- A	< 2	WT-042916-4176- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004158	Fountain	1	In classroom 2104 connecting hallway	Right Low	WT-042916-4175- A	< 2	WT-042916-4175- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004157	Cooler	1	In classroom 2104 connecting hallway	Left High	WT-042916-4174- A	< 2	WT-042916-4174- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004156	Classroom	1	In classroom 2106		WT-042916-4173- A	< 2	WT-042916-4173- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004155	Classroom	2	In room 2107		WT-042916-4172- A	< 2	WT-042916-4172- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004154	Cooler	1	In hallway adjacent to room 2114	Right Low	WT-042916-4171- A	< 2	WT-042916-4171- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004153	Cooler	1	In hallway adjacent to room 2113	Left High	WT-042916-4170- A	< 2	WT-042916-4170- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004152	Classroom	1	In classroom 2109		WT-042916-4169- A	< 2	WT-042916-4169- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004151	Fountain	1	In classroom 2109 connecting hallway	Right Low	WT-042916-4168- A	< 2	WT-042916-4168- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004150	Fountain	1	In classroom 2109 connecting hallway	Left High	WT-042916-4167- A	< 2	WT-042916-4167- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004149	Classroom	1	In classroom 2111		WT-042916-4166- A	< 2	WT-042916-4166- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004148	Classroom	2	In speech room 2217		WT-042916-4165- A	< 2	WT-042916-4165- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004147	Classroom	2	In classroom 2003		WT-042916-4164- A	< 2	WT-042916-4164- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004146	Fountain	2	In classroom 2201 connecting hallway	Right Low	WT-042916-4163- A	< 2	WT-042916-4163- B	< 2			
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004145	Fountain	2	In classroom 2201 connecting hallway	Left High	WT-042916-4162- A	< 2	WT-042916-4162- B	< 2			



RANDALL HIGHLANDS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004144	Classroom	2	In classroom 2201	WT-042916-4161- A	7	WT-042916-4161- B	< 2				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004143	Cooler	2	In hallway adjacent to 2214 Right Low	WT-042916-4160- A	< 1	WT-042916-4160- B	< 1				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004142	Cooler	2	In hallway adjacent to 2213	WT-042916-4159- A	< 1	WT-042916-4159- B	< 1				
RANDALL HIGHLANDS ELEMENTARY SCHOOL	5/5/2016	WS- 004141	Utility	Basement	In sub basement boiler room	WT-042916-4158- A	1350	WT-042916-4158- B	336	Non-drinking water source - Not accessible to children (boilers)			

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.