



Randall RC Lead in Water Test Results

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006241	3/18/2021	3/18/2022	Ground Floor	Food Prep Sink	In kitchen	WF-03182021-006241	4/7/2021	FT-FY21-032021-006241-A	<1	FT-FY21-032021-006241-B	<1