



Randall Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006241	12/27/2023	12/27/2024	Ground Floor	Food Prep Sink	In kitchen	WF-12272023-006241	5/3/2024	FT-FY24-04172024-006241-A	<1	FT-FY24-04172024-006241-B	<1
WS- 006242	4/12/2024	4/12/2025	Ground Floor	Cooler	In hallway across from girls' restroom	WF-04122024-006242	5/3/2024	FT-FY24-04172024-006242-A	<1	FT-FY24-04172024-006242-B	<1