



RANDALL REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	RANDALL RECREATION CENTER & POOL	WS- 006241	9/22/2016	Ground Floor	Food Prep Sink	In kitchen	FT-82016-006241-A	< 1	FT-82016-006241-B	< 1
2	RANDALL RECREATION CENTER & POOL	WS- 006242	9/22/2016	Ground Floor	Cooler	In hallway across from girls' restroom	FT-82016-006242-A	< 1	FT-82016-006242-B	< 1