



Randle Highlands ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004142	5/16/2018	5/16/2019	2	Cooler	In hallway adjacent to 2214	High Left	WF-05162018-004142	10/22/2018	FT-FY19-102018-004142-A	< 1	FT-FY19-102018-004142-B	< 1
WS-004143	5/16/2018	5/16/2019	2	Cooler	In hallway adjacent to 2214	Low Right	WF-05162018-004143	10/22/2018	FT-FY19-102018-004143-A	< 1	FT-FY19-102018-004143-B	< 1
WS-004145	5/16/2018	5/16/2019	2	Cooler	In classroom 2201 connecting hallway	High Left	WF-05162018-004145	10/22/2018	FT-FY19-102018-004145-A	< 1	FT-FY19-102018-004145-B	< 1
WS-004146	5/16/2018	5/16/2019	2	Cooler	In classroom 2201 connecting hallway	Low Right	WF-05162018-004146	10/22/2018	FT-FY19-102018-004146-A	< 1	FT-FY19-102018-004146-B	< 1
WS-004150	5/16/2018	5/16/2019	1	Cooler	In classroom 2109 connecting hallway	High Left	WF-05162018-004150	10/22/2018	FT-FY19-102018-004150-A	< 1	FT-FY19-102018-004150-B	< 1
WS-004151	5/16/2018	5/16/2019	1	Cooler	In classroom 2109 connecting hallway	Low Right	WF-05162018-004151	10/22/2018	FT-FY19-102018-004151-A	< 1	FT-FY19-102018-004151-B	< 1
WS-004153	5/16/2018	5/16/2019	1	Cooler	In hallway adjacent to room 2114	High Left	WF-05162018-004153	10/22/2018	FT-FY19-102018-004153-A	< 1	FT-FY19-102018-004153-B	< 1
WS-004154	5/16/2018	5/16/2019	1	Cooler	In hallway adjacent to room 2114	Low Right	WF-05162018-004154	10/22/2018	FT-FY19-102018-004154-A	< 1	FT-FY19-102018-004154-B	< 1
WS-004157	5/16/2018	5/16/2019	1	Cooler	In classroom 2104 connecting hallway	High Left	WF-05162018-004157	10/22/2018	FT-FY19-102018-004157-A	< 1	FT-FY19-102018-004157-B	< 1
WS-004158	5/16/2018	5/16/2019	1	Cooler	In classroom 2104 connecting hallway	Low Right	WF-05162018-004158	10/22/2018	FT-FY19-102018-004158-A	< 1	FT-FY19-102018-004158-B	< 1
WS-004161	5/16/2018	5/16/2019	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05162018-004161	10/22/2018	FT-FY19-102018-004161-A	< 1	FT-FY19-102018-004161-B	< 1
WS-004162	5/16/2018	5/16/2019	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05162018-004162	10/22/2018	FT-FY19-102018-004162-A	< 1	FT-FY19-102018-004162-B	< 1
WS-004175	5/16/2018	5/16/2019	2	Cooler	In classroom 2209 connecting hallway	High Left	WF-05162018-004175	10/22/2018	FT-FY19-102018-004175-A	< 1	FT-FY19-102018-004175-B	< 1
WS-004176	5/16/2018	5/16/2019	2	Cooler	In classroom 2209 connecting hallway	Low Right	WF-05162018-004176	10/22/2018	FT-FY19-102018-004176-A	< 1	FT-FY19-102018-004176-B	< 1
WS-004178	5/16/2018	5/16/2019	2	Break Room	In staff lounge 2207		WF-05162018-004178	10/22/2018	FT-FY19-102018-004178-A	< 1	FT-FY19-102018-004178-B	< 1
WS-004180	5/16/2018	5/16/2019	2	Cooler	In classroom 2204 connecting hallway	High Left	WF-05162018-004180	10/22/2018	FT-FY19-102018-004180-A	< 1	FT-FY19-102018-004180-B	< 1
WS-004181	5/16/2018	5/16/2019	2	Cooler	In classroom 2204 connecting hallway	Low Right	WF-05162018-004181	10/22/2018	FT-FY19-102018-004181-A	< 1	FT-FY19-102018-004181-B	< 1
WS-004184	5/16/2018	5/16/2019	Ground Floor	Cooler	In classroom 2009 connecting hallway	High Left	WF-05162018-004184	10/22/2018	FT-FY19-102018-004184-A	< 1	FT-FY19-102018-004184-B	< 1
WS-004185	5/16/2018	5/16/2019	Ground Floor	Cooler	In classroom 2009 connecting hallway	Low Right	WF-05162018-004185	10/22/2018	FT-FY19-102018-004185-A	< 1	FT-FY19-102018-004185-B	< 1
WS-004187	5/16/2018	5/16/2019	Ground Floor	Health Suite	In health suite 2007		WF-05162018-004187	10/22/2018	FT-FY19-102018-004187-A	< 1	FT-FY19-102018-004187-B	< 1
WS-004189	5/16/2018	5/16/2019	Ground Floor	Cooler	In classroom 2004 connecting hallway	High Left	WF-05162018-004189	10/22/2018	FT-FY19-102018-004189-A	< 1	FT-FY19-102018-004189-B	< 1
WS-004190	5/16/2018	5/16/2019	Ground Floor	Cooler	In classroom 2004 connecting hallway	Low Right	WF-05162018-004190	10/22/2018	FT-FY19-102018-004190-A	< 1	FT-FY19-102018-004190-B	< 1
WS-004193	5/16/2018	5/16/2019	Ground Floor	Cooler	In classroom 2001 connecting hallway	High Left	WF-05162018-004193	10/22/2018	FT-FY19-102018-004193-A	< 1	FT-FY19-102018-004193-B	< 1
WS-004196	5/16/2018	5/16/2019	Ground Floor	Cooler	In hallway adjacent to room 2014	High Left	WF-05162018-004196	10/22/2018	FT-FY19-102018-004196-A	< 1	FT-FY19-102018-004196-B	< 1
WS-004197	5/16/2018	5/16/2019	Ground Floor	Cooler	In hallway adjacent to room 2014	Low Right	WF-05162018-004197	10/22/2018	FT-FY19-102018-004197-A	< 1	FT-FY19-102018-004197-B	< 1
WS-004198	5/16/2018	5/16/2019	Basement	Cooler	In hallway adjacent to room 2B14	High Left	WF-05162018-004198	10/22/2018	FT-FY19-102018-004198-A	< 1	FT-FY19-102018-004198-B	< 1
WS-004199	5/16/2018	5/16/2019	Basement	Cooler	In hallway adjacent to room 2B14	Low Right	WF-05162018-004199	10/22/2018	FT-FY19-102018-004199-A	< 1	FT-FY19-102018-004199-B	< 1
WS-004202	5/16/2018	5/16/2019	Basement	Cooler	In classroom 2B09 connecting hallway	High Left	WF-05162018-004202	10/22/2018	FT-FY19-102018-004202-A	< 1	FT-FY19-102018-004202-B	< 1
WS-004203	5/16/2018	5/16/2019	Basement	Cooler	In classroom 2B09 connecting hallway	Low Right	WF-05162018-004203	10/22/2018	FT-FY19-102018-004203-A	< 1	FT-FY19-102018-004203-B	< 1
WS-004206	5/16/2018	5/16/2019	Basement	Cooler	In classroom 2B04 connecting hallway	Low Right	WF-05162018-004206	10/22/2018	FT-FY19-102018-004206-A	< 1	FT-FY19-102018-004206-B	< 1
WS-004210	5/16/2018	5/16/2019	Basement	Cooler	In classroom 2B01 connecting hallway	High Left	WF-05162018-004210	10/22/2018	FT-FY19-102018-004210-A	< 1	FT-FY19-102018-004210-B	< 1
WS-004211	5/16/2018	5/16/2019	Basement	Cooler	In classroom 2B01 connecting hallway	Low Right	WF-05162018-004211	10/22/2018	FT-FY19-102018-004211-A	< 1	FT-FY19-102018-004211-B	< 1
WS-004215	5/16/2018	5/16/2019	Ground Floor	Cooler	In hallway adjacent to 3001		WF-05162018-004215	10/22/2018	FT-FY19-102018-004215-A	< 1	FT-FY19-102018-004215-B	< 1
WS-004183	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom 2011		WF-09242018-004183	10/22/2018	FT-FY19-102018-004183-A	< 1	FT-FY19-102018-004183-B	< 1
WS-004186	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom 2009		WF-09242018-004186	10/22/2018	FT-FY19-102018-004186-A	< 1	FT-FY19-102018-004186-B	< 1
WS-004188	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom 2006		WF-09242018-004188	10/22/2018	FT-FY19-102018-004188-A	< 1	FT-FY19-102018-004188-B	< 1
WS-004191	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom 2004		WF-09242018-004191	10/22/2018	FT-FY19-102018-004191-A	< 1	FT-FY19-102018-004191-B	< 1
WS-004192	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom 2003		WF-09242018-004192	10/22/2018	FT-FY19-102018-004192-A	< 1	FT-FY19-102018-004192-B	< 1
WS-004195	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom 2001		WF-09242018-004195	10/22/2018	FT-FY19-102018-004195-A	< 1	FT-FY19-102018-004195-B	< 1
WS-004201	9/24/2018	9/24/2019	Basement	Classroom Faucet	In classroom 2B11		WF-09242018-004201	10/22/2018	FT-FY19-102018-004201-A	< 1	FT-FY19-102018-004201-B	< 1
WS-004204	9/24/2018	9/24/2019	Basement	Classroom Faucet	In classroom 2B09		WF-09242018-004204	10/22/2018	FT-FY19-102018-004204-A	< 1	FT-FY19-102018-004204-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004213	Ground Floor	Food Prep Sink	In kitchen 2038		Left	10/22/2018	FT-FY19-102018-004213-A	< 1	FT-FY19-102018-004213-B	< 1

WS- 004214	Ground Floor	Food Prep Sink	In kitchen 2038	Right	10/22/2018	FT-FY19-102018-004214-A	< 1	FT-FY19-102018-004214-B	< 1
------------	--------------	----------------	-----------------	-------	------------	-------------------------	-----	-------------------------	-----