



Randle Highlands Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002601	8/3/2022	8/3/2023	2	Combo Faucet	In classroom E201	Low Left	WF-08032022-002601	8/30/2022	FT-FY23-08192022-002601-A	1.9	FT-FY23-08192022-002601-B	<1
WS- 002602	8/3/2022	8/3/2023	2	Combo Fountain	In classroom E201		WF-08032022-002602	8/30/2022	FT-FY23-08192022-002602-A	<1	FT-FY23-08192022-002602-B	<1
WS- 002604	8/3/2022	8/3/2023	2	Combo Faucet	In classroom E207	Low Left	WF-08032022-002604	8/30/2022	FT-FY23-08192022-002604-A	<1	FT-FY23-08192022-002604-B	<1
WS- 002605	8/3/2022	8/3/2023	2	Combo Fountain	In classroom E207		WF-08032022-002605	8/30/2022	FT-FY23-08192022-002605-A	<1	FT-FY23-08192022-002605-B	<1
WS- 002606	8/3/2022	8/3/2023	2	Break Room	In staff lounge E223		WF-08032022-002606	8/30/2022	FT-FY23-08192022-002606-A	<1	FT-FY23-08192022-002606-B	<1
WS- 002608	8/3/2022	8/3/2023	2	Combo Faucet	In classroom E216	Low Left	WF-08032022-002608	8/30/2022	FT-FY23-08192022-002608-A	<1	FT-FY23-08192022-002608-B	<1
WS- 002609	8/3/2022	8/3/2023	2	Combo Fountain	In classroom E216		WF-08032022-002609	8/30/2022	FT-FY23-08192022-002609-A	<1	FT-FY23-08192022-002609-B	<1
WS- 002610	8/3/2022	8/3/2023	2	Health Suite	In wellness room E215		WF-08032022-002610	8/30/2022	FT-FY23-08192022-002610-A	<1	FT-FY23-08192022-002610-B	<1
WS- 002612	8/3/2022	8/3/2023	3	Combo Faucet	In classroom E301	Low Left	WF-08032022-002612	8/30/2022	FT-FY23-08192022-002612-A	<1	FT-FY23-08192022-002612-B	<1
WS- 002613	8/3/2022	8/3/2023	3	Combo Fountain	In classroom E301		WF-08032022-002613	8/30/2022	FT-FY23-08192022-002613-A	<1	FT-FY23-08192022-002613-B	<1
WS- 002615	8/3/2022	8/3/2023	3	Combo Faucet	In classroom E305	Low Left	WF-08032022-002615	8/30/2022	FT-FY23-08192022-002615-A	<1	FT-FY23-08192022-002615-B	<1
WS- 002616	8/3/2022	8/3/2023	3	Combo Fountain	In classroom E305		WF-08032022-002616	8/30/2022	FT-FY23-08192022-002616-A	1.3	FT-FY23-08192022-002616-B	<1
WS- 002618	8/3/2022	8/3/2023	3	Combo Faucet	In classroom E319	Low Left	WF-08032022-002618	8/30/2022	FT-FY23-08192022-002618-A	1.4	FT-FY23-08192022-002618-B	<1
WS- 002619	8/3/2022	8/3/2023	3	Combo Fountain	In classroom E319		WF-08032022-002619	8/30/2022	FT-FY23-08192022-002619-A	<1	FT-FY23-08192022-002619-B	<1
WS- 002621	8/3/2022	8/3/2023	3	Combo Faucet	In classroom E313	Low Left	WF-08032022-002621	8/30/2022	FT-FY23-08192022-002621-A	<1	FT-FY23-08192022-002621-B	<1
WS- 002622	8/3/2022	8/3/2023	3	Combo Fountain	In classroom E313		WF-08032022-002622	8/30/2022	FT-FY23-08192022-002622-A	<1	FT-FY23-08192022-002622-B	<1
WS- 002623	8/3/2022	8/3/2023	3	Bottle Filler	In open area adjacent to E313		WF-08032022-002623	8/30/2022	FT-FY23-08192022-002623-A	<1	FT-FY23-08192022-002623-B	<1
WS- 002624	8/3/2022	8/3/2023	3	Cooler	In open area adjacent to E313	High Left	WF-08032022-002624	8/30/2022	FT-FY23-08192022-002624-A	<1	FT-FY23-08192022-002624-B	<1
WS- 002625	8/3/2022	8/3/2023	3	Cooler	In open area adjacent to E313	Low Right	WF-08032022-002625	8/30/2022	FT-FY23-08192022-002625-A	<1	FT-FY23-08192022-002625-B	<1
WS- 002626	8/3/2022	8/3/2023	2	Bottle Filler	In open area adjacent to E216		WF-08032022-002626	8/30/2022	FT-FY23-08192022-002626-A	<1	FT-FY23-08192022-002626-B	<1
WS- 002627	8/3/2022	8/3/2023	2	Cooler	In open area adjacent to E216	High Left	WF-08032022-002627	8/30/2022	FT-FY23-08192022-002627-A	<1	FT-FY23-08192022-002627-B	<1
WS- 002628	8/3/2022	8/3/2023	2	Cooler	In open area adjacent to E216	Low Right	WF-08032022-002628	8/30/2022	FT-FY23-08192022-002628-A	<1	FT-FY23-08192022-002628-B	<1
WS- 002631	8/17/2022	8/17/2023	1	Bottle Filler	In common area		WF-08172022-002631	8/30/2022	FT-FY23-08192022-002631-A	<1	FT-FY23-08192022-002631-B	<1
WS- 002632	8/17/2022	8/17/2023	1	Cooler	In common area	High Left	WF-08172022-002632	8/30/2022	FT-FY23-08192022-002632-A	<1	FT-FY23-08192022-002632-B	<1
WS- 002633	8/17/2022	8/17/2023	1	Cooler	In common area	Low Right	WF-08172022-002633	8/30/2022	FT-FY23-08192022-002633-A	<1	FT-FY23-08192022-002633-B	<1
WS- 002634	8/17/2022	8/17/2023	1	Combo Faucet	In toddler room C102		WF-08172022-002634	8/30/2022	FT-FY23-08192022-002634-A	<1	FT-FY23-08192022-002634-B	<1
WS- 002635	8/17/2022	8/17/2023	1	Combo Fountain	In toddler room C102		WF-08172022-002635	8/30/2022	FT-FY23-08192022-002635-A	<1	FT-FY23-08192022-002635-B	<1
WS- 002638	8/17/2022	8/17/2023	1	Combo Faucet	In infant room C101		WF-08172022-002638	8/30/2022	FT-FY23-08192022-002638-A	<1	FT-FY23-08192022-002638-B	<1
WS- 002639	8/17/2022	8/17/2023	1	Combo Fountain	In infant room C101		WF-08172022-002639	8/30/2022	FT-FY23-08192022-002639-A	<1	FT-FY23-08192022-002639-B	<1
WS- 004142	5/18/2022	5/18/2023	2	Cooler	In hallway adjacent to 2214	High Left	WF-05182022-004142	8/30/2022	FT-FY23-08192022-004142-A	<1	FT-FY23-08192022-004142-B	<1
WS- 004143	5/18/2022	5/18/2023	2	Cooler	In hallway adjacent to 2214	Low Right	WF-05182022-004143	8/30/2022	FT-FY23-08192022-004143-A	<1	FT-FY23-08192022-004143-B	<1
WS- 004145	5/18/2022	5/18/2023	2	Cooler	In classroom 2201 connecting hallway	High Left	WF-05182022-004145	8/30/2022	FT-FY23-08192022-004145-A	<1	FT-FY23-08192022-004145-B	<1
WS- 004146	5/18/2022	5/18/2023	2	Cooler	In classroom 2201 connecting hallway	Low Right	WF-05182022-004146	8/30/2022	FT-FY23-08192022-004146-A	<1	FT-FY23-08192022-004146-B	<1
WS- 004151	5/18/2022	5/18/2023	1	Cooler	In classroom 2109 connecting hallway	Low Right	WF-05182022-004151	8/30/2022	FT-FY23-08192022-004151-A	<1	FT-FY23-08192022-004151-B	<1
WS- 004153	5/18/2022	5/18/2023	1	Cooler	In hallway adjacent to room 2114	High Left	WF-05182022-004153	8/30/2022	FT-FY23-08192022-004153-A	<1	FT-FY23-08192022-004153-B	<1

WS-004154	5/18/2022	5/18/2023	1	Cooler	In hallway adjacent to room 2114	Low Right	WF-05182022-004154	8/30/2022	FT-FY23-08192022-004154-A	<1	FT-FY23-08192022-004154-B	<1
WS-004158	5/18/2022	5/18/2023	1	Cooler	In classroom 2104 connecting hallway	Low Right	WF-05182022-004158	8/30/2022	FT-FY23-08192022-004158-A	<1	FT-FY23-08192022-004158-B	<1
WS-004161	5/18/2022	5/18/2023	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05182022-004161	8/30/2022	FT-FY23-08192022-004161-A	<1	FT-FY23-08192022-004161-B	<1
WS-004162	5/18/2022	5/18/2023	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05182022-004162	8/30/2022	FT-FY23-08192022-004162-A	<1	FT-FY23-08192022-004162-B	<1
WS-004175	5/18/2022	5/18/2023	2	Cooler	In classroom 2209 connecting hallway	High Left	WF-05182022-004175	8/30/2022	FT-FY23-08192022-004175-A	<1	FT-FY23-08192022-004175-B	<1
WS-004176	5/18/2022	5/18/2023	2	Cooler	In classroom 2209 connecting hallway	Low Right	WF-05182022-004176	8/30/2022	FT-FY23-08192022-004176-A	<1	FT-FY23-08192022-004176-B	<1
WS-004178	5/18/2022	5/18/2023	2	Break Room	In staff lounge 2207		WF-05182022-004178	8/30/2022	FT-FY23-08192022-004178-A	2.3	FT-FY23-08192022-004178-B	<1
WS-004180	5/18/2022	5/18/2023	2	Cooler	In classroom 2204 connecting hallway	High Left	WF-05182022-004180	8/30/2022	FT-FY23-08192022-004180-A	<1	FT-FY23-08192022-004180-B	<1
WS-004181	5/18/2022	5/18/2023	2	Cooler	In classroom 2204 connecting hallway	Low Right	WF-05182022-004181	8/30/2022	FT-FY23-08192022-004181-A	<1	FT-FY23-08192022-004181-B	<1
WS-004183	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2011		WF-08302021-004183	8/30/2022	FT-FY23-08192022-004183-A	<1	FT-FY23-08192022-004183-B	<1
WS-004184	5/18/2022	5/18/2023	Ground Floor	Cooler	In classroom 2009 connecting hallway	High Left	WF-05182022-004184	8/30/2022	FT-FY23-08192022-004184-A	<1	FT-FY23-08192022-004184-B	<1
WS-004185	5/18/2022	5/18/2023	Ground Floor	Cooler	In classroom 2009 connecting hallway	Low Right	WF-05182022-004185	8/30/2022	FT-FY23-08192022-004185-A	<1	FT-FY23-08192022-004185-B	<1
WS-004186	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2009		WF-08302021-004186	8/30/2022	FT-FY23-08192022-004186-A	<1	FT-FY23-08192022-004186-B	<1
WS-004187	5/18/2022	5/18/2023	Ground Floor	Health Suite	In health suite 2007		WF-05182022-004187	8/30/2022	FT-FY23-08192022-004187-A	<1	FT-FY23-08192022-004187-B	<1
WS-004188	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2006		WF-08302021-004188	8/30/2022	FT-FY23-08192022-004188-A	<1	FT-FY23-08192022-004188-B	<1
WS-004189	5/18/2022	5/18/2023	Ground Floor	Cooler	In classroom 2004 connecting hallway	High Left	WF-05182022-004189	8/30/2022	FT-FY23-08192022-004189-A	<1	FT-FY23-08192022-004189-B	<1
WS-004190	5/18/2022	5/18/2023	Ground Floor	Cooler	In classroom 2004 connecting hallway	Low Right	WF-05182022-004190	8/30/2022	FT-FY23-08192022-004190-A	<1	FT-FY23-08192022-004190-B	<1
WS-004191	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2004		WF-08302021-004191	8/30/2022	FT-FY23-08192022-004191-A	<1	FT-FY23-08192022-004191-B	<1
WS-004192	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2003		WF-08302021-004192	8/30/2022	FT-FY23-08192022-004192-A	<1	FT-FY23-08192022-004192-B	<1
WS-004193	5/18/2022	5/18/2023	Ground Floor	Cooler	In classroom 2001 connecting hallway	High Left	WF-05182022-004193	8/30/2022	FT-FY23-08192022-004193-A	<1	FT-FY23-08192022-004193-B	<1
WS-004195	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2001		WF-08302021-004195	8/30/2022	FT-FY23-08192022-004195-A	<1	FT-FY23-08192022-004195-B	<1
WS-004196	5/18/2022	5/18/2023	Ground Floor	Cooler	In hallway adjacent to room 2014	High Left	WF-05182022-004196	8/30/2022	FT-FY23-08192022-004196-A	<1	FT-FY23-08192022-004196-B	<1
WS-004197	5/18/2022	5/18/2023	Ground Floor	Cooler	In hallway adjacent to room 2014	Low Right	WF-05182022-004197	8/30/2022	FT-FY23-08192022-004197-A	<1	FT-FY23-08192022-004197-B	<1
WS-004198	5/18/2022	5/18/2023	Basement	Cooler	In hallway adjacent to room 2B14	High Left	WF-05182022-004198	8/30/2022	FT-FY23-08192022-004198-A	<1	FT-FY23-08192022-004198-B	<1
WS-004199	5/18/2022	5/18/2023	Basement	Cooler	In hallway adjacent to room 2B14	Low Right	WF-05182022-004199	8/30/2022	FT-FY23-08192022-004199-A	<1	FT-FY23-08192022-004199-B	<1
WS-004201	9/3/2021	9/3/2022	Basement	Classroom Faucet	In classroom 2B11		WF-09032021-004201	8/30/2022	FT-FY23-08192022-004201-A	<1	FT-FY23-08192022-004201-B	<1
WS-004202	5/18/2022	5/18/2023	Basement	Cooler	In classroom 2B09 connecting hallway	High Left	WF-05182022-004202	8/30/2022	FT-FY23-08192022-004202-A	<1	FT-FY23-08192022-004202-B	<1
WS-004203	5/18/2022	5/18/2023	Basement	Cooler	In classroom 2B09 connecting hallway	Low Right	WF-05182022-004203	8/30/2022	FT-FY23-08192022-004203-A	<1	FT-FY23-08192022-004203-B	<1
WS-004204	9/3/2021	9/3/2022	Basement	Classroom Faucet	In classroom 2B09		WF-09032021-004204	8/30/2022	FT-FY23-08192022-004204-A	2.3	FT-FY23-08192022-004204-B	<1
WS-004205	5/18/2022	5/18/2023	Basement	Cooler	In classroom 2B04 connecting hallway	High Left	WF-05182022-004205	8/30/2022	FT-FY23-08192022-004205-A	<1	FT-FY23-08192022-004205-B	<1
WS-004206	5/18/2022	5/18/2023	Basement	Cooler	In classroom 2B04 connecting hallway	Low Right	WF-05182022-004206	8/30/2022	FT-FY23-08192022-004206-A	<1	FT-FY23-08192022-004206-B	<1
WS-004208	5/18/2022	5/18/2023	Ground Floor	Bottle Filler	In hallway adjacent to 3001		WF-05182022-004208	8/30/2022	FT-FY23-08192022-004208-A	<1	FT-FY23-08192022-004208-B	<1
WS-004210	5/18/2022	5/18/2023	Basement	Cooler	In classroom 2B01 connecting hallway	High Left	WF-05182022-004210	8/30/2022	FT-FY23-08192022-004210-A	<1	FT-FY23-08192022-004210-B	<1
WS-004211	5/18/2022	5/18/2023	Basement	Cooler	In classroom 2B01 connecting hallway	Low Right	WF-05182022-004211	8/30/2022	FT-FY23-08192022-004211-A	<1	FT-FY23-08192022-004211-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002641	8/17/2022	8/17/2023	1	Food Prep Sink	In meal distribution E108	WF-08172022-002641	8/30/2022	FT-FY23-08192022-002641-A	<1	FT-FY23-08192022-002641-B	<1
WS-004213	1/10/2022	1/10/2023	Ground Floor	Food Prep Sink	In kitchen room 2038	WF-01102022-004213	8/30/2022	FT-FY23-08192022-004213-A	<1	FT-FY23-08192022-004213-B	<1

WS-004214	1/10/2022	1/10/2023	Ground Floor	Food Prep Sink	In kitchen 2038	Right	WF-01102022-004214	8/30/2022	FT-FY23-08192022-004214-A	<1	FT-FY23-08192022-004214-B	<1
-----------	-----------	-----------	--------------	----------------	-----------------	-------	--------------------	-----------	---------------------------	----	---------------------------	----