



Randle Highlands Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004142	6/23/2020	6/23/2021	2	Cooler	In hallway adjacent to 2214 High Left	WF-06232020-004142	1/13/2021	FT-FY21-012021-004142-A	<1	FT-FY21-012021-004142-B	<1
WS-004143	6/23/2020	6/23/2021	2	Cooler	In hallway adjacent to 2214 Low Right	WF-06232020-004143	1/13/2021	FT-FY21-012021-004143-A	<1	FT-FY21-012021-004143-B	<1
WS-004145	6/23/2020	6/23/2021	2	Cooler	In classroom 2201 connecting hallway High Left	WF-06232020-004145	1/13/2021	FT-FY21-012021-004145-A	<1	FT-FY21-012021-004145-B	<1
WS-004146	6/23/2020	6/23/2021	2	Cooler	In classroom 2201 connecting hallway Low Right	WF-06232020-004146	1/13/2021	FT-FY21-012021-004146-A	<1	FT-FY21-012021-004146-B	<1
WS-004150	6/23/2020	6/23/2021	1	Cooler	In classroom 2109 connecting hallway High Left	WF-06232020-004150	1/13/2021	FT-FY21-012021-004150-A	<1	FT-FY21-012021-004150-B	<1
WS-004151	6/23/2020	6/23/2021	1	Cooler	In classroom 2109 connecting hallway Low Right	WF-06232020-004151	1/13/2021	FT-FY21-012021-004151-A	<1	FT-FY21-012021-004151-B	<1
WS-004153	6/23/2020	6/23/2021	1	Cooler	In hallway adjacent to room 2114 High Left	WF-06232020-004153	1/13/2021	FT-FY21-012021-004153-A	<1	FT-FY21-012021-004153-B	<1
WS-004154	6/23/2020	6/23/2021	1	Cooler	In hallway adjacent to room 2114 Low Right	WF-06232020-004154	1/13/2021	FT-FY21-012021-004154-A	<1	FT-FY21-012021-004154-B	<1
WS-004157	6/23/2020	6/23/2021	1	Cooler	In classroom 2104 connecting hallway High Left	WF-06232020-004157	1/13/2021	FT-FY21-012021-004157-A	<1	FT-FY21-012021-004157-B	<1
WS-004158	6/23/2020	6/23/2021	1	Cooler	In classroom 2104 connecting hallway Low Right	WF-06232020-004158	1/13/2021	FT-FY21-012021-004158-A	<1	FT-FY21-012021-004158-B	<1
WS-004161	6/23/2020	6/23/2021	1	Cooler	In classroom 2101 connecting hallway High Left	WF-06232020-004161	1/13/2021	FT-FY21-012021-004161-A	<1	FT-FY21-012021-004161-B	<1
WS-004162	6/23/2020	6/23/2021	1	Cooler	In classroom 2101 connecting hallway High Left	WF-06232020-004162	1/13/2021	FT-FY21-012021-004162-A	<1	FT-FY21-012021-004162-B	<1
WS-004175	6/23/2020	6/23/2021	2	Cooler	In classroom 2209 connecting hallway High Left	WF-06232020-004175	1/13/2021	FT-FY21-012021-004175-A	<1	FT-FY21-012021-004175-B	<1
WS-004176	6/23/2020	6/23/2021	2	Cooler	In classroom 2209 connecting hallway Low Right	WF-06232020-004176	1/13/2021	FT-FY21-012021-004176-A	<1	FT-FY21-012021-004176-B	<1
WS-004178	6/23/2020	6/23/2021	2	Break Room	In staff lounge 2207	WF-06232020-004178	1/13/2021	FT-FY21-012021-004178-A	<1	FT-FY21-012021-004178-B	<1
WS-004180	6/23/2020	6/23/2021	2	Cooler	In classroom 2204 connecting hallway High Left	WF-06232020-004180	1/13/2021	FT-FY21-012021-004180-A	<1	FT-FY21-012021-004180-B	<1
WS-004181	6/23/2020	6/23/2021	2	Cooler	In classroom 2204 connecting hallway Low Right	WF-06232020-004181	1/13/2021	FT-FY21-012021-004181-A	<1	FT-FY21-012021-004181-B	<1
WS-004183	9/8/2020	9/8/2021	Ground Floor	Classroom Faucet	In classroom 2011	WF-09082020-004183	1/13/2021	FT-FY21-012021-004183-A	<1	FT-FY21-012021-004183-B	<1
WS-004184	6/23/2020	6/23/2021	Ground Floor	Cooler	In classroom 2009 connecting hallway High Left	WF-06232020-004184	1/13/2021	FT-FY21-012021-004184-A	<1	FT-FY21-012021-004184-B	<1
WS-004185	6/23/2020	6/23/2021	Ground Floor	Cooler	In classroom 2009 connecting hallway Low Right	WF-06232020-004185	1/13/2021	FT-FY21-012021-004185-A	<1	FT-FY21-012021-004185-B	<1
WS-004186	9/8/2020	9/8/2021	Ground Floor	Classroom Faucet	In classroom 2009	WF-09082020-004186	1/13/2021	FT-FY21-012021-004186-A	<1	FT-FY21-012021-004186-B	<1
WS-004187	6/23/2020	6/23/2021	Ground Floor	Health Suite	In health suite 2007	WF-06232020-004187	1/13/2021	FT-FY21-012021-004187-A	<1	FT-FY21-012021-004187-B	<1
WS-004188	9/8/2020	9/8/2021	Ground Floor	Classroom Faucet	In classroom 2006	WF-09082020-004188	1/13/2021	FT-FY21-012021-004188-A	2.8	FT-FY21-012021-004188-B	<1
WS-004189	6/23/2020	6/23/2021	Ground Floor	Cooler	In classroom 2004 connecting hallway High Left	WF-06232020-004189	1/13/2021	FT-FY21-012021-004189-A	<1	FT-FY21-012021-004189-B	<1
WS-004190	6/23/2020	6/23/2021	Ground Floor	Cooler	In classroom 2004 connecting hallway Low Right	WF-06232020-004190	1/13/2021	FT-FY21-012021-004190-A	<1	FT-FY21-012021-004190-B	<1
WS-004191	9/8/2020	9/8/2021	Ground Floor	Classroom Faucet	In classroom 2004	WF-09082020-004191	1/13/2021	FT-FY21-012021-004191-A	<1	FT-FY21-012021-004191-B	<1
WS-004192	9/8/2020	9/8/2021	Ground Floor	Classroom Faucet	In classroom 2003	WF-09082020-004192	1/13/2021	FT-FY21-012021-004192-A	<1	FT-FY21-012021-004192-B	<1
WS-004193	6/23/2020	6/23/2021	Ground Floor	Cooler	In classroom 2001 connecting hallway High Left	WF-06232020-004193	1/13/2021	FT-FY21-012021-004193-A	<1	FT-FY21-012021-004193-B	<1
WS-004194	6/23/2020	6/23/2021	Ground Floor	Cooler	In classroom 2001 connecting hallway Low Right	WF-06232020-004194	1/13/2021	FT-FY21-012021-004194-A	<1	FT-FY21-012021-004194-B	<1
WS-004195	9/8/2020	9/8/2021	Ground Floor	Classroom Faucet	In classroom 2001	WF-09082020-004195	1/13/2021	FT-FY21-012021-004195-A	<1	FT-FY21-012021-004195-B	<1
WS-004196	6/23/2020	6/23/2021	Ground Floor	Cooler	In hallway adjacent to room 2014 High Left	WF-06232020-004196	1/13/2021	FT-FY21-012021-004196-A	<1	FT-FY21-012021-004196-B	<1
WS-004197	6/23/2020	6/23/2021	Ground Floor	Cooler	In hallway adjacent to room 2014 Low Right	WF-06232020-004197	1/13/2021	FT-FY21-012021-004197-A	<1	FT-FY21-012021-004197-B	<1

WS- 004198	6/23/2020	6/23/2021	Basement	Cooler	In hallway adjacent to room 2B14	High	Left	WF-06232020-004198	1/13/2021	FT-FY21-012021-004198-A	<1	FT-FY21-012021-004198-B	<1
WS- 004199	6/23/2020	6/23/2021	Basement	Cooler	In hallway adjacent to room 2B14	Low	Right	WF-06232020-004199	1/13/2021	FT-FY21-012021-004199-A	<1	FT-FY21-012021-004199-B	<1
WS- 004201	9/8/2020	9/8/2021	Basement	Classroom Faucet	In classroom 2B11			WF-09082020-004201	1/13/2021	FT-FY21-012021-004201-A	<1	FT-FY21-012021-004201-B	<1
WS- 004202	6/23/2020	6/23/2021	Basement	Cooler	In classroom 2B09 connecting hallway	High	Left	WF-06232020-004202	1/13/2021	FT-FY21-012021-004202-A	<1	FT-FY21-012021-004202-B	<1
WS- 004203	6/23/2020	6/23/2021	Basement	Cooler	In classroom 2B09 connecting hallway	Low	Right	WF-06232020-004203	1/13/2021	FT-FY21-012021-004203-A	<1	FT-FY21-012021-004203-B	<1
WS- 004204	9/8/2020	9/8/2021	Basement	Classroom Faucet	In classroom 2B09			WF-09082020-004204	1/13/2021	FT-FY21-012021-004204-A	<1	FT-FY21-012021-004204-B	<1
WS- 004205	6/23/2020	6/23/2021	Basement	Cooler	In classroom 2B04 connecting hallway	High	Left	WF-06232020-004205	1/13/2021	FT-FY21-012021-004205-A	<1	FT-FY21-012021-004205-B	<1
WS- 004206	6/23/2020	6/23/2021	Basement	Cooler	In classroom 2B04 connecting hallway	Low	Right	WF-06232020-004206	1/13/2021	FT-FY21-012021-004206-A	<1	FT-FY21-012021-004206-B	<1
WS- 004210	6/23/2020	6/23/2021	Basement	Cooler	In classroom 2B01 connecting hallway	High	Left	WF-06232020-004210	1/13/2021	FT-FY21-012021-004210-A	<1	FT-FY21-012021-004210-B	<1
WS- 004211	6/23/2020	6/23/2021	Basement	Cooler	In classroom 2B01 connecting hallway	Low	Right	WF-06232020-004211	1/13/2021	FT-FY21-012021-004211-A	<1	FT-FY21-012021-004211-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004213	2/24/2020	2/24/2021	Ground Floor	Food Prep Sink	In kitchen room 2038	Left	WF-02242020-004213	1/13/2021	FT-FY21-012021-004213-A	<1	FT-FY21-012021-004213-B	<1
WS- 004214	2/24/2020	2/24/2021	Ground Floor	Food Prep Sink	In kitchen 2038	Right	WF-02242020-004214	1/13/2021	FT-FY21-012021-004214-A	<1	FT-FY21-012021-004214-B	<1