



Randle Highlands Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004142	5/24/2021	5/24/2022	2	Cooler	In hallway adjacent to 2214	High Left	WF-05242021-004142	1/29/2022	FT-FY22-01102022-004142-A	<1	FT-FY22-01102022-004142-B	<1	
WS-004143	5/24/2021	5/24/2022	2	Cooler	In hallway adjacent to 2214	Low Right	WF-05242021-004143	1/29/2022	FT-FY22-01102022-004143-A	<1	FT-FY22-01102022-004143-B	<1	
WS-004145	5/24/2021	5/24/2022	2	Cooler	In classroom 2201 connecting hallway	High Left	WF-05242021-004145	1/29/2022	FT-FY22-01102022-004145-A	<1	FT-FY22-01102022-004145-B	<1	
WS-004146	5/24/2021	5/24/2022	2	Cooler	In classroom 2201 connecting hallway	Low Right	WF-05242021-004146	1/29/2022	FT-FY22-01102022-004146-A	<1	FT-FY22-01102022-004146-B	<1	
WS-004150	5/24/2021	5/24/2022	1	Cooler	In classroom 2109 connecting hallway	High Left	WF-05242021-004150	1/29/2022	FT-FY22-01102022-004150-A	<1	FT-FY22-01102022-004150-B	<1	
WS-004151	5/24/2021	5/24/2022	1	Cooler	In classroom 2109 connecting hallway	Low Right	WF-05242021-004151	1/29/2022	FT-FY22-01102022-004151-A	<1	FT-FY22-01102022-004151-B	<1	
WS-004153	5/24/2021	5/24/2022	1	Cooler	In hallway adjacent to room 2114	High Left	WF-05242021-004153	1/29/2022	FT-FY22-01102022-004153-A	<1	FT-FY22-01102022-004153-B	<1	
WS-004154	5/24/2021	5/24/2022	1	Cooler	In hallway adjacent to room 2114	Low Right	WF-05242021-004154	1/29/2022	FT-FY22-01102022-004154-A	<1	FT-FY22-01102022-004154-B	<1	
WS-004158	5/24/2021	5/24/2022	1	Cooler	In classroom 2104 connecting hallway	Low Right	WF-05242021-004158	1/29/2022	FT-FY22-01102022-004158-A	<1	FT-FY22-01102022-004158-B	<1	
WS-004161	5/24/2021	5/24/2022	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05242021-004161	1/29/2022	FT-FY22-01102022-004161-A	<1	FT-FY22-01102022-004161-B	<1	
WS-004162	5/24/2021	5/24/2022	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05242021-004162	1/29/2022	FT-FY22-01102022-004162-A	<1	FT-FY22-01102022-004162-B	<1	
WS-004175	5/24/2021	5/24/2022	2	Cooler	In classroom 2209 connecting hallway	High Left	WF-05242021-004175	1/29/2022	FT-FY22-01102022-004175-A	<1	FT-FY22-01102022-004175-B	<1	
WS-004176	5/24/2021	5/24/2022	2	Cooler	In classroom 2209 connecting hallway	Low Right	WF-05242021-004176	1/29/2022	FT-FY22-01102022-004176-A	<1	FT-FY22-01102022-004176-B	<1	
WS-004178	5/24/2021	5/24/2022	2	Break Room	In staff lounge 2207		WF-05242021-004178	1/29/2022	FT-FY22-01102022-004178-A	<1	FT-FY22-01102022-004178-B	<1	
WS-004180	5/24/2021	5/24/2022	2	Cooler	In classroom 2204 connecting hallway	High Left	WF-05242021-004180	1/29/2022	FT-FY22-01102022-004180-A	<1	FT-FY22-01102022-004180-B	<1	
WS-004181	5/24/2021	5/24/2022	2	Cooler	In classroom 2204 connecting hallway	Low Right	WF-05242021-004181	1/29/2022	FT-FY22-01102022-004181-A	<1	FT-FY22-01102022-004181-B	<1	
WS-004183	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2011		WF-08302021-004183	1/29/2022	FT-FY22-01102022-004183-A	<1	FT-FY22-01102022-004183-B	<1	
WS-004184	5/24/2021	5/24/2022	Ground Floor	Cooler	In classroom 2009 connecting hallway	High Left	WF-05242021-004184	1/29/2022	FT-FY22-01102022-004184-A	<1	FT-FY22-01102022-004184-B	<1	
WS-004185	5/24/2021	5/24/2022	Ground Floor	Cooler	In classroom 2009 connecting hallway	Low Right	WF-05242021-004185	1/29/2022	FT-FY22-01102022-004185-A	<1	FT-FY22-01102022-004185-B	<1	
WS-004186	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2009		WF-08302021-004186	1/29/2022	FT-FY22-01102022-004186-A	<1	FT-FY22-01102022-004186-B	<1	
WS-004187	5/24/2021	5/24/2022	Ground Floor	Health Suite	In health suite 2007		WF-05242021-004187	1/29/2022	FT-FY22-01102022-004187-A	<1	FT-FY22-01102022-004187-B	<1	
WS-004188	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2006		WF-08302021-004188	1/29/2022	FT-FY22-01102022-004188-A	<1	FT-FY22-01102022-004188-B	<1	
WS-004189	5/24/2021	5/24/2022	Ground Floor	Cooler	In classroom 2004 connecting hallway	High Left	WF-05242021-004189	1/29/2022	FT-FY22-01102022-004189-A	<1	FT-FY22-01102022-004189-B	<1	
WS-004190	5/24/2021	5/24/2022	Ground Floor	Cooler	In classroom 2004 connecting hallway	Low Right	WF-05242021-004190	1/29/2022	FT-FY22-01102022-004190-A	<1	FT-FY22-01102022-004190-B	<1	
WS-004191	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2004		WF-08302021-004191	1/29/2022	FT-FY22-01102022-004191-A	<1	FT-FY22-01102022-004191-B	<1	
WS-004192	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2003		WF-08302021-004192	1/29/2022	FT-FY22-01102022-004192-A	<1	FT-FY22-01102022-004192-B	<1	
WS-004193	5/24/2021	5/24/2022	Ground Floor	Cooler	In classroom 2001 connecting hallway	High Left	WF-05242021-004193	1/29/2022	FT-FY22-01102022-004193-A	<1	FT-FY22-01102022-004193-B	<1	
WS-004195	8/30/2021	8/30/2022	Ground Floor	Classroom Faucet	In classroom 2001		WF-08302021-004195	1/29/2022	FT-FY22-01102022-004195-A	<1	FT-FY22-01102022-004195-B	<1	
WS-004196	5/24/2021	5/24/2022	Ground Floor	Cooler	In hallway adjacent to room 2014	High Left	WF-05242021-004196	1/29/2022	FT-FY22-01102022-004196-A	<1	FT-FY22-01102022-004196-B	<1	
WS-004197	5/24/2021	5/24/2022	Ground Floor	Cooler	In hallway adjacent to room 2014	Low Right	WF-05242021-004197	1/29/2022	FT-FY22-01102022-004197-A	<1	FT-FY22-01102022-004197-B	<1	
WS-004198	5/24/2021	5/24/2022	Basement	Cooler	In hallway adjacent to room 2B14	High Left	WF-05242021-004198	1/29/2022	FT-FY22-01102022-004198-A	<1	FT-FY22-01102022-004198-B	<1	
WS-004199	5/24/2021	5/24/2022	Basement	Cooler	In hallway adjacent to room 2B14	Low Right	WF-05242021-004199	1/29/2022	FT-FY22-01102022-004199-A	<1	FT-FY22-01102022-004199-B	<1	
WS-004201	9/3/2021	9/3/2022	Basement	Classroom Faucet	In classroom 2B11		WF-09032021-004201	1/29/2022	FT-FY22-01102022-004201-A	<1	FT-FY22-01102022-004201-B	<1	
WS-004202	5/24/2021	5/24/2022	Basement	Cooler	In classroom 2B09 connecting hallway	High Left	WF-05242021-004202	1/29/2022	FT-FY22-01102022-004202-A	<1	FT-FY22-01102022-004202-B	<1	
WS-004204	9/3/2021	9/3/2022	Basement	Classroom Faucet	In classroom 2B09		WF-09032021-004204	1/29/2022	FT-FY22-01102022-004204-A	<1	FT-FY22-01102022-004204-B	<1	

WS- 004205	5/24/2021	5/24/2022	Basement	Cooler	In classroom 2B04 connecting hallway	High Left	WF-05242021-004205	1/29/2022	FT-FY22-01102022-004205-A	<1	FT-FY22-01102022-004205-B	<1
WS- 004206	5/24/2021	5/24/2022	Basement	Cooler	In classroom 2B04 connecting hallway	Low Right	WF-05242021-004206	1/29/2022	FT-FY22-01102022-004206-A	<1	FT-FY22-01102022-004206-B	<1
WS- 004210	5/24/2021	5/24/2022	Basement	Cooler	In classroom 2B01 connecting hallway	High Left	WF-05242021-004210	1/29/2022	FT-FY22-01102022-004210-A	<1	FT-FY22-01102022-004210-B	<1
WS- 004211	5/24/2021	5/24/2022	Basement	Cooler	In classroom 2B01 connecting hallway	Low Right	WF-05242021-004211	1/29/2022	FT-FY22-01102022-004211-A	<1	FT-FY22-01102022-004211-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004213	1/10/2022	1/10/2023	Ground Floor	Food Prep Sink	In kitchen room 2038	Left	WF-01102022-004213	1/29/2022	FT-FY22-01102022-004213-A	<1	FT-FY22-01102022-004213-B	<1
WS- 004214	1/10/2022	1/10/2023	Ground Floor	Food Prep Sink	In kitchen 2038	Right	WF-01102022-004214	1/29/2022	FT-FY22-01102022-004214-A	<1	FT-FY22-01102022-004214-B	<1