



# Randle Highlands Elementary School Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location                      | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |
|-----------|-----------------------|------------------------|-------|----------------|--------------------------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| WS-002601 | 8/13/2024             | 8/13/2025              | 2     | Combo Faucet   | In classroom E201                    | WF-08132024-002601  | 1/27/2025     | FT-FY25-12262024-002601-A | <2                               | FT-FY25-12262024-002601-B | <2                               |
| WS-002602 | 5/8/2024              | 5/8/2025               | 2     | Combo Fountain | In classroom E201                    | WF-05082024-002602  | 1/27/2025     | FT-FY25-12262024-002602-A | <2                               | FT-FY25-12262024-002602-B | <2                               |
| WS-002604 | 8/13/2024             | 8/13/2025              | 2     | Combo Faucet   | In classroom E207                    | WF-08132024-002604  | 1/27/2025     | FT-FY25-12262024-002604-A | <2                               | FT-FY25-12262024-002604-B | <2                               |
| WS-002605 | 5/8/2024              | 5/8/2025               | 2     | Combo Fountain | In classroom E207                    | WF-05082024-002605  | 1/27/2025     | FT-FY25-12262024-002605-A | <2                               | FT-FY25-12262024-002605-B | <2                               |
| WS-002606 | 5/8/2024              | 5/8/2025               | 2     | Break Room     | In staff lounge E223                 | WF-05082024-002606  | 1/27/2025     | FT-FY25-12262024-002606-A | <2                               | FT-FY25-12262024-002606-B | <2                               |
| WS-002608 | 8/13/2024             | 8/13/2025              | 2     | Combo Faucet   | In classroom E216                    | WF-08132024-002608  | 1/27/2025     | FT-FY25-12262024-002608-A | <2                               | FT-FY25-12262024-002608-B | <2                               |
| WS-002609 | 5/8/2024              | 5/8/2025               | 2     | Combo Fountain | In classroom E216                    | WF-05082024-002609  | 1/27/2025     | FT-FY25-12262024-002609-A | <2                               | FT-FY25-12262024-002609-B | <2                               |
| WS-002610 | 5/8/2024              | 5/8/2025               | 2     | Health Suite   | In wellness room E215                | WF-05082024-002610  | 1/27/2025     | FT-FY25-12262024-002610-A | <2                               | FT-FY25-12262024-002610-B | <2                               |
| WS-002612 | 8/13/2024             | 8/13/2025              | 3     | Combo Faucet   | In classroom E301                    | WF-08132024-002612  | 1/27/2025     | FT-FY25-12262024-002612-A | <2                               | FT-FY25-12262024-002612-B | <2                               |
| WS-002613 | 5/8/2024              | 5/8/2025               | 3     | Combo Fountain | In classroom E301                    | WF-05082024-002613  | 1/27/2025     | FT-FY25-12262024-002613-A | <2                               | FT-FY25-12262024-002613-B | <2                               |
| WS-002615 | 8/13/2024             | 8/13/2025              | 3     | Combo Faucet   | In classroom E305                    | WF-08132024-002615  | 1/27/2025     | FT-FY25-12262024-002615-A | <2                               | FT-FY25-12262024-002615-B | <2                               |
| WS-002616 | 5/8/2024              | 5/8/2025               | 3     | Combo Fountain | In classroom E305                    | WF-05082024-002616  | 1/27/2025     | FT-FY25-12262024-002616-A | <2                               | FT-FY25-12262024-002616-B | <2                               |
| WS-002618 | 8/13/2024             | 8/13/2025              | 3     | Combo Faucet   | In classroom E319                    | WF-08132024-002618  | 1/27/2025     | FT-FY25-12262024-002618-A | <2                               | FT-FY25-12262024-002618-B | <2                               |
| WS-002619 | 5/8/2024              | 5/8/2025               | 3     | Combo Fountain | In classroom E319                    | WF-05082024-002619  | 1/27/2025     | FT-FY25-12262024-002619-A | <2                               | FT-FY25-12262024-002619-B | <2                               |
| WS-002621 | 8/13/2024             | 8/13/2025              | 3     | Combo Faucet   | In classroom E313                    | WF-08132024-002621  | 1/27/2025     | FT-FY25-12262024-002621-A | <2                               | FT-FY25-12262024-002621-B | <2                               |
| WS-002622 | 5/8/2024              | 5/8/2025               | 3     | Combo Fountain | In classroom E313                    | WF-05082024-002622  | 1/27/2025     | FT-FY25-12262024-002622-A | <2                               | FT-FY25-12262024-002622-B | <2                               |
| WS-002623 | 5/8/2024              | 5/8/2025               | 3     | Bottle Filler  | In open area adjacent to E313        | WF-05082024-002623  | 1/27/2025     | FT-FY25-12262024-002623-A | <2                               | FT-FY25-12262024-002623-B | <2                               |
| WS-002624 | 5/8/2024              | 5/8/2025               | 3     | Cooler         | In open area adjacent to E313        | WF-05082024-002624  | 1/27/2025     | FT-FY25-12262024-002624-A | <2                               | FT-FY25-12262024-002624-B | <2                               |
| WS-002625 | 5/8/2024              | 5/8/2025               | 3     | Cooler         | In open area adjacent to E313        | WF-05082024-002625  | 1/27/2025     | FT-FY25-12262024-002625-A | <2                               | FT-FY25-12262024-002625-B | <2                               |
| WS-002626 | 5/8/2024              | 5/8/2025               | 2     | Bottle Filler  | In open area adjacent to E216        | WF-05082024-002626  | 1/27/2025     | FT-FY25-12262024-002626-A | <2                               | FT-FY25-12262024-002626-B | <2                               |
| WS-002627 | 5/8/2024              | 5/8/2025               | 2     | Cooler         | In open area adjacent to E216        | WF-05082024-002627  | 1/27/2025     | FT-FY25-12262024-002627-A | <2                               | FT-FY25-12262024-002627-B | <2                               |
| WS-002628 | 5/8/2024              | 5/8/2025               | 2     | Cooler         | In open area adjacent to E216        | WF-05082024-002628  | 1/27/2025     | FT-FY25-12262024-002628-A | <2                               | FT-FY25-12262024-002628-B | <2                               |
| WS-002631 | 5/8/2024              | 5/8/2025               | 1     | Bottle Filler  | In common area                       | WF-05082024-002631  | 1/27/2025     | FT-FY25-12262024-002631-A | <2                               | FT-FY25-12262024-002631-B | <2                               |
| WS-002632 | 5/8/2024              | 5/8/2025               | 1     | Cooler         | In common area                       | WF-05082024-002632  | 1/27/2025     | FT-FY25-12262024-002632-A | <2                               | FT-FY25-12262024-002632-B | <2                               |
| WS-002633 | 5/8/2024              | 5/8/2025               | 1     | Cooler         | In common area                       | WF-05082024-002633  | 1/27/2025     | FT-FY25-12262024-002633-A | <2                               | FT-FY25-12262024-002633-B | <2                               |
| WS-002634 | 8/13/2024             | 8/13/2025              | 1     | Combo Faucet   | In toddler room C102                 | WF-08132024-002634  | 1/27/2025     | FT-FY25-12262024-002634-A | <2                               | FT-FY25-12262024-002634-B | <2                               |
| WS-002635 | 5/8/2024              | 5/8/2025               | 1     | Combo Fountain | In toddler room C102                 | WF-05082024-002635  | 1/27/2025     | FT-FY25-12262024-002635-A | <2                               | FT-FY25-12262024-002635-B | <2                               |
| WS-002638 | 8/13/2024             | 8/13/2025              | 1     | Combo Faucet   | In infant room C101                  | WF-08132024-002638  | 1/27/2025     | FT-FY25-12262024-002638-A | <2                               | FT-FY25-12262024-002638-B | <2                               |
| WS-002639 | 5/8/2024              | 5/8/2025               | 1     | Combo Fountain | In infant room C101                  | WF-05082024-002639  | 1/27/2025     | FT-FY25-12262024-002639-A | <2                               | FT-FY25-12262024-002639-B | <2                               |
| WS-004142 | 5/8/2024              | 5/8/2025               | 2     | Cooler         | In hallway adjacent to 2214          | WF-05082024-004142  | 1/27/2025     | FT-FY25-12262024-004142-A | <2                               | FT-FY25-12262024-004142-B | <2                               |
| WS-004143 | 5/8/2024              | 5/8/2025               | 2     | Cooler         | In hallway adjacent to 2214          | WF-05082024-004143  | 1/27/2025     | FT-FY25-12262024-004143-A | <2                               | FT-FY25-12262024-004143-B | <2                               |
| WS-004145 | 5/8/2024              | 5/8/2025               | 2     | Cooler         | In classroom 2201 connecting hallway | WF-05082024-004145  | 1/27/2025     | FT-FY25-12262024-004145-A | <2                               | FT-FY25-12262024-004145-B | <2                               |
| WS-004146 | 5/8/2024              | 5/8/2025               | 2     | Cooler         | In classroom 2201 connecting hallway | WF-05082024-004146  | 1/27/2025     | FT-FY25-12262024-004146-A | <2                               | FT-FY25-12262024-004146-B | <2                               |

|           |           |           |              |                  |                                      |           |                    |           |                           |    |                           |    |
|-----------|-----------|-----------|--------------|------------------|--------------------------------------|-----------|--------------------|-----------|---------------------------|----|---------------------------|----|
| WS-004150 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In classroom 2109 connecting hallway | High Left | WF-05082024-004150 | 1/27/2025 | FT-FY25-12262024-004150-A | <2 | FT-FY25-12262024-004150-B | <2 |
| WS-004151 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In classroom 2109 connecting hallway | Low Right | WF-05082024-004151 | 1/27/2025 | FT-FY25-12262024-004151-A | <2 | FT-FY25-12262024-004151-B | <2 |
| WS-004153 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In hallway adjacent to room 2114     | High Left | WF-05082024-004153 | 1/27/2025 | FT-FY25-12262024-004153-A | <2 | FT-FY25-12262024-004153-B | <2 |
| WS-004154 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In hallway adjacent to room 2114     | Low Right | WF-05082024-004154 | 1/27/2025 | FT-FY25-12262024-004154-A | <2 | FT-FY25-12262024-004154-B | <2 |
| WS-004157 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In classroom 2104 connecting hallway | High Left | WF-05082024-004157 | 1/27/2025 | FT-FY25-12262024-004157-A | <2 | FT-FY25-12262024-004157-B | <2 |
| WS-004158 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In classroom 2104 connecting hallway | Low Right | WF-05082024-004158 | 1/27/2025 | FT-FY25-12262024-004158-A | <2 | FT-FY25-12262024-004158-B | <2 |
| WS-004161 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In classroom 2101 connecting hallway | High Left | WF-05082024-004161 | 1/27/2025 | FT-FY25-12262024-004161-A | <2 | FT-FY25-12262024-004161-B | <2 |
| WS-004162 | 5/8/2024  | 5/8/2025  | 1            | Cooler           | In classroom 2101 connecting hallway | High Left | WF-05082024-004162 | 1/27/2025 | FT-FY25-12262024-004162-A | <2 | FT-FY25-12262024-004162-B | <2 |
| WS-004175 | 5/8/2024  | 5/8/2025  | 2            | Cooler           | In classroom 2209 connecting hallway | High Left | WF-05082024-004175 | 1/27/2025 | FT-FY25-12262024-004175-A | <2 | FT-FY25-12262024-004175-B | <2 |
| WS-004176 | 5/8/2024  | 5/8/2025  | 2            | Cooler           | In classroom 2209 connecting hallway | Low Right | WF-05082024-004176 | 1/27/2025 | FT-FY25-12262024-004176-A | <2 | FT-FY25-12262024-004176-B | <2 |
| WS-004178 | 5/8/2024  | 5/8/2025  | 2            | Break Room       | In staff lounge 2207                 |           | WF-05082024-004178 | 1/27/2025 | FT-FY25-12262024-004178-A | <2 | FT-FY25-12262024-004178-B | <2 |
| WS-004180 | 5/8/2024  | 5/8/2025  | 2            | Cooler           | In classroom 2204 connecting hallway | High Left | WF-05082024-004180 | 1/27/2025 | FT-FY25-12262024-004180-A | <2 | FT-FY25-12262024-004180-B | <2 |
| WS-004181 | 5/8/2024  | 5/8/2025  | 2            | Cooler           | In classroom 2204 connecting hallway | Low Right | WF-05082024-004181 | 1/27/2025 | FT-FY25-12262024-004181-A | <2 | FT-FY25-12262024-004181-B | <2 |
| WS-004183 | 8/13/2024 | 8/13/2025 | Ground Floor | Classroom Faucet | In classroom 2011                    |           | WF-08132024-004183 | 1/27/2025 | FT-FY25-12262024-004183-A | <2 | FT-FY25-12262024-004183-B | <2 |
| WS-004184 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In classroom 2009 connecting hallway | High Left | WF-05082024-004184 | 1/27/2025 | FT-FY25-12262024-004184-A | <2 | FT-FY25-12262024-004184-B | <2 |
| WS-004185 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In classroom 2009 connecting hallway | Low Right | WF-05082024-004185 | 1/27/2025 | FT-FY25-12262024-004185-A | <2 | FT-FY25-12262024-004185-B | <2 |
| WS-004186 | 8/13/2024 | 8/13/2025 | Ground Floor | Classroom Faucet | In classroom 2009                    |           | WF-08132024-004186 | 1/27/2025 | FT-FY25-12262024-004186-A | <2 | FT-FY25-12262024-004186-B | <2 |
| WS-004187 | 5/8/2024  | 5/8/2025  | Ground Floor | Health Suite     | In health suite 2007                 |           | WF-05082024-004187 | 1/27/2025 | FT-FY25-12262024-004187-A | <2 | FT-FY25-12262024-004187-B | <2 |
| WS-004188 | 8/13/2024 | 8/13/2025 | Ground Floor | Classroom Faucet | In classroom 2006                    |           | WF-08132024-004188 | 1/27/2025 | FT-FY25-12262024-004188-A | <2 | FT-FY25-12262024-004188-B | <2 |
| WS-004189 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In classroom 2004 connecting hallway | High Left | WF-05082024-004189 | 1/27/2025 | FT-FY25-12262024-004189-A | <2 | FT-FY25-12262024-004189-B | <2 |
| WS-004190 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In classroom 2004 connecting hallway | Low Right | WF-05082024-004190 | 1/27/2025 | FT-FY25-12262024-004190-A | <2 | FT-FY25-12262024-004190-B | <2 |
| WS-004191 | 8/13/2024 | 8/13/2025 | Ground Floor | Classroom Faucet | In classroom 2004                    |           | WF-08132024-004191 | 1/27/2025 | FT-FY25-12262024-004191-A | <2 | FT-FY25-12262024-004191-B | <2 |
| WS-004192 | 8/13/2024 | 8/13/2025 | Ground Floor | Classroom Faucet | In classroom 2003                    |           | WF-08132024-004192 | 1/27/2025 | FT-FY25-12262024-004192-A | <2 | FT-FY25-12262024-004192-B | <2 |
| WS-004193 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In classroom 2001 connecting hallway | High Left | WF-05082024-004193 | 1/27/2025 | FT-FY25-12262024-004193-A | <2 | FT-FY25-12262024-004193-B | <2 |
| WS-004195 | 8/13/2024 | 8/13/2025 | Ground Floor | Classroom Faucet | In classroom 2001                    |           | WF-08132024-004195 | 1/27/2025 | FT-FY25-12262024-004195-A | <2 | FT-FY25-12262024-004195-B | <2 |
| WS-004196 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In hallway adjacent to room 2014     | High Left | WF-05082024-004196 | 1/27/2025 | FT-FY25-12262024-004196-A | <2 | FT-FY25-12262024-004196-B | <2 |
| WS-004197 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In hallway adjacent to room 2014     | Low Right | WF-05082024-004197 | 1/27/2025 | FT-FY25-12262024-004197-A | <2 | FT-FY25-12262024-004197-B | <2 |
| WS-004198 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In hallway adjacent to room 2B14     | High Left | WF-05082024-004198 | 1/27/2025 | FT-FY25-12262024-004198-A | <2 | FT-FY25-12262024-004198-B | <2 |
| WS-004199 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In hallway adjacent to room 2B14     | Low Right | WF-05082024-004199 | 1/27/2025 | FT-FY25-12262024-004199-A | <2 | FT-FY25-12262024-004199-B | <2 |
| WS-004201 | 8/13/2024 | 8/13/2025 | Basement     | Classroom Faucet | In classroom 2B11                    |           | WF-08132024-004201 | 1/27/2025 | FT-FY25-12262024-004201-A | <2 | FT-FY25-12262024-004201-B | <2 |
| WS-004202 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In classroom 2B09 connecting hallway | High Left | WF-05082024-004202 | 1/27/2025 | FT-FY25-12262024-004202-A | <2 | FT-FY25-12262024-004202-B | <2 |
| WS-004203 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In classroom 2B09 connecting hallway | Low Right | WF-05082024-004203 | 1/27/2025 | FT-FY25-12262024-004203-A | <2 | FT-FY25-12262024-004203-B | <2 |
| WS-004204 | 8/13/2024 | 8/13/2025 | Basement     | Classroom Faucet | In classroom 2B09                    |           | WF-08132024-004204 | 1/27/2025 | FT-FY25-12262024-004204-A | <2 | FT-FY25-12262024-004204-B | <2 |
| WS-004205 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In classroom 2B04 connecting hallway | High Left | WF-05082024-004205 | 1/27/2025 | FT-FY25-12262024-004205-A | <2 | FT-FY25-12262024-004205-B | <2 |
| WS-004206 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In classroom 2B04 connecting hallway | Low Right | WF-05082024-004206 | 1/27/2025 | FT-FY25-12262024-004206-A | <2 | FT-FY25-12262024-004206-B | <2 |
| WS-004208 | 5/8/2024  | 5/8/2025  | Ground Floor | Bottle Filler    | In hallway adjacent to 3001          |           | WF-05082024-004208 | 1/27/2025 | FT-FY25-12262024-004208-A | <2 | FT-FY25-12262024-004208-B | <2 |
| WS-004210 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In classroom 2B01 connecting hallway | High Left | WF-05082024-004210 | 1/27/2025 | FT-FY25-12262024-004210-A | <2 | FT-FY25-12262024-004210-B | <2 |
| WS-004211 | 5/8/2024  | 5/8/2025  | Basement     | Cooler           | In classroom 2B01 connecting hallway | Low Right | WF-05082024-004211 | 1/27/2025 | FT-FY25-12262024-004211-A | <2 | FT-FY25-12262024-004211-B | <2 |
| WS-004215 | 5/8/2024  | 5/8/2025  | Ground Floor | Cooler           | In hallway adjacent to 3001          |           | WF-05082024-004215 | 1/27/2025 | FT-FY25-12262024-004215-A | <2 | FT-FY25-12262024-004215-B | <2 |

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

| Record ID  | Filter Installed Date | Filter Expiration Date | Floor        | Device Type    | Device Location           | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|--------------|----------------|---------------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| WS- 002637 | 1/8/2025              | 1/8/2026               | 1            | Food Prep Sink | In meal distribution C107 | WF-01082025-002637  | 1/27/2025     | FT-FY25-12262024-002637-A | <2                               | FT-FY25-12262024-002637-B | <2                               |
| WS- 002641 | 1/8/2025              | 1/8/2026               | 1            | Food Prep Sink | In meal distribution E108 | WF-01082025-002641  | 1/27/2025     | FT-FY25-12262024-002641-A | <2                               | FT-FY25-12262024-002641-B | <2                               |
| WS- 004213 | 1/8/2025              | 1/8/2026               | Ground Floor | Food Prep Sink | In kitchen room 2038 Left | WF-01082025-004213  | 1/27/2025     | FT-FY25-12262024-004213-A | <2                               | FT-FY25-12262024-004213-B | <2                               |
| WS- 004214 | 1/8/2025              | 1/8/2026               | Ground Floor | Food Prep Sink | In kitchen 2038 Right     | WF-01082025-004214  | 1/27/2025     | FT-FY25-12262024-004214-A | <2                               | FT-FY25-12262024-004214-B | <2                               |

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.