



Randle Highlands ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004142	5/7/2019	5/7/2020	2	Cooler	In hallway adjacent to 2214 High Left	WF-05072019-004142	10/22/2019	FT-FY20-102019-004142-A	<1	FT-FY20-102019-004142-B	<1
WS-004143	5/7/2019	5/7/2020	2	Cooler	In hallway adjacent to 2214 Low Right	WF-05072019-004143	10/22/2019	FT-FY20-102019-004143-A	<1	FT-FY20-102019-004143-B	<1
WS-004145	5/7/2019	5/7/2020	2	Cooler	In classroom 2201 connecting hallway High Left	WF-05072019-004145	10/22/2019	FT-FY20-102019-004145-A	<1	FT-FY20-102019-004145-B	<1
WS-004146	5/7/2019	5/7/2020	2	Cooler	In classroom 2201 connecting hallway Low Right	WF-05072019-004146	10/22/2019	FT-FY20-102019-004146-A	<1	FT-FY20-102019-004146-B	<1
WS-004150	5/7/2019	5/7/2020	1	Cooler	In classroom 2109 connecting hallway High Left	WF-05072019-004150	10/22/2019	FT-FY20-102019-004150-A	<1	FT-FY20-102019-004150-B	<1
WS-004151	5/7/2019	5/7/2020	1	Cooler	In classroom 2109 connecting hallway Low Right	WF-05072019-004151	10/22/2019	FT-FY20-102019-004151-A	<1	FT-FY20-102019-004151-B	<1
WS-004153	5/7/2019	5/7/2020	1	Cooler	In hallway adjacent to room 2114 High Left	WF-05072019-004153	10/22/2019	FT-FY20-102019-004153-A	<1	FT-FY20-102019-004153-B	<1
WS-004154	5/7/2019	5/7/2020	1	Cooler	In hallway adjacent to room 2114 Low Right	WF-05072019-004154	10/22/2019	FT-FY20-102019-004154-A	<1	FT-FY20-102019-004154-B	<1
WS-004158	5/7/2019	5/7/2020	1	Cooler	In classroom 2104 connecting hallway Low Right	WF-05072019-004158	10/22/2019	FT-FY20-102019-004158-A	<1	FT-FY20-102019-004158-B	<1
WS-004161	5/7/2019	5/7/2020	1	Cooler	In classroom 2101 connecting hallway High Left	WF-05072019-004161	10/22/2019	FT-FY20-102019-004161-A	<1	FT-FY20-102019-004161-B	<1
WS-004162	5/7/2019	5/7/2020	1	Cooler	In classroom 2101 connecting hallway High Left	WF-05072019-004162	10/22/2019	FT-FY20-102019-004162-A	<1	FT-FY20-102019-004162-B	<1
WS-004175	5/7/2019	5/7/2020	2	Cooler	In classroom 2209 connecting hallway High Left	WF-05072019-004175	10/22/2019	FT-FY20-102019-004175-A	<1	FT-FY20-102019-004175-B	<1
WS-004176	5/7/2019	5/7/2020	2	Cooler	In classroom 2209 connecting hallway Low Right	WF-05072019-004176	10/22/2019	FT-FY20-102019-004176-A	<1	FT-FY20-102019-004176-B	<1
WS-004178	5/7/2019	5/7/2020	2	Break Room	In staff lounge 2207	WF-05072019-004178	10/22/2019	FT-FY20-102019-004178-A	<1	FT-FY20-102019-004178-B	<1
WS-004180	5/7/2019	5/7/2020	2	Cooler	In classroom 2204 connecting hallway High Left	WF-05072019-004180	10/22/2019	FT-FY20-102019-004180-A	<1	FT-FY20-102019-004180-B	<1
WS-004181	5/7/2019	5/7/2020	2	Cooler	In classroom 2204 connecting hallway Low Right	WF-05072019-004181	10/22/2019	FT-FY20-102019-004181-A	<1	FT-FY20-102019-004181-B	<1
WS-004183	9/18/2019	9/18/2020	Ground Floor	Classroom Faucet	In classroom 2011	WF-09182019-004183	10/22/2019	FT-FY20-102019-004183-A	<1	FT-FY20-102019-004183-B	<1
WS-004184	5/7/2019	5/7/2020	Ground Floor	Cooler	In classroom 2009 connecting hallway High Left	WF-05072019-004184	10/22/2019	FT-FY20-102019-004184-A	<1	FT-FY20-102019-004184-B	<1
WS-004185	5/7/2019	5/7/2020	Ground Floor	Cooler	In classroom 2009 connecting hallway Low Right	WF-05072019-004185	10/22/2019	FT-FY20-102019-004185-A	<1	FT-FY20-102019-004185-B	<1
WS-004186	9/18/2019	9/18/2020	Ground Floor	Classroom Faucet	In classroom 2009	WF-09182019-004186	10/22/2019	FT-FY20-102019-004186-A	<1	FT-FY20-102019-004186-B	<1
WS-004187	5/7/2019	5/7/2020	Ground Floor	Health Suite	In health suite 2007	WF-05072019-004187	10/22/2019	FT-FY20-102019-004187-A	<1	FT-FY20-102019-004187-B	<1
WS-004188	9/18/2019	9/18/2020	Ground Floor	Classroom Faucet	In classroom 2006	WF-09182019-004188	10/22/2019	FT-FY20-102019-004188-A	<1	FT-FY20-102019-004188-B	<1
WS-004189	5/7/2019	5/7/2020	Ground Floor	Cooler	In classroom 2004 connecting hallway High Left	WF-05072019-004189	10/22/2019	FT-FY20-102019-004189-A	<1	FT-FY20-102019-004189-B	<1
WS-004190	5/7/2019	5/7/2020	Ground Floor	Cooler	In classroom 2004 connecting hallway Low Right	WF-05072019-004190	10/22/2019	FT-FY20-102019-004190-A	<1	FT-FY20-102019-004190-B	<1
WS-004191	9/18/2019	9/18/2020	Ground Floor	Classroom Faucet	In classroom 2004	WF-09182019-004191	10/22/2019	FT-FY20-102019-004191-A	2.3	FT-FY20-102019-004191-B	<1
WS-004192	9/18/2019	9/18/2020	Ground Floor	Classroom Faucet	In classroom 2003	WF-09182019-004192	10/22/2019	FT-FY20-102019-004192-A	<1	FT-FY20-102019-004192-B	<1
WS-004193	5/7/2019	5/7/2020	Ground Floor	Cooler	In classroom 2001 connecting hallway High Left	WF-05072019-004193	10/22/2019	FT-FY20-102019-004193-A	<1	FT-FY20-102019-004193-B	<1
WS-004195	9/18/2019	9/18/2020	Ground Floor	Classroom Faucet	In classroom 2001	WF-09182019-004195	10/22/2019	FT-FY20-102019-004195-A	<1	FT-FY20-102019-004195-B	<1
WS-004196	5/7/2019	5/7/2020	Ground Floor	Cooler	In hallway adjacent to room 2014 High Left	WF-05072019-004196	10/22/2019	FT-FY20-102019-004196-A	<1	FT-FY20-102019-004196-B	<1
WS-004197	5/7/2019	5/7/2020	Ground Floor	Cooler	In hallway adjacent to room 2014 Low Right	WF-05072019-004197	10/22/2019	FT-FY20-102019-004197-A	<1	FT-FY20-102019-004197-B	<1
WS-004198	5/7/2019	5/7/2020	Basement	Cooler	In hallway adjacent to room 2B14 High Left	WF-05072019-004198	10/22/2019	FT-FY20-102019-004198-A	<1	FT-FY20-102019-004198-B	<1
WS-004199	5/7/2019	5/7/2020	Basement	Cooler	In hallway adjacent to room 2B14 Low Right	WF-05072019-004199	10/22/2019	FT-FY20-102019-004199-A	<1	FT-FY20-102019-004199-B	<1
WS-004201	9/18/2019	9/18/2020	Basement	Classroom Faucet	In classroom 2B11	WF-09182019-004201	10/22/2019	FT-FY20-102019-004201-A	<1	FT-FY20-102019-004201-B	<1

WS- 004202	5/7/2019	5/7/2020	Basement	Cooler	In classroom 2B09 connecting hallway	High	Left	WF-05072019-004202	10/22/2019	FT-FY20-102019-004202-A	<1	FT-FY20-102019-004202-B	<1
WS- 004204	9/18/2019	9/18/2020	Basement	Classroom Faucet	In classroom 2B09			WF-09182019-004204	10/22/2019	FT-FY20-102019-004204-A	<1	FT-FY20-102019-004204-B	<1
WS- 004206	5/7/2019	5/7/2020	Basement	Cooler	In classroom 2B04 connecting hallway	Low	Right	WF-05072019-004206	10/22/2019	FT-FY20-102019-004206-A	<1	FT-FY20-102019-004206-B	<1
WS- 004210	5/7/2019	5/7/2020	Basement	Cooler	In classroom 2B01 connecting hallway	High	Left	WF-05072019-004210	10/22/2019	FT-FY20-102019-004210-A	<1	FT-FY20-102019-004210-B	<1
WS- 004211	5/7/2019	5/7/2020	Basement	Cooler	In classroom 2B01 connecting hallway	Low	Right	WF-05072019-004211	10/22/2019	FT-FY20-102019-004211-A	<1	FT-FY20-102019-004211-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004214	7/15/2019	7/15/2020	Ground Floor	Food Prep Sink	In kitchen 2038	Right	WF-07152019-004214	10/22/2019	FT-FY20-102019-004214-A	<1	FT-FY20-102019-004214-B	<1