



Randle Highlands Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002601	8/14/2023	8/14/2024	2	Combo Faucet	In classroom E201	Low Left	WF-08142023-002601	1/18/2024	FT-FY24-11272023-002601-A	<1	FT-FY24-11272023-002601-B	<1
WS- 002604	8/14/2023	8/14/2024	2	Combo Faucet	In classroom E207	Low Left	WF-08142023-002604	1/18/2024	FT-FY24-11272023-002604-A	<1	FT-FY24-11272023-002604-B	<1
WS- 002606	5/10/2023	5/10/2024	2	Break Room	In staff lounge E223		WF-05102023-002606	1/18/2024	FT-FY24-11272023-002606-A	<1	FT-FY24-11272023-002606-B	<1
WS- 002608	8/14/2023	8/14/2024	2	Combo Faucet	In classroom E216	Low Left	WF-08142023-002608	1/18/2024	FT-FY24-11272023-002608-A	<1	FT-FY24-11272023-002608-B	<1
WS- 002610	5/10/2023	5/10/2024	2	Health Suite	In wellness room E215		WF-05102023-002610	1/18/2024	FT-FY24-11272023-002610-A	<1	FT-FY24-11272023-002610-B	<1
WS- 002612	8/14/2023	8/14/2024	3	Combo Faucet	In classroom E301	Low Left	WF-08142023-002612	1/18/2024	FT-FY24-11272023-002612-A	<1	FT-FY24-11272023-002612-B	<1
WS- 002615	8/14/2023	8/14/2024	3	Combo Faucet	In classroom E305	Low Left	WF-08142023-002615	1/18/2024	FT-FY24-11272023-002615-A	<1	FT-FY24-11272023-002615-B	<1
WS- 002618	8/14/2023	8/14/2024	3	Combo Faucet	In classroom E319	Low Left	WF-08142023-002618	1/18/2024	FT-FY24-11272023-002618-A	<1	FT-FY24-11272023-002618-B	<1
WS- 002621	8/14/2023	8/14/2024	3	Combo Faucet	In classroom E313	Low Left	WF-08142023-002621	1/18/2024	FT-FY24-11272023-002621-A	<1	FT-FY24-11272023-002621-B	<1
WS- 002623	5/10/2023	5/10/2024	3	Bottle Filler	In open area adjacent to E313		WF-05102023-002623	1/18/2024	FT-FY24-11272023-002623-A	<1	FT-FY24-11272023-002623-B	<1
WS- 002626	5/10/2023	5/10/2024	2	Bottle Filler	In open area adjacent to E216		WF-05102023-002626	1/18/2024	FT-FY24-11272023-002626-A	<1	FT-FY24-11272023-002626-B	<1
WS- 002627	5/10/2023	5/10/2024	2	Cooler	In open area adjacent to E216	High Left	WF-05102023-002627	1/18/2024	FT-FY24-11272023-002627-A	<1	FT-FY24-11272023-002627-B	<1
WS- 002631	5/10/2023	5/10/2024	1	Bottle Filler	In common area		WF-05102023-002631	1/18/2024	FT-FY24-11272023-002631-A	<1	FT-FY24-11272023-002631-B	<1
WS- 002638	8/14/2023	8/14/2024	1	Combo Faucet	In infant room C101		WF-08142023-002638	1/18/2024	FT-FY24-11272023-002638-A	<1	FT-FY24-11272023-002638-B	<1
WS- 004142	5/10/2023	5/10/2024	2	Cooler	In hallway adjacent to 2214	High Left	WF-05102023-004142	1/18/2024	FT-FY24-11272023-004142-A	<1	FT-FY24-11272023-004142-B	<1
WS- 004143	5/10/2023	5/10/2024	2	Cooler	In hallway adjacent to 2214	Low Right	WF-05102023-004143	1/18/2024	FT-FY24-11272023-004143-A	<1	FT-FY24-11272023-004143-B	<1
WS- 004145	5/10/2023	5/10/2024	2	Cooler	In classroom 2201 connecting hallway	High Left	WF-05102023-004145	1/18/2024	FT-FY24-11272023-004145-A	<1	FT-FY24-11272023-004145-B	<1
WS- 004146	5/10/2023	5/10/2024	2	Cooler	In classroom 2201 connecting hallway	Low Right	WF-05102023-004146	1/18/2024	FT-FY24-11272023-004146-A	<1	FT-FY24-11272023-004146-B	<1
WS- 004150	5/10/2023	5/10/2024	1	Cooler	In classroom 2109 connecting hallway	High Left	WF-05102023-004150	1/18/2024	FT-FY24-11272023-004150-A	<1	FT-FY24-11272023-004150-B	<1
WS- 004151	5/10/2023	5/10/2024	1	Cooler	In classroom 2109 connecting hallway	Low Right	WF-05102023-004151	1/18/2024	FT-FY24-11272023-004151-A	<1	FT-FY24-11272023-004151-B	<1
WS- 004153	5/10/2023	5/10/2024	1	Cooler	In hallway adjacent to room 2114	High Left	WF-05102023-004153	1/18/2024	FT-FY24-11272023-004153-A	<1	FT-FY24-11272023-004153-B	<1
WS- 004157	5/10/2023	5/10/2024	1	Cooler	In classroom 2104 connecting hallway	High Left	WF-05102023-004157	1/18/2024	FT-FY24-11272023-004157-A	1.0	FT-FY24-11272023-004157-B	<1
WS- 004158	5/10/2023	5/10/2024	1	Cooler	In classroom 2104 connecting hallway	Low Right	WF-05102023-004158	1/18/2024	FT-FY24-11272023-004158-A	<1	FT-FY24-11272023-004158-B	<1
WS- 004161	5/10/2023	5/10/2024	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05102023-004161	1/18/2024	FT-FY24-11272023-004161-A	<1	FT-FY24-11272023-004161-B	1.1
WS- 004162	5/10/2023	5/10/2024	1	Cooler	In classroom 2101 connecting hallway	High Left	WF-05102023-004162	1/18/2024	FT-FY24-11272023-004162-A	1.0	FT-FY24-11272023-004162-B	<1
WS- 004175	5/10/2023	5/10/2024	2	Cooler	In classroom 2209 connecting hallway	High Left	WF-05102023-004175	1/18/2024	FT-FY24-11272023-004175-A	<1	FT-FY24-11272023-004175-B	<1
WS- 004176	5/10/2023	5/10/2024	2	Cooler	In classroom 2209 connecting hallway	Low Right	WF-05102023-004176	1/18/2024	FT-FY24-11272023-004176-A	<1	FT-FY24-11272023-004176-B	<1
WS- 004178	5/10/2023	5/10/2024	2	Break Room	In staff lounge 2207		WF-05102023-004178	1/18/2024	FT-FY24-11272023-004178-A	<1	FT-FY24-11272023-004178-B	<1
WS- 004180	5/10/2023	5/10/2024	2	Cooler	In classroom 2204 connecting hallway	High Left	WF-05102023-004180	1/18/2024	FT-FY24-11272023-004180-A	<1	FT-FY24-11272023-004180-B	<1
WS- 004181	5/10/2023	5/10/2024	2	Cooler	In classroom 2204 connecting hallway	Low Right	WF-05102023-004181	1/18/2024	FT-FY24-11272023-004181-A	<1	FT-FY24-11272023-004181-B	<1
WS- 004183	8/14/2023	8/14/2024	Ground Floor	Classroom Faucet	In classroom 2011		WF-08142023-004183	1/18/2024	FT-FY24-11272023-004183-A	<1	FT-FY24-11272023-004183-B	<1
WS- 004186	8/14/2023	8/14/2024	Ground Floor	Classroom Faucet	In classroom 2009		WF-08142023-004186	1/18/2024	FT-FY24-11272023-004186-A	<1	FT-FY24-11272023-004186-B	<1
WS- 004187	5/10/2023	5/10/2024	Ground Floor	Health Suite	In health suite 2007		WF-05102023-004187	1/18/2024	FT-FY24-11272023-004187-A	<1	FT-FY24-11272023-004187-B	<1
WS- 004188	8/14/2023	8/14/2024	Ground Floor	Classroom Faucet	In classroom 2006		WF-08142023-004188	1/18/2024	FT-FY24-11272023-004188-A	<1	FT-FY24-11272023-004188-B	<1

WS- 004189	5/10/2023	5/10/2024	Ground Floor	Cooler	In classroom 2004 connecting hallway	High Left	WF-05102023-004189	1/18/2024	FT-FY24-11272023-004189-A	<1	FT-FY24-11272023-004189-B	<1
WS- 004190	5/10/2023	5/10/2024	Ground Floor	Cooler	In classroom 2004 connecting hallway	Low Right	WF-05102023-004190	1/18/2024	FT-FY24-11272023-004190-A	<1	FT-FY24-11272023-004190-B	<1
WS- 004191	8/14/2023	8/14/2024	Ground Floor	Classroom Faucet	In classroom 2004		WF-08142023-004191	1/18/2024	FT-FY24-11272023-004191-A	<1	FT-FY24-11272023-004191-B	<1
WS- 004192	8/14/2023	8/14/2024	Ground Floor	Classroom Faucet	In classroom 2003		WF-08142023-004192	1/18/2024	FT-FY24-11272023-004192-A	<1	FT-FY24-11272023-004192-B	<1
WS- 004193	5/10/2023	5/10/2024	Ground Floor	Cooler	In classroom 2001 connecting hallway	High Left	WF-05102023-004193	1/18/2024	FT-FY24-11272023-004193-A	<1	FT-FY24-11272023-004193-B	<1
WS- 004194	5/10/2023	5/10/2024	Ground Floor	Cooler	In classroom 2001 connecting hallway	Low Right	WF-05102023-004194	1/18/2024	FT-FY24-11272023-004194-A	<1	FT-FY24-11272023-004194-B	<1
WS- 004195	8/14/2023	8/14/2024	Ground Floor	Classroom Faucet	In classroom 2001		WF-08142023-004195	1/18/2024	FT-FY24-11272023-004195-A	<1	FT-FY24-11272023-004195-B	1.2
WS- 004196	5/10/2023	5/10/2024	Ground Floor	Cooler	In hallway adjacent to room 2014	High Left	WF-05102023-004196	1/18/2024	FT-FY24-11272023-004196-A	<1	FT-FY24-11272023-004196-B	<1
WS- 004197	5/10/2023	5/10/2024	Ground Floor	Cooler	In hallway adjacent to room 2014	Low Right	WF-05102023-004197	1/18/2024	FT-FY24-11272023-004197-A	<1	FT-FY24-11272023-004197-B	<1
WS- 004198	5/10/2023	5/10/2024	Basement	Cooler	In hallway adjacent to room 2B14	High Left	WF-05102023-004198	1/18/2024	FT-FY24-11272023-004198-A	<1	FT-FY24-11272023-004198-B	<1
WS- 004199	5/10/2023	5/10/2024	Basement	Cooler	In hallway adjacent to room 2B14	Low Right	WF-05102023-004199	1/18/2024	FT-FY24-11272023-004199-A	<1	FT-FY24-11272023-004199-B	<1
WS- 004201	8/14/2023	8/14/2024	Basement	Classroom Faucet	In classroom 2B11		WF-08142023-004201	1/18/2024	FT-FY24-11272023-004201-A	<1	FT-FY24-11272023-004201-B	<1
WS- 004202	5/10/2023	5/10/2024	Basement	Cooler	In classroom 2B09 connecting hallway	High Left	WF-05102023-004202	1/18/2024	FT-FY24-11272023-004202-A	<1	FT-FY24-11272023-004202-B	<1
WS- 004203	5/10/2023	5/10/2024	Basement	Cooler	In classroom 2B09 connecting hallway	Low Right	WF-05102023-004203	1/18/2024	FT-FY24-11272023-004203-A	<1	FT-FY24-11272023-004203-B	<1
WS- 004204	8/14/2023	8/14/2024	Basement	Classroom Faucet	In classroom 2B09		WF-08142023-004204	1/18/2024	FT-FY24-11272023-004204-A	1.2	FT-FY24-11272023-004204-B	1.4
WS- 004205	5/10/2023	5/10/2024	Basement	Cooler	In classroom 2B04 connecting hallway	High Left	WF-05102023-004205	1/18/2024	FT-FY24-11272023-004205-A	<1	FT-FY24-11272023-004205-B	<1
WS- 004206	5/10/2023	5/10/2024	Basement	Cooler	In classroom 2B04 connecting hallway	Low Right	WF-05102023-004206	1/18/2024	FT-FY24-11272023-004206-A	<1	FT-FY24-11272023-004206-B	<1
WS- 004208	5/10/2023	5/10/2024	Ground Floor	Bottle Filler	In hallway adjacent to 3001		WF-05102023-004208	1/18/2024	FT-FY24-11272023-004208-A	<1	FT-FY24-11272023-004208-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002637	12/22/2022	12/22/2023	1	Food Prep Sink	In meal distribution C107	WF-12222022-002637	1/18/2024	FT-FY24-11272023-002637-A	<1	FT-FY24-11272023-002637-B	<1	
WS- 002641	12/22/2022	12/22/2023	1	Food Prep Sink	In meal distribution E108	WF-12222022-002641	1/18/2024	FT-FY24-11272023-002641-A	<1	FT-FY24-11272023-002641-B	<1	
WS- 004213	12/22/2022	12/22/2023	Ground Floor	Food Prep Sink	In kitchen room 2038	Left	WF-12222022-004213	1/18/2024	FT-FY24-11272023-004213-A	<1	FT-FY24-11272023-004213-B	<1
WS- 004214	12/22/2022	12/22/2023	Ground Floor	Food Prep Sink	In kitchen 2038	Right	WF-12222022-004214	1/18/2024	FT-FY24-11272023-004214-A	<1	FT-FY24-11272023-004214-B	<1