



Raymond Education Campus Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-016375	7/18/2023	7/18/2024	1	Break Room	In room B-129	WF-07182023-016375	8/18/2023	FT-FY24-08082023-016375-A	<1	FT-FY24-08082023-016375-B	<1	
WS-016377	7/18/2023	7/18/2024	1	Combo Fountain	In wellness B-127	WF-07182023-016377	8/18/2023	FT-FY24-08082023-016377-A	<1	FT-FY24-08082023-016377-B	<1	
WS-016379	7/18/2023	7/18/2024	1	Cooler	In hallway across from room B-125	Low Left	WF-07182023-016379	8/18/2023	FT-FY24-08082023-016379-A	<1	FT-FY24-08082023-016379-B	<1
WS-016380	7/18/2023	7/18/2024	1	Cooler	In hallway across from room B-125	High Right	WF-07182023-016380	8/18/2023	FT-FY24-08082023-016380-A	<1	FT-FY24-08082023-016380-B	<1
WS-016381	7/18/2023	7/18/2024	1	Health Suite	In health suite B-121B		WF-07182023-016381	8/18/2023	FT-FY24-08082023-016381-A	<1	FT-FY24-08082023-016381-B	<1
WS-016383	7/18/2023	7/18/2024	1	Bottle Filler	In cafeteria		WF-07182023-016383	8/18/2023	FT-FY24-08082023-016383-A	<1	FT-FY24-08082023-016383-B	<1
WS-016384	7/18/2023	7/18/2024	1	Cooler	In cafeteria	Low Left	WF-07182023-016384	8/18/2023	FT-FY24-08082023-016384-A	<1	FT-FY24-08082023-016384-B	<1
WS-016385	7/18/2023	7/18/2024	1	Cooler	In cafeteria	High Right	WF-07182023-016385	8/18/2023	FT-FY24-08082023-016385-A	<1	FT-FY24-08082023-016385-B	<1
WS-016386	7/18/2023	7/18/2024	1	Break Room	In B-107 parent resource room		WF-07182023-016386	8/18/2023	FT-FY24-08082023-016386-A	<1	FT-FY24-08082023-016386-B	<1
WS-016387	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-101		WF-07182023-016387	8/18/2023	FT-FY24-08082023-016387-A	2.4	FT-FY24-08082023-016387-B	<1
WS-016388	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-101		WF-07182023-016388	8/18/2023	FT-FY24-08082023-016388-A	<1	FT-FY24-08082023-016388-B	<1
WS-016389	7/18/2023	7/18/2024	1	Bottle Filler	In hallway adjacent to room A-102		WF-07182023-016389	8/18/2023	FT-FY24-08082023-016389-A	<1	FT-FY24-08082023-016389-B	<1
WS-016390	7/18/2023	7/18/2024	1	Cooler	In hallway adjacent to room A-102	Low Left	WF-07182023-016390	8/18/2023	FT-FY24-08082023-016390-A	<1	FT-FY24-08082023-016390-B	<1
WS-016391	7/18/2023	7/18/2024	1	Cooler	In hallway adjacent to room A-102	High Right	WF-07182023-016391	8/18/2023	FT-FY24-08082023-016391-A	<1	FT-FY24-08082023-016391-B	<1
WS-016392	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-102		WF-07182023-016392	8/18/2023	FT-FY24-08082023-016392-A	1.5	FT-FY24-08082023-016392-B	<1
WS-016393	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-102		WF-07182023-016393	8/18/2023	FT-FY24-08082023-016393-A	<1	FT-FY24-08082023-016393-B	<1
WS-016394	7/18/2023	7/18/2024	1	Break Room	In room A-103		WF-07182023-016394	8/18/2023	FT-FY24-08082023-016394-A	<1	FT-FY24-08082023-016394-B	<1
WS-016395	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-105		WF-07182023-016395	8/18/2023	FT-FY24-08082023-016395-A	<1	FT-FY24-08082023-016395-B	<1
WS-016396	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-105		WF-07182023-016396	8/18/2023	FT-FY24-08082023-016396-A	<1	FT-FY24-08082023-016396-B	<1
WS-016397	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-106		WF-07182023-016397	8/18/2023	FT-FY24-08082023-016397-A	<1	FT-FY24-08082023-016397-B	<1
WS-016398	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-106		WF-07182023-016398	8/18/2023	FT-FY24-08082023-016398-A	<1	FT-FY24-08082023-016398-B	<1
WS-016399	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-107		WF-07182023-016399	8/18/2023	FT-FY24-08082023-016399-A	<1	FT-FY24-08082023-016399-B	<1
WS-016400	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-107		WF-07182023-016400	8/18/2023	FT-FY24-08082023-016400-A	<1	FT-FY24-08082023-016400-B	<1
WS-016401	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-108		WF-07182023-016401	8/18/2023	FT-FY24-08082023-016401-A	<1	FT-FY24-08082023-016401-B	<1
WS-016402	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-108		WF-07182023-016402	8/18/2023	FT-FY24-08082023-016402-A	<1	FT-FY24-08082023-016402-B	<1
WS-016403	7/18/2023	7/18/2024	1	Combo Faucet	In classroom A-109		WF-07182023-016403	8/18/2023	FT-FY24-08082023-016403-A	<1	FT-FY24-08082023-016403-B	<1
WS-016404	7/18/2023	7/18/2024	1	Combo Fountain	In classroom A-109		WF-07182023-016404	8/18/2023	FT-FY24-08082023-016404-A	<1	FT-FY24-08082023-016404-B	<1
WS-016405	7/18/2023	7/18/2024	1	Bottle Filler	In the gym		WF-07182023-016405	8/18/2023	FT-FY24-08082023-016405-A	<1	FT-FY24-08082023-016405-B	<1
WS-016406	7/18/2023	7/18/2024	1	Cooler	In the gym	Low Left	WF-07182023-016406	8/18/2023	FT-FY24-08082023-016406-A	<1	FT-FY24-08082023-016406-B	<1
WS-016407	7/18/2023	7/18/2024	1	Cooler	In the gym	High Right	WF-07182023-016407	8/18/2023	FT-FY24-08082023-016407-A	<1	FT-FY24-08082023-016407-B	<1
WS-016409	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-206		WF-07182023-016409	8/18/2023	FT-FY24-08082023-016409-A	<1	FT-FY24-08082023-016409-B	<1
WS-016411	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-207		WF-07182023-016411	8/18/2023	FT-FY24-08082023-016411-A	<1	FT-FY24-08082023-016411-B	<1
WS-016413	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-208		WF-07182023-016413	8/18/2023	FT-FY24-08082023-016413-A	<1	FT-FY24-08082023-016413-B	<1
WS-016414	7/18/2023	7/18/2024	2	Bottle Filler	In hallway across from room B-207		WF-07182023-016414	8/18/2023	FT-FY24-08082023-016414-A	<1	FT-FY24-08082023-016414-B	<1
WS-016415	7/18/2023	7/18/2024	2	Cooler	In hallway across from room B-207	Low Left	WF-07182023-016415	8/18/2023	FT-FY24-08082023-016415-A	<1	FT-FY24-08082023-016415-B	<1

WS-016416	7/18/2023	7/18/2024	2	Cooler	In hallway across from room B-207	High Right	WF-07182023-016416	8/18/2023	FT-FY24-08082023-016416-A	<1	FT-FY24-08082023-016416-B	<1
WS-016418	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-205		WF-07182023-016418	8/18/2023	FT-FY24-08082023-016418-A	<1	FT-FY24-08082023-016418-B	<1
WS-016420	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-204		WF-07182023-016420	8/18/2023	FT-FY24-08082023-016420-A	<1	FT-FY24-08082023-016420-B	<1
WS-016422	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-201		WF-07182023-016422	8/18/2023	FT-FY24-08082023-016422-A	<1	FT-FY24-08082023-016422-B	<1
WS-016423	7/18/2023	7/18/2024	2	Bottle Filler	In hallway adjacent to room B-201		WF-07182023-016423	8/18/2023	FT-FY24-08082023-016423-A	<1	FT-FY24-08082023-016423-B	<1
WS-016424	7/18/2023	7/18/2024	2	Cooler	In hallway adjacent to room B-201	Low Left	WF-07182023-016424	8/18/2023	FT-FY24-08082023-016424-A	<1	FT-FY24-08082023-016424-B	<1
WS-016425	7/18/2023	7/18/2024	2	Cooler	In hallway adjacent to room B-201	High Right	WF-07182023-016425	8/18/2023	FT-FY24-08082023-016425-A	<1	FT-FY24-08082023-016425-B	<1
WS-016427	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-202		WF-07182023-016427	8/18/2023	FT-FY24-08082023-016427-A	<1	FT-FY24-08082023-016427-B	<1
WS-016429	7/18/2023	7/18/2024	2	Combo Fountain	In classroom B-203		WF-07182023-016429	8/18/2023	FT-FY24-08082023-016429-A	<1	FT-FY24-08082023-016429-B	<1
WS-016430	7/18/2023	7/18/2024	2	Break Room	In room A-201		WF-07182023-016430	8/18/2023	FT-FY24-08082023-016430-A	<1	FT-FY24-08082023-016430-B	<1
WS-016432	7/18/2023	7/18/2024	2	Combo Fountain	In classroom A-202		WF-07182023-016432	8/18/2023	FT-FY24-08082023-016432-A	<1	FT-FY24-08082023-016432-B	<1
WS-016434	7/18/2023	7/18/2024	2	Combo Fountain	In classroom A-205		WF-07182023-016434	8/18/2023	FT-FY24-08082023-016434-A	<1	FT-FY24-08082023-016434-B	<1
WS-016435	7/18/2023	7/18/2024	2	Bottle Filler	In hallway across from room A-205		WF-07182023-016435	8/18/2023	FT-FY24-08082023-016435-A	<1	FT-FY24-08082023-016435-B	<1
WS-016436	7/18/2023	7/18/2024	2	Cooler	In hallway across from room A-205	Low Left	WF-07182023-016436	8/18/2023	FT-FY24-08082023-016436-A	<1	FT-FY24-08082023-016436-B	<1
WS-016437	7/18/2023	7/18/2024	2	Cooler	In hallway across from room A-205	High Right	WF-07182023-016437	8/18/2023	FT-FY24-08082023-016437-A	<1	FT-FY24-08082023-016437-B	<1
WS-016439	7/18/2023	7/18/2024	2	Combo Fountain	In classroom A-206		WF-07182023-016439	8/18/2023	FT-FY24-08082023-016439-A	<1	FT-FY24-08082023-016439-B	<1
WS-016441	7/18/2023	7/18/2024	2	Combo Fountain	In classroom A-207		WF-07182023-016441	8/18/2023	FT-FY24-08082023-016441-A	<1	FT-FY24-08082023-016441-B	<1
WS-016442	7/18/2023	7/18/2024	2	Bottle Filler	In hallway across from room A-207		WF-07182023-016442	8/18/2023	FT-FY24-08082023-016442-A	<1	FT-FY24-08082023-016442-B	<1
WS-016443	7/18/2023	7/18/2024	2	Cooler	In hallway across from room A-207	Low Left	WF-07182023-016443	8/18/2023	FT-FY24-08082023-016443-A	<1	FT-FY24-08082023-016443-B	<1
WS-016444	7/18/2023	7/18/2024	2	Cooler	In hallway across from room A-207	High Right	WF-07182023-016444	8/18/2023	FT-FY24-08082023-016444-A	<1	FT-FY24-08082023-016444-B	<1
WS-016446	7/18/2023	7/18/2024	2	Combo Fountain	In classroom A-208		WF-07182023-016446	8/18/2023	FT-FY24-08082023-016446-A	<1	FT-FY24-08082023-016446-B	<1
WS-016448	7/18/2023	7/18/2024	2	Combo Fountain	In classroom A-209		WF-07182023-016448	8/18/2023	FT-FY24-08082023-016448-A	<1	FT-FY24-08082023-016448-B	<1
WS-016455	7/18/2023	7/18/2024	3	Bottle Filler	In hallway across from room B-305		WF-07182023-016455	8/18/2023	FT-FY24-08082023-016455-A	<1	FT-FY24-08082023-016455-B	<1
WS-016456	7/18/2023	7/18/2024	3	Cooler	In hallway across from room B-305	Low Left	WF-07182023-016456	8/18/2023	FT-FY24-08082023-016456-A	<1	FT-FY24-08082023-016456-B	<1
WS-016457	7/18/2023	7/18/2024	3	Cooler	In hallway across from room B-305	High Right	WF-07182023-016457	8/18/2023	FT-FY24-08082023-016457-A	<1	FT-FY24-08082023-016457-B	<1
WS-016464	7/18/2023	7/18/2024	3	Bottle Filler	In hallway adjacent to B-301		WF-07182023-016464	8/18/2023	FT-FY24-08082023-016464-A	<1	FT-FY24-08082023-016464-B	<1
WS-016465	7/18/2023	7/18/2024	3	Cooler	In hallway adjacent to B-301	Low Left	WF-07182023-016465	8/18/2023	FT-FY24-08082023-016465-A	<1	FT-FY24-08082023-016465-B	<1
WS-016466	7/18/2023	7/18/2024	3	Cooler	In hallway adjacent to B-301	High Right	WF-07182023-016466	8/18/2023	FT-FY24-08082023-016466-A	<1	FT-FY24-08082023-016466-B	<1
WS-016480	7/18/2023	7/18/2024	3	Bottle Filler	In hallway across from room A-305		WF-07182023-016480	8/18/2023	FT-FY24-08082023-016480-A	<1	FT-FY24-08082023-016480-B	<1
WS-016481	7/18/2023	7/18/2024	3	Cooler	In hallway across from room A-305	Low Left	WF-07182023-016481	8/18/2023	FT-FY24-08082023-016481-A	<1	FT-FY24-08082023-016481-B	<1
WS-016482	7/18/2023	7/18/2024	3	Cooler	In hallway across from room A-305	High Right	WF-07182023-016482	8/18/2023	FT-FY24-08082023-016482-A	<1	FT-FY24-08082023-016482-B	<1
WS-016485	7/18/2023	7/18/2024	3	Bottle Filler	In music room A-307		WF-07182023-016485	8/18/2023	FT-FY24-08082023-016485-A	<1	FT-FY24-08082023-016485-B	<1
WS-016486	7/18/2023	7/18/2024	3	Cooler	In music room A-307	Low Left	WF-07182023-016486	8/18/2023	FT-FY24-08082023-016486-A	<1	FT-FY24-08082023-016486-B	<1
WS-016487	7/18/2023	7/18/2024	3	Cooler	In music room A-307	High Right	WF-07182023-016487	8/18/2023	FT-FY24-08082023-016487-A	<1	FT-FY24-08082023-016487-B	<1

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016382	7/18/2023	7/18/2024	1	Food Prep Sink	In the kitchen	WF-07182023-016382	8/18/2023	FT-FY24-08082023-016382-A	23.4	FT-FY24-08082023-016382-B	<1