



RAYMOND EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st	2nd Draw - Sample ID	Final Result - 2nd
1	RAYMOND EDUCATIONAL CAMPUS	WS- 008641	8/7/2016	1	Cooler	In classroom 110	FT-72016-008641-A	< 1	FT-72016-008641-B	< 1
2	RAYMOND EDUCATIONAL CAMPUS	WS- 008642	8/7/2016	1	Cooler	In hallway adjacent to room 110	FT-72016-008642-A	< 1	FT-72016-008642-B	< 1
3	RAYMOND EDUCATIONAL CAMPUS	WS- 008643	8/7/2016	1	Cooler	In classroom 111	FT-72016-008643-A	< 1	FT-72016-008643-B	< 1
4	RAYMOND EDUCATIONAL CAMPUS	WS- 008644	8/7/2016	1	Cooler	In classroom 113	FT-72016-008644-A	< 1	FT-72016-008644-B	< 1
5	RAYMOND EDUCATIONAL CAMPUS	WS- 008645	8/7/2016	1	Cooler	In hallway between girls' and boys' restrooms	FT-72016-008645-A	< 1	FT-72016-008645-B	< 1
6	RAYMOND EDUCATIONAL CAMPUS	WS- 008646	8/7/2016	1	Cooler	In classroom 115	FT-72016-008646-A	< 1	FT-72016-008646-B	< 1
7	RAYMOND EDUCATIONAL CAMPUS	WS- 008647	8/7/2016	1	Cooler	In classroom 117	FT-72016-008647-A	< 1	FT-72016-008647-B	< 1
8	RAYMOND EDUCATIONAL CAMPUS	WS- 008648	8/7/2016	1	Cooler	In classroom 116	FT-82016-008648-A	< 1	FT-82016-008648-B	< 1
9	RAYMOND EDUCATIONAL CAMPUS	WS- 008650	8/7/2016	2	Cooler	In hallway between girls' and boys' restrooms	FT-72016-008650-A	< 1	FT-72016-008650-B	< 1
10	RAYMOND EDUCATIONAL CAMPUS	WS- 008651	8/7/2016	2	Cooler	In hallway adjacent to stairwell	FT-72016-008651-A	< 1	FT-72016-008651-B	< 1
11	RAYMOND EDUCATIONAL CAMPUS	WS- 008652	8/7/2016	1	Bottle Filler	In hallway adjacent to main office (bottle filler)	FT-82016-008652-A	< 1	FT-82016-008652-B	< 1
12	RAYMOND EDUCATIONAL CAMPUS	WS- 008653	8/7/2016	1	Cooler	In hallway adjacent to main office	FT-72016-008653-A	< 1	FT-72016-008653-B	< 1
13	RAYMOND EDUCATIONAL CAMPUS	WS- 008654	8/7/2016	1	Cooler	In health suite	FT-72016-008654-A	< 1	FT-72016-008654-B	< 1
14	RAYMOND EDUCATIONAL CAMPUS	WS- 008655	8/7/2016	1	Cooler	In hallway across from kitchen	FT-72016-008655-A	< 1	FT-72016-008655-B	< 1
15	RAYMOND EDUCATIONAL CAMPUS	WS- 008656	8/7/2016	1	Food Prep Sink	In kitchen Left	FT-72016-008656-A	< 1	FT-72016-008656-B	< 1
16	RAYMOND EDUCATIONAL CAMPUS	WS- 008658	8/7/2016	2	Bottle Filler	In hallway adjacent to room 22 (bottle filler)	FT-82016-008658-A	< 1	FT-82016-008658-B	< 1
17	RAYMOND EDUCATIONAL CAMPUS	WS- 008659	8/7/2016	2	Cooler	In hallway adjacent to room 22	FT-72016-008659-A	< 1	FT-72016-008659-B	< 1
18	RAYMOND EDUCATIONAL CAMPUS	WS- 008660	8/7/2016	2	Cooler	In hallway adjacent to room 26	FT-72016-008660-A	< 1	FT-72016-008660-B	< 1
19	RAYMOND EDUCATIONAL CAMPUS	WS- 008661	8/7/2016	3	Cooler	In hallway adjacent to room 36	FT-72016-008661-A	< 1	FT-72016-008661-B	< 1
20	RAYMOND EDUCATIONAL CAMPUS	WS- 008663	8/7/2016	3	Cooler	In hallway adjacent to room 30	FT-72016-008663-A	< 1	FT-72016-008663-B	< 1