



RAYMOND LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008640	Utility	Ground Floor	In incinerator room accessed through Counselor 1 office	WT-042916-8657- A	33.8	WT-042916-8657- B	6.7	Non-drinking water source turned off until further analysis complete			
2 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008641	Cooler	1	in classroom 110	WT-042916-8658- A	< 1	WT-042916-8658- B	< 1				
3 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008642	Cooler	1	in hallway adjacent to classroom 110	WT-042916-8659- A	< 1	WT-042916-8659- B	< 1				
4 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008643	Cooler	1	in classroom 111	WT-042916-8660- A	< 1	WT-042916-8660- B	< 1				
5 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008644	Cooler	1	in classroom 113	WT-042916-8661- A	< 1	WT-042916-8661- B	< 1				
6 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008645	Cooler	1	in hallway between girls and boys restrooms	WT-042916-8662- A	< 1	WT-042916-8662- B	< 1				
7 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008646	Cooler	1	in classroom 115	WT-042916-8663- A	< 1	WT-042916-8663- B	< 1				
8 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008647	Cooler	1	in classroom 117	WT-042916-8664- A	< 1	WT-042916-8664- B	< 1				
9 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008648	Cooler	1	in classroom 116	WT-042916-8665- A	< 1	WT-042916-8665- B	< 1				
10 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008649	Break Room	2	in teacher's lounge	WT-042916-8666- A	< 1	WT-042916-8666- B	< 1				
11 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008650	Cooler	2	in hallway between girls and boys restrooms	WT-042916-8667- A	< 1	WT-042916-8667- B	< 1				
12 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008651	Cooler	2	in hallway adjacent to stairwell	WT-042916-8668- A	< 1	WT-042916-8668- B	< 1				
13 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008652	Other	1	in hallway adjacent to main office (water bottle refill)	WT-042916-8669- A	< 1	WT-042916-8669- B	< 1				
14 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008653	Cooler	1	in hallway adjacent to main office	WT-042916-8670- A	< 1	WT-042916-8670- B	< 1				
15 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008654	Cooler	1	in health suite	WT-042916-8671- A	< 1	WT-042916-8671- B	< 1				
16 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008655	Cooler	1	in hallway across from kitchen	WT-042916-8672- A	< 1	WT-042916-8672- B	< 1				
17 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008656	Kitchen	1	in kitchen Left	WT-042916-8673- A	< 1	WT-042916-8673- B	< 1				
18 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008657	Kitchen	1	in kitchen Right	WT-042916-8674- A	< 1	WT-042916-8674- B	< 1				
19 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008658	Other	2	in hallway adjacent to classroom 22 (water bottle refill)	WT-042916-8675- A	< 1	WT-042916-8675- B	< 1				
20 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008659	Cooler	2	in hallway adjacent to classroom 22	WT-042916-8676- A	< 1	WT-042916-8676- B	< 1				
21 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008660	Cooler	2	in hallway adjacent to classroom 26	WT-042916-8677- A	< 1	WT-042916-8677- B	< 1				
22 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008661	Cooler	3	in hallway adjacent to classroom 36	WT-042916-8678- A	< 1	WT-042916-8678- B	< 1				
23 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008662	Break Room	3	in teacher's lounge room 304	WT-042916-8679- A	< 1	WT-042916-8679- B	< 1				
24 RAYMOND EDUCATIONAL CAMPUS	5/11/2016	WS-008663	Cooler	3	in hallway adjacent to classroom 30	WT-042916-8680- A	< 1	WT-042916-8680- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.