



# Raymond EC Lead Water Test Results



## FY18 Filter Test

| Less than 5 ppb - Devices Requiring No Remediation |                       |                        |       |                  |  |                    |               |                         |                                  |                         |                                  |
|--|-----------------------|------------------------|-------|------------------|--|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID  | Filter Installed Date | Filter Expiration Date | Floor | Device Type      | Device Location                                | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 008641   | 6/14/2017             | 6/14/2018              | 1     | Cooler           | In classroom 110                               | WF-62017-008641    | 11/29/2017    | FT-FY18--62017-008641-A | <1                               | FT-FY18--62017-008641-B | <1                               |
| WS- 008647   | 6/14/2017             | 6/14/2018              | 1     | Cooler           | In classroom 117                               | WF-62017-008647    | 11/29/2017    | FT-FY18--62017-008647-A | <1                               | FT-FY18--62017-008647-B | <1                               |
| WS- 008648   | 6/14/2017             | 6/14/2018              | 1     | Cooler           | In classroom 116                               | WF-62017-008648    | 11/29/2017    | FT-FY18--62017-008648-A | <1                               | FT-FY18--62017-008648-B | <1                               |
| WS- 008655   | 6/14/2017             | 6/14/2018              | 1     | Cooler           | In hallway across from kitchen                 | WF-62017-008655    | 11/29/2017    | FT-FY18--62017-008655-A | <1                               | FT-FY18--62017-008655-B | <1                               |
| WS- 008658   | 6/14/2017             | 6/14/2018              | 2     | Bottle Filler    | In hallway adjacent to room 22 (bottle filler) | WF-62017-008658    | 11/29/2017    | FT-FY18--62017-008658-A | <1                               | FT-FY18--62017-008658-B | <1                               |
| WS- 008661   | 6/14/2017             | 6/14/2018              | 3     | Cooler           | In hallway adjacent to room 36                 | WF-62017-008661    | 11/29/2017    | FT-FY18--62017-008661-A | <1                               | FT-FY18--62017-008661-B | <1                               |
| WS- 009140   | 11/8/2017             | 11/8/2018              | 1     | Bathroom         | In classroom 111 in bathroom                   | WF-112017-009140   | 11/29/2017    | FT-FY18-112017-009140-A | <1                               | FT-FY18-112017-009140-B | <1                               |
| WS- 009152   | 11/8/2017             | 11/8/2018              | 2     | Classroom Faucet | In classroom 20                                | WF-112017-009152   | 11/29/2017    | FT-FY18-112017-009152-A | <1                               | FT-FY18-112017-009152-B | <1                               |
| WS- 009154   | 11/8/2017             | 11/8/2018              | 1     | Classroom Faucet | In classroom 113                               | WF-112017-009154   | 11/29/2017    | FT-FY18-112017-009154-A | <1                               | FT-FY18-112017-009154-B | <1                               |
| WS- 009158   | 11/8/2017             | 11/8/2018              | 1     | Classroom Faucet | In classroom 110                               | WF-112017-009158   | 11/29/2017    | FT-FY18-112017-009158-A | <1                               | FT-FY18-112017-009158-B | <1                               |
| WS- 009159   | 11/8/2017             | 11/8/2018              | 1     | Classroom Faucet | In classroom 111                               | WF-112017-009159   | 11/29/2017    | FT-FY18-112017-009159-A | <1                               | FT-FY18-112017-009159-B | <1                               |

## Food Prep Sink

| Less than 5 ppb - Devices Requiring No Remediation |       |                |                    |               |                         |                                  |                         |                                  |  |  |
|--|-------|----------------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|--|--|
| RECORD ID  | Floor | Device Type    | Device Location    | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |  |  |
| WS- 008656   | 1     | Food Prep Sink | In kitchen<br>Left | 11/29/2017    | FT-FY18-102017-008656-A | <1                               | FT-FY18-102017-008656-B | <1                               |  |  |