



Raymond EC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008641	5/21/2018	5/21/2019	1	Cooler	In classroom 110	WF-05212018-008641	11/29/2018	FT-FY19-112018-008641-A	<1	FT-FY19-112018-008641-B	<1
WS-008642	5/21/2018	5/21/2019	1	Cooler	In hallway adjacent to room 110	WF-05212018-008642	11/29/2018	FT-FY19-112018-008642-A	<1	FT-FY19-112018-008642-B	<1
WS-008643	5/21/2018	5/21/2019	1	Cooler	In classroom 111	WF-05212018-008643	11/29/2018	FT-FY19-112018-008643-A	<1	FT-FY19-112018-008643-B	<1
WS-008644	5/21/2018	5/21/2019	1	Cooler	In classroom 113	WF-05212018-008644	11/29/2018	FT-FY19-112018-008644-A	<1	FT-FY19-112018-008644-B	<1
WS-008645	5/21/2018	5/21/2019	1	Cooler	In hallway between girls' and boys' restrooms	WF-05212018-008645	11/29/2018	FT-FY19-112018-008645-A	<1	FT-FY19-112018-008645-B	<1
WS-008646	5/21/2018	5/21/2019	1	Cooler	In classroom 115	WF-05212018-008646	11/29/2018	FT-FY19-112018-008646-A	<1	FT-FY19-112018-008646-B	<1
WS-008647	5/21/2018	5/21/2019	1	Cooler	In classroom 117	WF-05212018-008647	11/29/2018	FT-FY19-112018-008647-A	<1	FT-FY19-112018-008647-B	<1
WS-008648	5/21/2018	5/21/2019	1	Cooler	In classroom 116	WF-05212018-008648	11/29/2018	FT-FY19-112018-008648-A	<1	FT-FY19-112018-008648-B	<1
WS-008649	5/21/2018	5/21/2019	2	Break Room	In staff lounge	WF-05212018-008649	11/29/2018	FT-FY19-112018-008649-A	<1	FT-FY19-112018-008649-B	<1
WS-008650	5/21/2018	5/21/2019	2	Cooler	In hallway between girls' and boys' restrooms	WF-05212018-008650	11/29/2018	FT-FY19-112018-008650-A	<1	FT-FY19-112018-008650-B	<1
WS-008651	11/16/2018	11/16/2019	2	Cooler	In hallway adjacent to stairwell	WF-11162018-008651	11/29/2018	FT-FY19-112018-008651-A	<1	FT-FY19-112018-008651-B	<1
WS-008652	5/21/2018	5/21/2019	1	Bottle Filler	In hallway adjacent to main office (bottle filler)	WF-05212018-008652	11/29/2018	FT-FY19-112018-008652-A	<1	FT-FY19-112018-008652-B	<1
WS-008653	5/21/2018	5/21/2019	1	Cooler	In hallway adjacent to main office	WF-05212018-008653	11/29/2018	FT-FY19-112018-008653-A	<1	FT-FY19-112018-008653-B	<1
WS-008654	5/21/2018	5/21/2019	1	Cooler	In health suite	WF-05212018-008654	11/29/2018	FT-FY19-112018-008654-A	<1	FT-FY19-112018-008654-B	<1
WS-008655	5/21/2018	5/21/2019	1	Cooler	In hallway across from kitchen	WF-05212018-008655	11/29/2018	FT-FY19-112018-008655-A	<1	FT-FY19-112018-008655-B	<1
WS-008658	5/21/2018	5/21/2019	2	Bottle Filler	In hallway adjacent to room 22 (bottle filler)	WF-05212018-008658	11/29/2018	FT-FY19-112018-008658-A	<1	FT-FY19-112018-008658-B	<1
WS-008659	5/21/2018	5/21/2019	2	Cooler	In hallway adjacent to room 22	WF-05212018-008659	11/29/2018	FT-FY19-112018-008659-A	<1	FT-FY19-112018-008659-B	<1
WS-008660	5/21/2018	5/21/2019	2	Cooler	In hallway adjacent to room 26	WF-05212018-008660	11/29/2018	FT-FY19-112018-008660-A	<1	FT-FY19-112018-008660-B	<1
WS-008661	5/21/2018	5/21/2019	3	Cooler	In hallway adjacent to room 36	WF-05212018-008661	11/29/2018	FT-FY19-112018-008661-A	<1	FT-FY19-112018-008661-B	<1
WS-008662	5/21/2018	5/21/2019	3	Break Room	In staff lounge room 304	WF-05212018-008662	11/29/2018	FT-FY19-112018-008662-A	<1	FT-FY19-112018-008662-B	<1
WS-008663	5/21/2018	5/21/2019	3	Cooler	In hallway adjacent to room 30	WF-05212018-008663	11/29/2018	FT-FY19-112018-008663-A	<1	FT-FY19-112018-008663-B	<1
WS-009140	10/15/2018	10/15/2019	1	Bathroom	In classroom 111 in bathroom	WF-10152018-009140	11/29/2018	FT-FY19-112018-009140-A	<1	FT-FY19-112018-009140-B	<1
WS-009141	10/15/2018	10/15/2019	1	Bathroom	In classroom 110 in bathroom	WF-10152018-009141	11/29/2018	FT-FY19-112018-009141-A	<1	FT-FY19-112018-009141-B	<1
WS-009142	10/15/2018	10/15/2019	1	Bathroom	In classroom 113 in bathroom	WF-10152018-009142	11/29/2018	FT-FY19-112018-009142-A	<1	FT-FY19-112018-009142-B	<1
WS-009143	10/15/2018	10/15/2019	1	Bathroom	In classroom 116 in bathroom	WF-10152018-009143	11/29/2018	FT-FY19-112018-009143-A	<1	FT-FY19-112018-009143-B	<1
WS-009152	10/15/2018	10/15/2019	2	Classroom Faucet	In classroom 20	WF-10152018-009152	11/29/2018	FT-FY19-112018-009152-A	<1	FT-FY19-112018-009152-B	<1
WS-009153	10/15/2018	10/15/2019	3	Classroom Faucet	In classroom 36	Right WF-10152018-009153	11/29/2018	FT-FY19-112018-009153-A	<1	FT-FY19-112018-009153-B	<1
WS-009154	10/15/2018	10/15/2019	1	Classroom Faucet	In classroom 113	WF-10152018-009154	11/29/2018	FT-FY19-112018-009154-A	<1	FT-FY19-112018-009154-B	<1
WS-009155	10/15/2018	10/15/2019	1	Classroom Faucet	In classroom 115	WF-10152018-009155	11/29/2018	FT-FY19-112018-009155-A	<1	FT-FY19-112018-009155-B	<1
WS-009156	10/15/2018	10/15/2019	1	Classroom Faucet	In classroom 116	WF-10152018-009156	11/29/2018	FT-FY19-112018-009156-A	<1	FT-FY19-112018-009156-B	<1
WS-009157	10/15/2018	10/15/2019	1	Classroom Faucet	In classroom 117	WF-10152018-009157	11/29/2018	FT-FY19-112018-009157-A	<1	FT-FY19-112018-009157-B	<1

WS-009158	10/15/2018	10/15/2019	1	Classroom Faucet	In classroom 110	WF-10152018-009158	11/29/2018	FT-FY19-112018-009158-A	<1	FT-FY19-112018-009158-B	<1
WS-009159	10/15/2018	10/15/2019	1	Classroom Faucet	In classroom 111	WF-10152018-009159	11/29/2018	FT-FY19-112018-009159-A	<1	FT-FY19-112018-009159-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008840	1	Food Prep Sink	In kitchen third clockwise from entry	11/29/2018	FT-FY19-112018-008840-A	<1	FT-FY19-112018-008840-B	<1