



RIGGS LASALLE REC LEAD WATER TEST RESULTS



Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location			1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1 RIGGS LASALLE RECREATION CENTER	WS- 012016	9/22/2016	1	Cooler	In hallway in between restrooms	Low	Left	FT-82016-012016-A	< 1	FT-82016-012016-B	< 1
2 RIGGS LASALLE RECREATION CENTER	WS- 012017	9/22/2016	1	Cooler	In hallway in between restrooms	High	Right	FT-82016-012017-A	< 1	FT-82016-012017-B	< 1
3 RIGGS LASALLE RECREATION CENTER	WS- 012019	9/22/2016	1	Food Prep Sink	In kitchen 107			FT-82016-012019-A	< 1	FT-82016-012019-B	< 1