



Riggs Lasalle Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012016	12/19/2022	12/19/2023	1	Cooler	In hallway in between restrooms	Low	Left	WF-12192022-012016	2/15/2023	FT-FY23-01192023-012016-A	<1	FT-FY23-01192023-012016-B	<1
WS- 012017	12/19/2022	12/19/2023	1	Cooler	In hallway in between restrooms	High	Right	WF-12192022-012017	2/15/2023	FT-FY23-01192023-012017-A	<1	FT-FY23-01192023-012017-B	<1
WS- 012019	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen 107			WF-12192022-012019	2/15/2023	FT-FY23-01192023-012019-A	<1	FT-FY23-01192023-012019-B	<1